

**EVALUACIÓN DEL PORCENTAJE DE CARBONO DEL ACERO DE LOS DIENTES
DE PALA PARA RETROEXCAVADORA, APLICANDO ANÁLISIS DE VARIANZA DE
UN SOLO FACTOR PARA VERIFICAR LAS PROPIEDADES FÍSICO - MECÁNICAS
DE RESISTENCIA A LA TRACCIÓN Y DUREZA.**

Julio Edgar Vivas Pacheco

Trabajo de Grado Proyecto Aplicado para optar al título de:
Profesional en Química

Universidad Nacional Abierta y a Distancia
Escuela de Ciencias Básicas, Tecnología e Ingeniería
Programa de Química
Junio
2018

Dedicatoria

Dedico este trabajo de grado a:

A Dios Santo Todopoderoso.

A mi Madre, por su apoyo, confianza, desinterés y nobleza.

A mi Padre que en paz descansé.

A mis Hijos para que sigan el ejemplo.

A mi Amada María Cristina por su voz de aliento, transparencia y su amor.

Agradecimientos

Expreso mis agradecimientos a:

INDUMIL, Fabrica Santa Bárbara, Sogamoso Boyacá.

Universidad Nacional Abierta y a Distancia, UNAD.

Lic. Johny Roberto Rodríguez Director Nacional Programa de Química.

Ing. Luis Gabriel Prieto Ríos Director del Proyecto.

Profesionales Jurado Calificador.

Coronel ® Rubén Alonso Mogollón Director Fabrica.

Ing. Jair Nino Jefe Grupo Calidad.

Analistas compañeros del laboratorio Químico.

Tabla de Contenido

1. DEFINICION DEL PROBLEMA	1
1.1 Planteamiento del problema.....	1
2. JUSTIFICACION	2
3. OBJETIVOS	3
3.1 Objetivo General.....	3
3.2 Objetivos Especificos.....	3
4. MARCO REFERENCIAL.....	4
4.1 Elementos químicos contenidos en % de los aceros	4
4.2 Influencia en los aceros de los elementos Químicos	4
4.2.1 Niquel.....	4
4.2.2 Cromo.	4
4.2.3 Molibdeno.....	5
4.2.4 Manganeso	5
4.2.5 Silicio	5
4.2.6 Azufre.	5
4.2.7 Fosforo	5
4.2.8 Carbono.....	6
4.3 Diagrama Hierro - Carbono	6
4.3.1 Hierro alfa (α).	7
4.3.2 Hierro gamma (γ).....	7
4.3.3 Hierro delta (δ).....	7
4.3.4 Punto peritéctico.....	8
4.3.5 Punto eutéctico.....	8
4.3.6 Punto eutectoide.....	8
4.3.7 Fe- Fe_3C (metalestable)	8
4.3.8 Fe-C (estable)	8
4.4 Fases del Diagrama Hierro - Carbono	9
4.4.1 Fase Austenítica (0% hasta el 1,76%)	9

4.4.2 Zona de trabajo de este proyecto según el diagrama Hierro Carbono.	9
4.5 Ficha Técnica del diente para retroexcavadora	11
4.5.1 Características	11
4.5.2 Ventajas.....	11
4.5.3 Beneficios.....	11
4.6 Espectrometría de emisión atómica	12
4.6.1 Secuencia de eventos para Análisis Espectro químico	12
4.6.2 Porqué gas Argón y No aire	12
4.6.3 Calibración de un instrumento analítico	13
4.7 Resistencia a la Tracción.....	13
4.8 Dureza.....	14
4.9 Equipos utilizados en los ensayos.....	14
5. METODOLOGÍA.....	15
5.1 Recursos.....	15
5.1.1 Laboratorio de Ensayos INDUMIL Sogamoso, Boyacá	15
5.1.2 Materia Prima	15
5.2 Equipos	15
5.2.1 Espectrómetro de emisión atómica	15
5.2.2 Maquina Universal de Ensayos	17
5.2.3 Durómetro Universal	19
5.2.4 Microscopio Metalográfico.....	20
5.3 Normas	20
5.3.1 Norma para el ensayo y análisis de la composición química.....	20
5.3.2 Norma para el ensayo y análisis de la dureza	20
5.3.3 Norma para el ensayo y análisis de la resistencia a la Tracción	21
5.4 Diseño Experimental.....	21
5.4.1 Tratamiento de la muestra Original	21
5.4.2 Caracterización Físico Química.....	21
5.4.3 Planeación del Experimento	23
5.4.4 Modelo Matematico	23

5.4.5 El objetivo del experimento de análisis de Varianza con un solo factor	24
5.4.6 Experimentos con un solo factor: El análisis de Varianza.....	24
5.4.7 Teorema de Cochran aplicado a esta Investigación como Proyecto.....	26
6. RESULTADOS	30
6.1 Resultados Obtenidos del experimento en la Resistencia a la Tracción	30
6.2 Resultados análisis de la Varianza con un solo factor de una manera más formal de Resistencia a la Traccion	35
6.3 Comparativo de los resultados obtenidos en el acero original Vs resultados del acero reformulado en la Resistencia a la Tracción	36
6.4 Resultados Obtenidos del experimento en la Dureza	38
6.5 Resultados análisis de la Varianza con un solo factor de una manera más formal de la Dureza	44
6.6 Comparativo de los resultados obtenidos en el acero original Vs resultados del acero reformulado en la Dureza.....	44
6.7 Análisis de Resultados	46
7. CONCLUSIONES.....	47
8. RECOMENDACIONES.....	49
9. LISTA DE REFERENCIAS.....	50

Lista de tablas

Tabla 1. Rangos composición química en % de las curvas del espectrómetro	15
Tabla 2. Partes del Espectrómetro - Spectrolab.....	16
Tabla 3. Partes de la Maquina Universal de Ensayos	18
Tabla 4. Partes del Durómetro Universal.....	19
Tabla 5. Composición Química % obtenida de la muestra original	20
Tabla 6. Convenciones términos del análisis de Varianza para el método con un solo factor.....	25
Tabla 7. Tabla del análisis de varianza para el método con un solo factor.....	26
Tabla 8. Numeración de la corrida experimental.....	28
Tabla 9. Secuencia aleatoria del experimento.....	28
Tabla 10. Porcentaje de Carbono por niveles.	29
Tabla 11. Resistencia a la tracción observada con cinco niveles de % de carbono y cinco replicas.....	30
Tabla 12. Datos Resistencia a la tracción observada con cinco niveles de % de carbono y cinco replicas , con Totales y Promedios	33
Tabla 13. Resultados Análisis de Varianza de los datos de la Resistencia a la Tracción.	34
Tabla 14. Tabla de distribución de los puntos F de los puntos porcentuales.....	36
Tabla 15. Cuadro Comparativo de los resultados obtenidos en la acero original Vs resultados del acero reformulado.....	36
Tabla 16. Dureza observada HRC, con cinco niveles de Porcentaje de Carbono y cinco replicas.....	38
Tabla 17. Datos de Dureza observada HRC, con cinco niveles de porcentaje de Carbono y cinco replicas con Totales y promedios	41
Tabla 18. Análisis de Varianza de los datos de la Dureza	43
Tabla 19. Cuadro Comparativo de los resultados obtenidos de la Dureza en la acero original Vs resultados del acero reformulado	44

Lista de Figuras.

Figura 1. Diagrama de fases Hierro – Carbono que muestra la relación entre equilibrios estables de Hierro – Grafito (líneas discontinuas) y las reacciones meta estables de Hierro – Cementita (líneas continuas)Rangos composición química en % de las curvas del espectrómetro	10
Figura 2. Diente para retroexcavadora.....	11
Figura 3. Espectrómetro de emisión atómica.....	17
Figura 4. Maquina Universal de ensayos.....	18
Figura 5. Durómetro Universal	19
Figura 6. Registro Análisis de composición química del diente original	22
Figura 7. Dureza primera toma diente original 30,2 en escala Rockwell C	22
Figura 8. Resistencia a la Tracción diente original en escala Kgf/mm ²	23
Figura 9. Numero de corrida 2, Probeta de 0,3 % Carbono.....	30
Figura 10. Numero de corrida 8, Probeta de 0,35 % Carbono.....	31
Figura 11. Numero de corrida 17, Probeta de 0,45 % Carbono.....	31
Figura 12. Numero de corrida 17, Probeta de 0,45 % Carbono.....	32
Figura 13. Numero de corrida 25, Probeta de 0,50 % Carbono.....	32
Figura 14. Grafico Resistencia a la traccion de 46,25 Kgf/mm ² .acero original	37
Figura 15. Grafico resultados Resistencia a la Traccion Kgf/mm ² .acero reformulado....	37
Figura 16. Numero de corrida 2, Probeta de 0,30 % Carbono. Dureza de 20,2 HRC	39
Figura 17. Numero de corrida 6, Probeta de 0,35 % Carbono. Dureza de 24,1 HRC	39
Figura 18. Numero de corrida 12, Probeta de 0,40 % Carbono. Dureza de 30,4 HRC ...	40
Figura 19. Numero de corrida 18, Probeta de 0,45 % Carbono. Dureza de 39,0 HRC ...	40
Figura 20. Numero de corrida 24, Probeta de 0,50 % Carbono. Dureza de 47,2 HRC ...	41
Figura 21. Grafico de la Dureza de 31,06 H.R.C. obtenida en el acero original.....	45
Figura 22. Grafico resultados de Dureza en H.R.C. obtenidos del acero reformulado....	45

RESUMEN.

El presente proyecto aplicado tiene como objetivo principal la elaboración de un nuevo acero realizando una caracterización del comportamiento de las propiedades mecánicas de resistencia a la tracción y dureza del acero con aplicaciones industriales diversas al variar únicamente el porcentaje de Carbono. La elaboración de este acero surge debido a la necesidad de satisfacer a la industria actual de materiales nacionales que cumplan con criterios de calidad y durabilidad similares a los materiales importados, los cuales son los que se utilizan comercialmente y representan altos costos en su adquisición. El estudio partió de realizar una caracterización experimental de un acero importado que es muy utilizado industrialmente; el cual es con el que se encuentran fabricados los dientes de pala para retroexcavadora. Las pruebas experimentales de este material como la composición química, la dureza y resistencia a la tracción fueron tomadas como referencia para la elaboración del nuevo acero. Teniendo los resultados de la caracterización experimental, se procedió a realizar la formulación del nuevo acero realizando la variación de un solo factor; el porcentaje de Carbono. Una vez formulado el material, se efectuó un análisis técnico aplicando el análisis de varianza y sus resultados en cada nivel de los diferentes porcentajes de Carbono. Los datos obtenidos demuestran que la variación en el porcentaje de Carbono es el factor preponderante en la determinación de las características de dureza y resistencia a la tracción. En consecuencia, el nuevo acero formulado tiene características similares a las del acero importado y se plantea que su fabricación tenga aplicaciones industriales de uso metalmecánico y minero.

Palabras Clave: Diente para retroexcavadora, Acero, Resistencia a la tracción, Dureza, Metalografía, varianza, diagrama Hierro Carbono, Variación de un solo factor, Elementos químicos de un acero.

ABSTRACT

The main objective of this applied project is the development of a new steel, characterizing the behavior of the mechanical properties of tensile strength and hardness of steel with diverse industrial applications by varying only the percentage of Carbon. The development of this steel arises due to the need to satisfy the current industry of domestic materials that meet criteria of quality and durability similar to imported materials, which are those that are used commercially and represent high costs in their acquisition. He studied from an experimental characterization of an imported steel that is widely used industrially; which is the one with which the backhoe loader teeth are manufactured. The experimental tests of this material such as chemical composition, hardness and tensile strength were taken as reference for the development of the new steel. Taking the results of the experimental characterization, we proceeded to make the formulation of the new steel making the variation of a single factor; the percentage of Carbon. Once the material was formulated, a technical analysis was carried out applying the analysis of variance and its results in each level of the different percentages of Carbon. The data obtained show that the variation in the percentage of Carbon is the predominant factor in the determination of hardness and tensile strength characteristics. Consequently, the new formulated steel has characteristics similar to those of imported steel and it is proposed that its manufacture has industrial applications for metal-mechanic and mining use.

Key words: Backhoe tooth, Steel, Tensile strength, Hardness, Metallography, variance, Carbon Iron diagram, Single factor variation, Chemical elements of a steel.

INTRODUCCIÓN.

El desarrollo de nuevos materiales hoy día centra una particular atención, debido a los grandes consumos de acero a nivel industrial. La industria en general usa muchos aceros para diferentes procesos de producción, en este estudio se busca elaborar un nuevo acero reformulado a partir del acero importado con el cual están fabricados los dientes de pala para retroexcavadora. En este proyecto aplicado se realizaron ensayos de análisis de la composición química, de la dureza, de la resistencia a la tracción y la estructura metalográfica de dientes importados para así tener la información técnica como patrón de las características químicas y mecánicas con las cuales está elaborado este tipo de acero procediendo a realizar un experimento con un solo factor en la composición química variando el porcentaje de Carbono, para obtener una dureza una resistencia a la tracción y una estructura metalográfica de las probetas del acero nuevo obtenidas de materia prima nacional y realizar los respectivos análisis de los datos obtenidos producto de la variación en el contenido de Carbono.

Los análisis se realizaron en el laboratorio de ensayos físicos y químicos de Indumil Sogamoso donde se cuenta con un Espectrómetro de emisión óptica de chispa para el análisis de los elementos químicos en porcentaje; un Durómetro universal para las durezas en escala Rockwell C, un microscopio para la estructura metalográfica y una maquina universal de ensayos para la resistencia a la tracción en Kgf/mm^2 .

La idea principal es aprovechar esta información técnica obtenida de este estudio y proponer la implementación de este acero y su posible aplicación en otros tipos de repuestos de equipos que se utilizan en diferentes tipos de industrias.

1. DEFINICIÓN DEL PROBLEMA.

1.1. Planteamiento Del Problema.

Muchas de las piezas de acero utilizadas dentro de los procesos operativos de numerosas industrias, como las manufactureras o mineras son importadas y su desgaste natural con el uso y el tiempo, plantean una reposición de las mismas, lo cual supone costos que pueden ser llegar a ser considerablemente superiores, al incluir los aranceles de importación.

El presente proyecto aplicado pretende obtener la formulación de un nuevo acero que potencialmente permita sustituir el uso de piezas importadas, como los dientes de pala para retroexcavadora, planteando la posibilidad de fabricarlas de forma local.

Como metodología, en primer lugar fue realizada una caracterización experimental de la composición química, dureza y resistencia a la tracción de un acero importado para posteriormente proceder con la formulación del nuevo acero, variando un único factor, el porcentaje de Carbono, el cual es el factor preponderante para la obtención de buenas características de dureza y resistencia a la tracción.

2. JUSTIFICACIÓN.

La justificación del presente proyecto aplicado radica en la necesidad de desarrollar nuevos materiales a partir de materiales conocidos variando un solo factor el porcentaje de Carbono para obtener las nuevas propiedades físicas y mecánicas.

Al efectuar la variación en el porcentaje de Carbono se verificó que este elemento químico afecta las propiedades físicas y mecánicas del acero facilitando reformular un patrón y se sometió a ensayos de resistencia a la tracción y dureza obteniendo datos de esas características con mejor comportamiento en estas propiedades.

Este estudio sirve como soporte valioso para poder adelantar gran cantidad de investigaciones de aceros utilizados en las diferentes industrias y que por lo general son importados y que se les puedan variar el porcentaje de Carbono, sabiendo que los datos obtenidos y registrados en este proyecto son el soporte técnico que se pueden mejorar las propiedades mecánicas del acero importado y llegar a producir este acero para muchas utilizaciones en la industria donde se necesita que sea de buen rendimiento beneficiando a los usuarios.

3. OBJETIVOS.

3.1. Objetivo General.

Caracterizar, mediante ensayos de características físicas y químicas de los dientes de pala importados para retroexcavadora, con el ánimo de formular un estudio donde se evaluará el comportamiento de las propiedades mecánicas de un acero, con aplicaciones industriales diversas, variando únicamente el porcentaje de Carbono.

3.2. Objetivos Específicos.

- Determinar las características químicas y físicas de los dientes importados para poder tener un patrón de referencia de este acero.
- Establecer una nueva variación en la composición química en el porcentaje de Carbono de las probetas a ensayar con este tipo de acero de nueva formulación.
- Obtener los datos resultados de los ensayos objeto de este experimento de la variación de un solo factor el porcentaje de Carbono para verificar su incidencia en las propiedades físico - mecánicas de la resistencia a la tracción y dureza.

4. MARCO REFERENCIAL.

4.1 Elementos químicos contenidos en % de los aceros.

Se da el nombre de aceros aleados a los aceros que además de los cinco elementos: Carbono, Silicio, Manganese, Fósforo y Azufre, contienen también cantidades relativamente importantes de otros elementos como el cromo, níquel, molibdeno, cobre etc., que sirven para mejorar alguna de sus características fundamentales. También puede considerarse aceros aleados los que contienen alguno de los cuatro elementos diferentes del carbono que antes hemos citado, en mayor cantidad que los porcentajes que normalmente suelen contener los aceros al carbono.

La influencia que ejercen esos elementos químicos es muy variada, y, empleados en proporciones convenientes, se obtienen aceros con ciertas características que, en cambio, no se pueden alcanzar con los aceros ordinarios al carbono.

4.2. Influencia en los aceros de los elementos químicos.

4.2.1. Níquel.

Una de las ventajas más grandes que reporta el empleo del níquel, es evitar el crecimiento del grano en los tratamientos térmicos, lo que sirve para producir en ellos gran tenacidad. El níquel además hace descender los puntos críticos y por ello los tratamientos pueden hacerse a temperaturas ligeramente más bajas que la que corresponde a los aceros ordinarios. (Biltra, 2017)

4.2.2. Cromo.

Es uno de los elementos especiales más empleados para la fabricación de aceros aleados, usándose indistintamente en los aceros de construcción, en los de herramientas, en los inoxidables y los de resistencia en caliente. Se emplea en cantidades diversas desde 0.30 a 30, según los casos y sirve para aumentar la dureza y la resistencia a la tracción de los aceros, mejora la templabilidad, impide las deformaciones en el temple, aumenta la resistencia al desgaste, la inoxidabilidad, etc. (Biltra, 2017)

4.2.3 Molibdeno.

Mejora notablemente la resistencia a la tracción, la templabilidad y la resistencia de los aceros. Añadiendo solo pequeñas cantidades de molibdeno a los aceros cromo-níqueles, se disminuye o elimina casi completamente la fragilidad, que se presenta cuando estos aceros son revenidos en la zona de 450° a 550°. (Biltra, 2017)

4.2.4. Manganeso.

Aparece prácticamente en todos los aceros, debido, principalmente, a que se añade como elemento de adición para neutralizar la perniciosa influencia del azufre y del oxígeno, que siempre suelen contener los aceros cuando se encuentran en estado líquido en los hornos durante los procesos de fabricación. El manganeso actúa también como desoxidante y evita, en parte, que en la solidificación del acero que se desprendan gases que den lugar a porosidades perjudiciales en el material. (CAP, 2000)

4.2.5. Silicio.

Este elemento aparece en todos los aceros, lo mismo que el manganeso, porque se añade intencionadamente durante el proceso de fabricación. Se emplea como elemento desoxidante complementario del manganeso con objeto de evitar que aparezcan en el acero los poros y otros defectos internos. Los aceros pueden tener porcentajes de 0.20 a 0.34% de Si. (CAP, 2000)

4.2.6. Azufre.

Normalmente es una impureza y se mantiene a un bajo nivel. Sin embargo, alguna veces se agrega intencionalmente en grandes cantidades (0,06 a 0,30%) fácil mecanizado (habilidad para ser trabajado mediante cortes) de los aceros de aleación y al carbono. (CAP, 2000)

4.2.7. Fósforo.

Incrementa la resistencia y reduce la ductilidad de la ferrita. Aumenta la brillantez. Este elemento, en cantidades superiores al 0.004%, disminuye todas las propiedades mecánicas del

acero. Molibdeno: Formador de carburos, reduce el crecimiento del grano, mejora la resistencia al desgaste y la capacidad de conservar la dureza a temperaturas altas. (CAP, 2000)

4.2.8. Carbono.

Es el elemento que tiene más influencia en el comportamiento del acero; al aumentar el porcentaje de carbono, mejora la resistencia mecánica, la Templanbilidad y disminuye la ductilidad. (Biltra, 2017). El acero al carbono, constituye el principal producto de los aceros que se producen, estimando que un 90% de la producción total producida mundialmente corresponde a aceros al carbono y el 10% restante son aceros aleados. La composición química de los aceros al carbono es compleja, además del hierro y el carbono que no supera el 2%, hay en la aleación otros elementos necesarios para su producción, tales como silicio y manganeso, y hay otros que se consideran impurezas por la dificultad de excluirlos totalmente como el azufre, fósforo, oxígeno, hidrógeno. El aumento del contenido de carbono en el acero eleva su resistencia a la tracción y su dureza, incrementa el índice de fragilidad en frío y hace que disminuya la tenacidad y la ductilidad. (2013)

4.3. Diagrama Hierro – Carbono (Fe-C)

Para el estudio de las estructuras de los aceros industriales se necesita, en primer lugar, conocer y manejar con soltura el diagrama hierro-carbono, que se muestra en la (Figura 1). Esta figura representa en realidad dos diagramas, el meta estable hierro-carbono y el diagrama estable hierro-grafito. La cementita no es una fase estable, aunque dada la lentitud de su transformación, el diagrama meta estable es el que tiene un mayor interés práctico para el estudio de los aceros. El diagrama estable hierro-grafito solo tiene interés en el estudio de las fundiciones al silicio. (Universidad Tecnológica de Pereira, 2012)

En el diagrama de fase de Hierro – Carbono se observan las formas alotrópicas del hierro sólido, BCC y FCC, a distintas temperaturas. (Figura 1)

4.3.1. Hierro alfa (α)

Su estructura cristalina es BCC con una distancia interatómica de 2.86 Å. Su temperatura va desde 0°C - 910°C, es relativamente blanda, prácticamente no disuelve en carbono.

4.3.2. Hierro gamma (γ)

También conocida como Austenita. Se presenta de 723 °C a 1492 °C. Cristaliza en la estructura cristalizada FCC con mayor volumen que la estructura hierro alfa, disuelve fácilmente en carbono (más deformable que la ferrita).

Sus propiedades mecánicas dependen del contenido de carbono, pero podríamos dar como valores medios representativos: Una dureza de 300 HB (Dureza Brinell), una carga de rotura de 900 MPa (Mega páscales) a 1100 MPa y alargamientos entre 30 y 60%. (UTP, 2012)

4.3.3. Hierro delta (δ)

Está localizada desde 1400 °C y presenta una reducción en la distancia interatómica que la hace retornar a una estructura cristalina BCC. Su máxima solubilidad de carbono es 0.08% a 1492 °C. No posee una importancia industrial relevante. A partir de 1539 °C se inicia la fusión del Hierro puro.

Tomando como base el diagrama meta estable hierro-carbono, se denominan aceros a las aleaciones binarias con contenidos en carbono menor que 1,76%, mientras las fundiciones de hierro tienen contenidos en carbono superiores a 1,76% (hasta aproximadamente 6,67%). Este diagrama muestra con claridad el comportamiento fuertemente gammágico del carbono: la adición de carbono al hierro γ aumenta el dominio térmico de estabilidad de la Austenita. (2017). Así, por ejemplo, la temperatura de transformación del hierro γ en hierro α aumenta hasta 1492°C para un contenido en carbono del 0.18% (punto peritéctico del diagrama), mientras que la de la transformación de la Austenita en ferrita disminuye hasta 723°C para la aleación con 0.89% de carbono. El diagrama meta estable hierro-carbono muestra tres puntos invariantes característicos. (Figura1)

4.3.4. Punto peritéctico.

(1492°C): Fase líquida (0.4%C) + Fe δ (0.08%C) —>Fe γ (0.18% C)

4.3.5. Punto eutéctico.

(1130°C): Fase líquida (4.3%C) → Austenita (1,76%C)+Fe₃C (6.67%C)

4.3.6. Punto eutectoide.

(723°C): Austenita (0.89%C) → Ferrita (0.025%C) + Fe₃C (6.67%C)

Las líneas que delimitan las diferentes regiones del diagrama hierro-carbono identifican las situaciones en las que tienen lugar cambios estructurales: Las temperaturas de transformación se denominan temperaturas críticas, existen tres temperaturas de especial interés: A₁, A₃ Y A_{cm}. Las temperaturas A₁ y A₃ son las que respectivamente representan el inicio y el final de la transformación de la Austenita desde el dominio donde están presentes las fases ferrita y cementita, mientras que se llama temperatura A_{cm} a aquella que separa el dominio de estabilidad de la Austenita de la zona bifásica austenita+cementita. Dado que estas transformaciones no ocurren exactamente a la misma temperatura al calentar y al enfriar, se denotan a veces como A_r o A_c para describir la transformación en el enfriamiento y calentamiento respectivamente. (UTP, 2012)

El carbono se puede encontrar en las aleaciones hierro-carbono, tanto en estado ligado (Fe₃C), como en estado libre (C, es decir, grafito), por eso, el diagrama comprende dos sistemas:

4.3.7. Fe-Fe₃C (metalestable)

Este sistema está representado en el diagrama con líneas llenas gruesas y comprende aceros y fundiciones blancas, o sea, las aleaciones con el carbono ligado, sin carbono libre (grafito).

4.3.8 Fe-C (estable)

En el diagrama se representa con líneas punteadas; este sistema expone el esquema de formación de las estructuras en las fundiciones grises y atruchadas donde el carbono se encuentra total o parcialmente en estado libre (grafito).

Para estudiar las transformaciones que tienen lugar en aceros y fundiciones blancas se emplea el diagrama Fe-Fe₃C, y para estudiar fundiciones grises, ambos diagramas (Fe-Fe₃C y Fe-C). (UTP, 2012). El carbono puede presentarse en tres formas distintas en las aleaciones Fe-C: En solución intersticial; Como carburo de hierro; Como carbono libre o grafito.

4.4 Fases Del Diagrama Hierro Carbono.

4.4.1. Fase Austenítica (0% hasta 1,76% C).

La Austenita es el micro constituyente más denso de los aceros y está formado por una solución sólida por inserción de carbono en hierro gamma, como lo muestra la (Figura 1). La cantidad de carbono disuelto, varía de 0% a 1,76%, que es la máxima solubilidad de carbono en esta fase a temperaturas de 1130 °C. La Austenita no es estable a la temperatura ambiente pero existen algunos aceros al cromo-níquel denominados austeníticos cuya estructura es Austenita a temperatura ambiente. (Figura1) (UTP, 2012). La Austenita tiene las siguientes características:

- Baja temperatura de fusión,
- buena tenacidad y excelente soldabilidad.

4.4.2. Zona de trabajo de este proyecto según el diagrama Hierro Carbono.

De acuerdo al ensayo del porcentaje de carbono de la muestra original que es de 0,4 según flecha de color azul  en la (Figura 1).

La región de trabajo de la mezcla de este proyecto de la variación de un solo factor el porcentaje de carbono, se señala con flechas y sombra naranja  en el diagrama hierro carbono (Figura 1). La zona donde trabajamos este proyecto en el intervalo de 0,3% de C hasta 0,5% de C.; es un acero hipoeutectoide estos aceros según el Diagrama hierro - carbono tienen un contenido de Carbono inferior al (0,77 % de C). (Revista de Ingeniería UC, 2012)




Figura 1. Diagrama de fases Hierro – Carbono que muestra la relación entre equilibrios estables de Hierro – Grafito (líneas discontinuas) y las reacciones meta estables de Hierro – Cementita (líneas continuas). (UTP, 2012)

4.5. Ficha Técnica del diente para retroexcavadora.

4.5.1. Características.

Los dientes de pala y adaptadores diferentes que se usan en retroexcavadoras, excavadoras, cargadores y motoniveladoras, tienen tantas aplicaciones diferentes que hay que tener en cuenta las diferentes condiciones del terreno que hay que considerar. Se necesita una gran variedad para mantener las líneas productivas a tantas máquinas. John Deere o CAT tienen la selección necesaria por ser líderes a nivel mundial en este tipo de repuestos y maquinaria. (Deere, 2017). Se caracterizan por:

Ser adaptables a retro-cargadoras mixtas (CAT 910, 931, 933 y 941) y JCB 3CX. Los dientes de pala y los porta - dientes son fabricados en acero de composición especial (acero anti-desgaste al Cromo-Molibdeno). como uno de los materiales más usados en la fabricación de este tipo de repuestos dientes de pala, Poseen una dureza de 30 - 40 HRC.

El diente se monta en la porta-diente soldada en la cuchara retro-cargadora y se fija mediante chaveta metálica y goma.



Figura 2. Diente para retroexcavadora. (Deere, 2017)

4.5.2. Ventajas.

Material resistente al desgaste, Fácil montaje.

4.5.3. Beneficios.

La calidad del material anti desgasté debe ser un estatus de calidad, mediante este proyecto se pretende alargar la vida útil y disminuir la frecuencia de su cambio producto de variación de un solo factor del porcentaje de Carbono para mejorar propiedades físico mecánicas. (Wurth, 2017)

4.6. Espectrometría de emisión atómica.

Es un método estándar para el análisis de muestras metálicas, de gran uso en fabricación y control de la producción siderúrgica. Se basa en la obtención de chispas entre dos electrodos, lo que produce un plasma de vapor en el cátodo, de una temperatura mayor de 10000 °K. Esta técnica es rápida y simultánea de muchos elementos químicos en aleaciones, incluye elementos ligeros como C, Si, Mn, S, Cr, Ni, Mo y P, es complementaria con la espectrometría de rayos X. (Universidad Politécnica de Cartagena, 2017)

4.6.1. Secuencia de eventos para análisis espectro químico.

- Excitación del Átomo Elemental - Energía
- Transmisión de Energía al átomo
- Liberación de fotones del átomo Elemental
- Recolección de Fotones
- Separación de Longitudes de Onda Elementales
- Medición de la intensidad del elemento

4.6.2. Por que gas argón y no Aire.

- Elemento Químico con Numero Atómico No.18
- Argón es un gas atómico de espectro muy sencillo, es inerte y no forma compuesto químico con la muestra vaporizada.
- Argón tiene un potencial de ionización muy bajo.

- Argón alta pureza (99.9999%).
- Argón transmite longitudes de onda por debajo de 200nm. ($C = 193.1\text{nm}$)
- Emisión muy baja de ruido de fondo.
- Procesamiento de datos convierte Intensidades a concentración en %.

4.6.3. Calibración de un instrumento analítico.

Solamente mediante una calibración un instrumento se convierte en un instrumento analítico, de tal forma que los elementos químicos puedan ser medidos en concentraciones.

4.7. Resistencia a la Tracción.

La resistencia a la tracción (UTS), a menudo abreviado como resistencia a la tracción (TS) o resistencia a la rotura, es la tensión máxima que un material puede soportar, mientras se estira antes de fracturarse, que es cuando la muestra de la sección transversal empieza significativamente a estirarse. Resistencia a la tracción es lo contrario de resistencia a la compresión con valores muy diferentes.

La resistencia a la tracción rara vez se utilizan en el diseño de los elementos dúctiles, pero que son importantes para los miembros frágiles. Se tabulan para los materiales comunes, como las aleaciones, materiales compuestos, cerámica, plásticos y madera. Resistencia a la tracción se define como una tensión, que se mide como la fuerza por unidad de área. Para algunos materiales no homogéneos (o de los componentes montados) se puede dar cuenta sólo como una fuerza o como una fuerza por unidad de longitud. En el sistema SI, la unidad es pascal (Pa) o, equivalentemente, newton por metro cuadrado (N/m^2). La unidad habitual es libras de presión por pulgada cuadrada (lbf/in^2 o psi) o kilo-libras por pulgada cuadrada (ksi), que es igual a 1000 psi, kilo-libras por pulgada cuadrada son comúnmente utilizados para la medición de la tensión. (2017)

4.8. Dureza.

La dureza de un material puede definirse como "la resistencia que el material exhibe contra la deformación permanente ocasionada por la penetración de otro material de mayor dureza". La dureza no es una propiedad fundamental de un material y su valor cuantitativo debería evaluarse siempre en relación a:

- una carga dada en un penetrador.
- un perfil de tiempo de carga específico y una duración de carga específica.
- una geometría de penetrador específica.

El propósito principal de un ensayo de dureza es determinar la idoneidad de un material, o el tratamiento concreto al cual el material ha sido sometido.

El ensayo de dureza suele llevarse a cabo midiendo la profundidad de penetración del penetrador (Rockwell, ensayo de penetración instrumentado, dureza de penetración de bola) o bien midiendo el tamaño de una impresión dejada por un penetrador (Vickers, Knoop y Brinell). El método de ensayo de dureza por penetración más adecuado dependerá de la microestructura de los materiales; es decir, de la homogeneidad del material. Es importante que el material, bajo la penetración realizada por el ensayo de dureza, sea representativo de la totalidad de la microestructura, salvo que la tarea sea estudiar los diferentes constituyentes presentes en la microestructura. Esto significa que si una microestructura es muy tosca y heterogénea, se necesitará una mayor impresión que para un material homogéneo. (Struers, 2017)

4.9. Equipos utilizados en los ensayos.

Los equipos utilizados en los ensayos para obtener las diferentes características son equipos analíticos de última generación utilizados comúnmente en las diferentes industrias siderúrgicas.

El espectrómetro de emisión atómica se utiliza en este proyecto por ser un equipo analítico con el que se obtienen los datos de la composición química en porcentaje de los elementos químicos que son la base del presente proyecto en especial la obtención del porcentaje de Carbono del acero original y del acero reformulado.

El durómetro que se utiliza en este proyecto para obtener la dureza del acero en escala Rockwell C. del acero original y el acero reformulado, se utilizo en este proyecto por ser un equipo de buena utilización en la industria y comúnmente se encuentra en las fabricas siderúrgicas como un equipo de control.

La maquina universal de ensayos que se usa para obtener la resistencia a la tracción en escala de Kgf/mm². Equipo analítico de gran uso en la industria como ayuda al control de la obtención de las características mecánicas, en este proyecto se utiliza para obtener los datos del acero original y el acero reformulado.

5. METODOLOGÍA.

5.1. Recursos.

5.1.1. Laboratorio de Ensayos INDUMIL Sogamoso, Boyacá.

5.1.2. Materia Prima.

La materia prima utilizada para la obtención de las probetas del acero reformulado utilizado en los ensayos, tiene procedencia de origen nacional; que es la que se utiliza en los procesos de la Fabrica de Indumil Sogamoso.

5.2. Equipos.

5.2.1. Espectrómetro de emisión atómica.

Certificado de Calibración Numero 133274, Modelo Spectro LAV M11, Fabricante Alemania. Marca SPECTRO. (Ver Figura 3) Este equipo utilizado para el ensayo de análisis químico por espectrometría de emisión se compone de un sistema óptico, sistema de excitación de muestra y una CPU; Cada uno de estos componentes tiene partes eléctricas, mecánicas electrónicas hardware y software necesarios para el ensayo. El equipo maneja diferentes materiales en diferentes rangos de composición química (**Tabla 1**) Programa Acero de baja aleación.

Tabla 1. Rangos composición química en % de las curvas del Espectrómetro de emisión atómica.

%	C	Si	Mn	P	S	Cr	Mo	Ni	Al
Mínimo	0,0005	0,0006	0,0002	0,0002	0,0002	0,0003	0,00003	0,0004	0,0005
Máximo	1,5	5,3	2,4	0,12	0,12	8,5	8,5	5,5	1,9
%	As	B	Co	Cu	Nb	Sn	Ti	V	W
Mínimo	0,0002	0,0001	0,0002	0,0005	0,0002	0,0001	0,0001	0,0002	0,0002
Máximo	0,13	0,014	2,0	1,2	0,32	0,16	0,82	1,10	3,1
%	Zr	Ca	Sb	Ta	Pb	Bi	Se	Zn	Fe
Mínimo	0,0001	0,00003	0,0004	0,0005	0,0002	0,0002	0,0008	0,00005	Ref.
Máximo	0,22	0,02	0,11	0,20	0,025	0,01	0,12	0,025	

Fuente: Laboratorio de ensayos Indumil, Sogamoso.



Figura 3. Espectrómetro de emisión atómica.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

Tabla 2. Partes del Espectrómetro - Spectrolab.

A	Electrodo de tungsteno.
B	Orificio donde se coloca la muestra para el ensayo de análisis químico %.
C	Entrada del Argón alta pureza a la cámara de chispeo del equipo.
D	Óptica donde el equipo convierte intensidades en concentraciones en %.
E	Entrada de Argón alta pureza al equipo espectrómetro de emisión.
F	Monitor y CPU del software Spark Analyzer.
G	Impresora de los registros de los ensayos.
H	Entrada del Fluido Eléctrico 220 VAC. Al equipo espectrómetro de emisión.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

5.2.2 Maquina Universal de Ensayos.

Certificado de calibración No. ICCLAB-6087, 2016-12-13. ISO/IEC 17025:2005 09-LAC-027. Modelo AG-1, Fabricante Japón, Marca Shimadzu. (Ver Figura 4)

El equipo usado Maquina Universal de Ensayos tiene las siguientes características técnicas:

- Capacidad de la celda 100 KN Máximo.(10 toneladas)
- Pantalla táctil LCD grande para operación independiente.
- Control de alta precisión con sistema de brazo cerrado.
- Software Trapezium para procesamiento de datos de tensión y compresión.

Aplicaciones: Metales, concreto, y madera. (2017)




Figura 4. Maquina Universal de ensayos.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

Tabla 3. Partes de la Maquina Universal de Ensayos.

A	Celda de 100 KN Máximo. (10 toneladas).
B	Brazo aprieta mordaza.
C	Mordaza para sujetar la muestra a ensayar.
D	Base de la maquina con el motor
E	Entrada del Fluido Eléctrico 220 VAC. A la Maquina Universal de Ensayos.
F	Brazo de desplazamiento de alta precisión.
G	Pantalla táctil LCD grande para operación independiente.
H	Cable transmisor de datos.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

5.2.3 Durómetro Universal.

Informe de calibración 17252 / 2017. Modelo ZHU. Fabricante Reino unido. Marca ZWICK / ROELL. (Ver **Figura 5**) Estos tipos de durómetros poseen ciclo automático de cargas programables con tiempos de espera de 1 a 50 segundos, con conversión a otras escalas y corrección para superficies no planas. Posee un Microscopio incorporado para lecturas de dureza; tiene un espacio vertical de 250 mm. Y una distancia de 150 mm. Mínimo del centro del indentador hasta el bastidor.




Figura 5. Durómetro Universal.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

Trabajo de Grado Proyecto Aplicado

Tabla 4. Partes del Durómetro Universal.

A	Display donde registra la dureza obtenida en el durómetro.
B	Microscopio incorporado para las lecturas de la dureza.
C	Indentador accesorio para poder efectuar la dureza.
D	Base soporte para colocar la muestra en el ensayo de dureza.
E	Entrada del Fluido Eléctrico 110 VAC. Al durómetro universal.
F	Bastidor, tornillo de desplazamiento y fijación del soporte para las muestras.
G	Intercambiadores de la carga para la operación del equipo.
H	Pesas patrón del equipo para las diferentes cargas según tipo de dureza.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

5.2.4 Microscopio Metalográfico.

Informe de calibración Septiembre 2017. Modelo GX 71. Fabricante Japón.

Marca Olympus. Equipo con una amplitud de imagen de 50X, hasta 100 x lectura directa.

5.3 Normas.

El laboratorio de ensayos de INDUMIL Fabrica Santa Bárbara Sogamoso cuenta con varios equipos para los ensayos físico químicos en especial el Espectrómetro de emisión atómica que fue el equipo con que se acredito el ensayo de análisis químico vía espectrometría según Certificado de acreditación 12 – LAB – 044 con código de la técnica de los ensayos L16 - C60 con fecha de aprobación del 2016 – 05 – 19 según ONAC (Organismo Nacional de Acreditación) Normas a usar:

5.3.1 Norma para el Ensayo y análisis de la composición química.

Norma ASTM E 415 – 15, Standard Test Method for Analysis of Carbon and Low- Alloy Steel by Spark Atomic Emission Spectrometry. (Ver anexo 1)

5.3.2. Norma para el Ensayo y análisis de la dureza.

Norma ASTM E 18 – 05, Standard Test Methods for Rockwell Hardness and Rockwell Superficial Hardness of Metallic Materials. (Ver anexo 2)

5.3.3. Norma para el Ensayo y análisis de la Resistencia a la Tracción.

Norma Técnica Colombiana NTC 2, Ensayo de tracción para materiales metálicos. Método de ensayo a temperatura ambiente. (Ver anexo 3)

5.4. Diseño Experimental.

5.4.1. Tratamiento de la Muestra Original.

Para el tratamiento de la muestra original se procedió a efectuar ensayos de análisis de características químicas y físicas como son el análisis químico, de dureza, de metalografía y de resistencia a la tracción para obtener datos técnicos y así poder plantear con que características vamos a formular en la experimentación la variación de un solo factor; el porcentaje de Carbono (C) en las probetas obtenidas con composición química del acero para los dientes de pala.

5.4.2 Caracterización Físico Química:

- Composición Química en % obtenida de la muestra original. (**Tabla 5.**)

Tabla 5. Composición Química en % obtenida de la muestra original.

C	Si	Mn	P	S	Cr	Ni	Mo
0,40 %	1,92 %	1,55 %	0,028 %	0,014 %	1,50 %	0,18 %	0,24 %

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

SPECTRO

06-Apr-17 11:53:13 AM

Method: Fe-10
 Comment: low alloy steel
 Type Standard: AISI 4340 B.S. 60C

Sample Name:
Diente Original

06-Apr-17 11:53:13 AM

	C	Si	Mn	P	S	Cr	Mo	Ni
	%	%	%	%	%	%	%	%
1	0.402	1.92	1.55	0.0280	0.0133	1.50	0.239	0.185
2	0.382	1.90	1.57	0.0284	0.0130	1.52	0.239	0.185
3	0.407	1.92	1.55	0.0287	0.0148	1.50	0.237	0.182
< x > (3)	0.397	1.92	1.55	0.0283	0.0137	1.50	0.238	0.184
sd	0.0130	0.0108	0.0117	0.00035	0.0010	0.0125	0.0013	0.0016
rsd	3.3	0.6	0.8	1.2	7.3	0.8	0.5	0.9
	Al	Co	Cu	Nb	Ti	V	W	Pb
	%	%	%	%	%	%	%	%
1	0.161	0.0085	0.0382	0.0031	0.0029	0.0467	<0.00020	<0.00020
2	0.162	0.0080	0.0373	0.0029	0.0030	0.0471	<0.00020	<0.00020
3	0.166	0.0081	0.0359	0.0030	0.0033	0.0468	<0.00020	<0.00020
< x > (3)	0.163	0.0082	0.0371	0.0030	0.0031	0.0469	<0.00020	<0.00020
sd	0.0027	0.00027	0.00064	0.00010	0.00020	0.00022	0.00000	0.00000
rsd	1.7	3.2	12.8	3.4	6.5	0.5	0.0	0.0

Figura 6. Registro Análisis de composición química del diente original.

Fuente: Laboratorio de Ensayos Indumil, Sogamoso.

- Dureza obtenida en escala HRC (Hardness Rockwell C) muestra original: 30, 2 HRC: 31 HRC ; 32 HRC ; **Promedio 31, 06 HRC** (Hardness Rockwell C), (Ver Figura 7)



Figura 7. Dureza primera toma diente original 30,2 en escala Rockwell C.

- Resistencia a la Tracción obtenida de la muestra original. **46,25 Kgf/mm²** de Resistencia a la tracción. (Ver Figura 8)




Figura 8. Resistencia a la Tracción diente original en la escala de Kgf/mm²

Fuente: Laboratorio de Ensayos Indumil, Sogamoso.

- Metalografía obtenida de la muestra original Matriz Perlita Y Bainita.

5.4.3. Planeación del Experimento.

En este proyecto se planeó el ensayo a muestras experimentalmente en cinco niveles, o en los diferentes porcentajes de Carbono así: de 0,3%, de 0,35%, de 0,4%, de 0,45% y de 0,5% de acuerdo a la **Tabla 8.**, y en cada nivel 5 repeticiones o replicas para un total de 25 repeticiones.

5.4.4. Modelo Matemático.

El análisis de varianza es un ensayo o serie de ensayos en los cuales se introducen cambios de alguna característica en las variables de entrada que forman el proceso, para que así se pueda observar e identificar las causas de los cambios en la variable de salida obtenida.

El análisis de la varianza es un modelo matemático estadístico que permite obtener si diferentes tratamientos muestran diferencias significativas o por el contrario puede presumirse que sus medias poblacionales no se alteran. Por eso para este proyecto se aplico el análisis de varianza de un solo factor para poder verificar si el cambio en el porcentaje de Carbono se afecta de acuerdo al estudio del modelo matemático estadístico.

5.4.5. El objetivo del experimento de análisis de varianza con un solo factor.

El principal objetivo de este proyecto apunta su interés en investigar la Resistencia a la Tracción y Dureza de un acero especial con nueva formulación en su porcentaje de Carbono producto del experimento con un solo factor el análisis de varianza.

5.4.6. Experimentos con un Solo Factor: El análisis de Varianza.

El método tradicional de experimentación, el que quizás surge de forma más intuitiva para estudiar el sistema en este proyecto, consistió en variar-un-factor-cada-vez (VUFCV): partiendo de unas condiciones iniciales, se realizaron experimentos en los cuales todos los factores se mantienen constantes excepto el que se sometió al estudio. De este modo, la variación de la respuesta se pudo atribuir a la variación del factor, y, por tanto, reveló el efecto de ese factor.

El diseño se hizo probando ejemplares en cinco niveles con diferentes porcentajes de carbono de acuerdo al patrón de referencia diente importado y 5 réplicas por nivel para un total de 25 corridas o ensayos a los ejemplares o probetas y según resultados ensayar sus propiedades mecánicas de resistencia a tracción y dureza siguiendo la metodología según experimentación con un solo factor: El análisis de varianza. (Montgomery, 2001) y su método con los términos se resume en la **tabla 7**.

Tabla 6. Convenciones términos del análisis de Varianza para el método con un solo factor.

Termino de la expresión matemática	Significado de la expresión
$SS_{Tratamientos}$	<i>suma de cuadrados entre los tratamientos.</i>
$a - 1$	<i>grados de libertad , $a = \text{niveles} = 5$.</i>
$MS_{Tratamientos}$	<i>cuadrado medio entre los tratamientos.</i>
F_o	<i>estadistico de prueba para la hipotesis.</i>
SS_E	<i>suma de cuadrados debida al error por sustraccion.</i>
$N - a$	<i>grados de libertad para el error.</i>
MS_E	<i>cuadrado medio del error dentro de los tratamientos</i>
SS_T	<i>suma de cuadrados totales</i>
$N - 1$	<i>numero total de grados de libertad.</i>

Tabla 7. Tabla del análisis de Varianza para el método con un solo factor.

Fuente de variación	Suma de cuadrados	Grados de Libertad	Cuadrado medio	Fo
Entre los tratamientos	$SS_{Tratamientos} = n \sum_{i=1}^a (\bar{y}_{i\cdot} - \bar{y}_{..})^2$	a - 1	$MS_{Tratamientos}$	$Fo = \frac{MS_{Tratamientos}}{MS_E}$
Error dentro de los tratamientos	$SS_E = SS_T - SS_{Tratamientos}$	N - a	MS_E	-
Total	$SS_T = \sum_{i=1}^a \sum_{j=1}^n (y_{ij} - \bar{y}_{..})^2$	N - 1	-	-

Fuente: (Montgomery, 2001)

5.4.7 Teorema de Cochran aplicado a esta Investigación como Proyecto.

Los grados de libertad de $SS_{Tratamientos}$ y SS_E suman N - 1, el número total de grados de libertad, el teorema de Cochran implica que $SS_{Tratamientos}/\delta^2$ y SS_E / δ^2 son variables aleatorias ji-cuadrada con una distribución independiente. Por lo tanto, si la hipótesis nula dice de que si no hay diferencias en las medias de los tratamientos es verdadera, el cociente se distribuye como F con $a - 1$ y $N - a$ grados de libertad. (2017)

$$Fo = \frac{SS_{Tratamientos} / (a - 1)}{SS_E / (N - a)} = \frac{MS_{Tratamientos}}{MS_E}$$

Esta expresión ***Fo*** es el estadístico de la prueba para la hipótesis de que no hay diferencias en las medias de los tratamientos. (2017) Por los cuadrados medios esperados se observa que, en general, MS_E es un estimador insesgado de δ^2 (sigma 2).

Asimismo bajo la hipótesis nula, $MS_{Tratamientos}$ es un estimador insesgado de δ^2 (sigma 2). Sin embargo, si la hipótesis nula es falsa, el valor esperado de $MS_{Tratamientos}$ es mayor que δ^2 .

Por lo tanto, bajo la hipótesis alternativa, el valor esperado del numerador del estadístico de prueba *Fo*, es mayor que el valor esperado del denominador.

En consecuencia, *H₀* deberá rechazarse para valores del estadístico de prueba que son muy grandes. (Esto implica una región crítica de una sola cola superior)

Por lo tanto, *H₀* deberá rechazarse y concluirse que hay diferencias en las medias de los tratamientos si:

$$Fo > F_{a,a-1,N-a}$$

Donde *Fo* se calcula como:

$$Fo = \frac{SS_{Tratamientos} / (a - 1)}{SS_E / (N - a)} = \frac{MS_{Tratamientos}}{MS_E}$$

Se puede usar el enfoque de los valores P para tomar la decisión. (2017)

Para calcular los SS se pueden utilizar también las siguientes fórmulas equivalentes:

$$SS_T = \sum_{i=1}^5 \sum_{j=1}^5 y_{ij}^2 - \frac{\bar{y}_{..}^2}{N}$$

$$SS_{Tratamientos} = \frac{1}{n} \sum_{i=1}^a y_i^2 - \frac{\bar{y}^2}{N}$$

Y calcular SS_E como la suma de cuadrados del error por sustracción:

$$SS_E = SS_T - SS_{Tratamientos}$$

El desarrollo del experimento se efectuó aleatorizado se numeraron las corridas de la siguiente manera según la **Tabla 8**.

Tabla 8. Numeración de la corrida experimental

% de Carbono	Número de corrida experimental				
0,30	1	2	3	4	5
0,35	6	7	8	9	10
0,40	11	12	13	14	15
0,45	16	17	18	19	20
0,50	21	22	23	24	25

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

Después se procedió a seleccionar de manera aleatoria muy necesaria para evitar variables que perturbaran los resultados, se hizo entre 1 y 25 corridas, 5 corridas por nivel o Porcentaje de Carbono. La secuencia del experimento de un solo factor fue según la **Tabla 9**.

Tabla 9. Secuencia aleatoria del experimento.

Secuencia de prueba	Número de corrida	% de Carbono
1	7	0,35
2	18	0,45
3	23	0,50
4	10	0,35
5	5	0,30
6	17	0,45
7	14	0,40

8	6	0,35
9	15	0,40
10	20	0,45
11	9	0,35
12	4	0,30
13	12	0,40
14	8	0,35
15	1	0,30
16	24	0,50
17	21	0,50
18	11	0,40
19	2	0,30
20	13	0,40
21	22	0,50
22	25	0,50
23	16	0,45
24	3	0,30
25	19	0,45

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

Tabla 10. Porcentajes de Carbono por niveles.

Nivel 1	Nivel 2	Nivel 3	Nivel 4	Nivel 5
0,30 %	0,35 %	0,4 %	0,45 %	0,5 %
0,30 %	0,35 %	0,4 %	0,45 %	0,5 %
0,30 %	0,35 %	0,4 %	0,45 %	0,5 %
0,30 %	0,35 %	0,4 %	0,45 %	0,5 %
0,30 %	0,35 %	0,4 %	0,45 %	0,5 %

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

6. RESULTADOS.

6.1. Resultados obtenidos del experimento en la Resistencia a la Tracción.

Según la **Tabla 9**. Se siguió el orden aleatorio, y se ejecuto el ensayo de Resistencia a la Tracción obteniendo los siguientes resultados registrados en la **Tabla 11**. Y evidencias de los ensayos realizados en las siguientes figuras: **Figuras 9., Figura 10., Figura 11., Figura 12., Figura 13.**

Tabla 11. Resistencia a la Tracción observada con 5 niveles de % de Carbono y 5 replicas.

% de Carbono del acero	Resistencia a la tracción observada			Kgf/mm ²	
0,30 %	25,9	25,03	26,11	27,01	25,7
0,35 %	33,85	34,23	34,16	34,26	33,91
0,40 %	45,58	46,11	45,59	46,34	45,23
0,45 %	66,23	65,15	65,27	65,45	66,14
0,50 %	74,25	74,26	74,27	74,49	74,22

Fuente: Lab. Indumil.




Figura 9. Número de corrida 2, Probeta de 0,3 % Carbono, Resistencia a la Tracción obtenida de 25,03 Kgf/mm²

Fuente: Laboratorio de ensayos Indumil, Sogamoso.




Figura 10. Número de corrida 8, Probeta de 0,35 % Carbono, Resistencia a la Tracción obtenida de 34,16 Kgf/mm²

Fuente: Laboratorio de ensayos Indumil, Sogamoso.




Figura 11. Número de corrida 11, Probeta de 0,40 % Carbono, Resistencia a la Tracción obtenida de 45,58 Kgf/mm²

Fuente: Laboratorio de ensayos Indumil, Sogamoso.




Figura 12. Número de corrida 17, Probeta de 0,45 % Carbono. Resistencia a la Tracción obtenida de 65,15 Kgf/mm²

Fuente: Laboratorio de ensayos Indumil, Sogamoso.




Figura 13. Número de corrida 25, Probeta de 0,50 % Carbono. Resistencia a la Tracción obtenida de 74,22 Kgf/mm².

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

Se muestran las observaciones o replicas de los ensayos que se realizaron para la resistencia a la tracción en Kgf/mm², según **Tabla 12**.

Tabla 12. Datos Resistencia a la Tracción observada con cinco niveles de % de Carbono y cinco replicas, con Totales y Promedios.

% de Carbono del acero	Resistencia a la tracción observada Kgf/mm ²					Totales Yi	Promedios \bar{Y}_i
	1	2	3	4	5		
0,30 %	25,9	25,03	26,11	27,01	25,7	129,75	25,95
0,35 %	33,85	34,23	34,16	34,26	33,91	170,41	34,082
0,40 %	45,58	46,11	45,59	46,34	45,23	228,85	45,77
0,45 %	66,23	65,15	65,27	65,45	66,14	328,24	65,648
0,50 %	74,25	74,26	74,27	74,49	74,22	371,49	74,298

Yi 1228,74 Prom Yi 49,1496

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

Se uso el análisis de Varianza para probar la

Hipótesis nula existe cuando las medias de los tratamientos son iguales.

$$H_0 : \mu_1 = \mu_2 = \mu_3 = \mu_4 = \mu_5$$

Hipótesis alternativa existe cuando las medias de los tratamientos son diferentes.

H1: algunas medias son diferentes.

Las sumas de cuadrados requeridas se calcularon como sigue:

$$SS_T = \sum_{i=1}^5 \sum_{j=1}^5 y_{ij}^2 - \frac{\bar{y}_{..}^2}{N}$$

$$\begin{aligned}
 SS_T = & (25,9)^2 + (25,03)^2 + (26,11)^2 + (27,01)^2 + (25,7)^2 + (33,85)^2 + (34,23)^2 + \\
 & (34,16)^2 + (34,26)^2 + (33,91)^2 + (45,58)^2 + (46,11)^2 + (45,59)^2 + (46,34)^2 + (45,23)^2 + \\
 & (66,23)^2 + (65,15)^2 + (65,27)^2 + (65,45)^2 + (66,14)^2 + (74,25)^2 + (74,26)^2 + (74,27)^2 +
 \end{aligned}$$

$$(74,49)^2 + (74,22)^2 - ((1228,74)^2 / 25)$$

$$SS_T = 8410,64.$$

$$SS_{Tratamientos} = \frac{1}{n} \sum_{i=1}^a y_i^2 - \frac{\bar{y}^2}{N}$$

$$SS_{Tratamientos} = 1 / 5 ((129,75)^2 + (170,41)^2 + (228,85)^2 + (328,24)^2 + (371,49)^2 - (1228,74)^2 / 25)$$

$$SS_{Tratamientos} = 8406,57$$

$$SS_E = SS_T - SS_{Tratamientos}$$

$$SS_E = 8410,64 - 8406,57 = 4,07$$

$$MS_{Tratamientos} = 8406,57 / 4 = 2101,64$$

$$MS_E = 4,07 / 20 = 0,20$$

Tabla 13. Resultados análisis de Varianza de los datos de la Resistencia a la Tracción.

Fuente de variación	Suma de cuadrados	Grados de Libertad	Cuadrado medio	Fo	Valor P
% de Carbono	(SS _{Tratamientos}) = 8406,57	(a - 1) = 4	MS _{Tratamientos} = 2101,64	10508,22	<0,01
Error	(SS _E) = 4,07	(N - a) = 20	MS _E = 0,20	-	-
Total	(SS _T) = 8410,64	(N - 1) = 24	-	-	-

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

Según la **Tabla 13.**, el cuadrado medio de los tratamientos $MS_{Tratamientos} = (2101,64)$ es resultado de la división de $(SS_{Tratamientos}) = 8406,57 / (a - 1) = 4$; y es muchas veces mayor que el cuadrado medio dentro de los tratamientos (o cuadrado medio del error $MS_E = 0,20$), Por lo tanto no es posible que las medias de los tratamientos sean iguales. Concluyéndose que es un ensayo de variabilidad dentro del mismo nivel de porcentaje de Carbono, rechazándose la hipótesis nula H_0 y aceptando la hipótesis alternativa $H1$ (algunas medias son diferentes)

6.2 Resultados analisis de la Varianza con un solo factor de una manera mas formal de la Resistencia a la Traccion.

Calculando el coeficiente F: $F_o = 2101,64 / 0,20 = 10508,22$.

Obtención del F de referencia con un $\alpha = 0,05$ de la tabla de distribucion.F: $F_{0,05 , 4,20} = 2,87$ (**Tabla 14**) con flecha de color  Por lo tanto $10508,22 > 2,87$, se rechaza H_0 y se concluye que las medias de los tratamientos son diferentes;observandose variabilidad dentro del mismo nivel del contenido de Carbono, según el experimento en la variacion del porcentaje de Carbono en el acero aleado objeto de este experimento incide de manera significativa en la Resistencia a la Traccion media obtenida. (Montgomery, 2001)

Tabla 14. Tabla de distribución de los puntos F de los puntos porcentuales.

 F: $F_{0,05,4,20} = 2,87$. (Montgomery, 2001)

		IV. Puntos porcentuales de la distribución F (continuación)														
		$F_{0,05,v_1,v_2}$														
		Grados de libertad del numerador (v_1)														
v_2	v_1	1	2	3	4	5	6	7	8	9	10	12	15	20	24	30
	1	161.4	199.5	215.7	224.6	230.2	234.0	236.8	238.9	240.5	241.9	243.9	245.9	248.0	249.1	250.1
	2	18.51	19.09	19.16	19.25	19.30	19.33	19.35	19.37	19.38	19.40	19.41	19.43	19.45	19.45	19.46
	3	10.13	9.55	9.28	9.12	9.01	8.94	8.89	8.85	8.81	8.79	8.74	8.70	8.66	8.64	8.62
	4	7.71	6.94	6.59	6.39	6.26	6.16	6.09	6.04	5.99	5.91	5.86	5.80	5.77	5.75	
	5	6.61	5.79	5.41	5.19	5.05	4.95	4.88	4.82	4.77	4.74	4.68	4.62	4.56	4.53	4.50
	6	5.99	5.14	4.76	4.53	4.39	4.28	4.21	4.15	4.10	4.06	4.00	3.94	3.87	3.84	3.81
	7	5.59	4.74	4.35	4.12	3.97	3.87	3.79	3.73	3.68	3.64	3.57	3.51	3.44	3.41	3.38
	8	5.32	4.46	4.07	3.84	3.69	3.58	3.50	3.44	3.39	3.35	3.28	3.22	3.15	3.12	3.08
	9	5.12	4.26	3.86	3.63	3.48	3.37	3.29	3.23	3.18	3.14	3.07	3.01	2.94	2.90	2.86
	10	4.96	4.10	3.71	3.48	3.33	3.22	3.14	3.07	3.02	2.98	2.91	2.85	2.77	2.74	2.70
	11	4.84	3.98	3.59	3.36	3.20	3.09	3.01	2.95	2.90	2.85	2.79	2.72	2.65	2.61	2.57
	12	4.75	3.89	3.49	3.26	3.11	3.00	2.91	2.85	2.80	2.75	2.69	2.62	2.54	2.51	2.47
	13	4.67	3.81	3.41	3.18	3.03	2.92	2.83	2.77	2.71	2.67	2.60	2.53	2.46	2.42	2.38
	14	4.60	3.74	3.34	3.11	2.96	2.85	2.76	2.70	2.65	2.60	2.53	2.46	2.39	2.35	2.31
Grados de libertad del denominador (v_2)	15	4.54	3.68	3.29	3.06	2.90	2.79	2.71	2.64	2.59	2.54	2.48	2.40	2.33	2.29	2.25
	16	4.49	3.63	3.24	3.01	2.85	2.74	2.66	2.59	2.54	2.49	2.42	2.35	2.28	2.24	2.19
	17	4.45	3.59	3.20	2.96	2.81	2.70	2.61	2.55	2.49	2.45	2.38	2.31	2.23	2.19	2.15
	18	4.41	3.55	3.16	2.93	2.77	2.66	2.58	2.51	2.46	2.41	2.34	2.27	2.19	2.15	2.11
	19	4.38	3.52	3.13	2.90	2.74	2.63	2.54	2.48	2.42	2.38	2.31	2.23	2.16	2.11	2.07
	20	4.35	3.49	3.10	2.87	2.71	2.60	2.51	2.45	2.39	2.35	2.28	2.20	2.12	2.08	2.04
	21	4.32	3.47	3.07	2.84	2.68	2.57	2.49	2.42	2.37	2.32	2.25	2.18	2.10	2.05	2.01
	22	4.30	3.44	3.05	2.82	2.66	2.53	2.46	2.40	2.34	2.30	2.23	2.15	2.07	2.03	1.98
	23	4.28	3.42	3.03	2.80	2.64	2.53	2.44	2.37	2.32	2.27	2.20	2.13	2.05	2.01	1.96
	24	4.26	3.40	3.01	2.78	2.63	2.51	2.42	2.36	2.30	2.25	2.18	2.11	2.03	1.98	1.94
	25	4.24	3.39	2.99	2.76	2.60	2.49	2.40	2.34	2.28	2.24	2.16	2.09	2.01	1.96	1.92
	26	4.23	3.37	2.98	2.74	2.59	2.47	2.39	2.32	2.27	2.22	2.15	2.07	1.99	1.95	1.90

6.3 Comparativo de los resultados obtenidos en el acero original Vs

resultados del acero reformulado en la Resistencia a la Traccion.

Tabla 15. Cuadro Comparativo de los resultados obtenidos en la acero original Vs

resultados del acero reformulado.

Acero	Porcentaje de Carbono	Resistencia a la Traccion
Original	0,397 %	46,25 Kgf/mm ²
Reformulado	0,50 %	74,298 Kgf/mm ² en promedio.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

Trabajo de Grado Proyecto Aplicado




Figura 14. Grafico Resistencia a la traccion de 46,25 Kgf/mm² . Acero Original.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.




Figura 15. Grafico resultados de Resistencia a la tracción Kgf/mm² acero reformulado.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

En la **tabla 15.** y **figura 14 y Figura 15** se observa el cambio en la Resistencia a la tracción por la incidencia del mayor porcentaje de Carbono 0,50 % , aumentándose esa característica Mecánica en este proyecto aplicado.

6.4. Resultados obtenidos del experimento en la Dureza.

Se siguió el orden aleatorio. Según **Tabla 9.**, y se ejecuto el ensayo de Dureza obteniendo los siguientes resultados registrados en la **Tabla 16.** Y evidencias de los ensayos en las **Figuras 16., Figura 17., Figura 18., Figura 19., Figura 20.**

Tabla 16. Dureza observada HRC, con cinco niveles de Porcentaje de Carbono y cinco replicas.

% de Carbono del acero	Dureza observada HRC (Hardness Rockwell C)				
0,30 %	20,3	20,2	20,5	20,6	20,4
0,35 %	24,1	24,2	24,9	24,3	24,2
0,40 %	30,3	30,4	30,1	30,2	30,3
0,45 %	40,1	39,7	39,0	39,3	39,4
0,50 %	47,1	47,4	47,3	47,2	47,4

Fuente: Laboratorio de ensayos Indumil, Sogamoso.



Figura 16. Número de corrida 2, Probeta de 0,30 % Carbono. Dureza de 20,2 HRC.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.



Figura 17. Numero de corrida 6, Probeta de 0,35 % Carbono. Dureza de 24,1 HRC.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.



Figura 18. Numero de corrida 12, Probeta de 0,4 % Carbono. Dureza de 30,4 HRC.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.




Figura 19. Numero de corrida 18, Probeta de 0,45 % Carbono. Dureza de 39,0 HRC.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.



Figura 20. Numero de corrida 24, Probeta de 0,5 % Carbono. Dureza de 47,2 HRC.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

De acuerdo a los datos obtenidos según **Tabla 12.** Y **Tabla 16.**, se obtuvo que la variación de la Resistencia a la Tracción y la Dureza son producto de la variación en el elemento químico

en el porcentaje de Carbono de 0,5% del acero reformulado incrementándose la Resistencia a la Tracción en (Kgf/mm²) y la Dureza en H.R.C. (Hardness Rockwell C).

Se muestran las observaciones o replicas de los ensayos que se realizaron para la Dureza, según la **Tabla 17**.

Tabla 17. Datos de Dureza observada HRC, con cinco niveles de porcentajes de Carbono y cinco replicas con Totales y Promedios.

% de Carbono del acero	Dureza observada (Hardness Rockwell C) HRC					Totales ΣY_i	Promedios \bar{Y}_i
	1	2	3	4	5		
0,30 %	20,3	20,2	20,5	20,6	20,4	102	20,4
0,35 %	24,1	24,2	24,9	24,3	24,2	121,7	24,24
0,40 %	30,3	30,4	30,1	30,2	30,3	151,3	30,26
0,45 %	40,1	39,7	39,0	39,3	39,4	197,5	39,5
0,50 %	47,1	47,4	47,3	47,2	47,4	236,4	47,28

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

$\Sigma Y_i = 808,9$ Prom $\bar{Y}_i = 32,336$

Se uso el análisis de Varianza para probar la

Hipótesis nula

$$H_0 : \mu_1 = \mu_2 = \mu_3 = \mu_4 = \mu_5$$

Hipótesis alternativa

H1: algunas medias son diferentes.

Las sumas de cuadrados requeridas se calcularon como sigue:

$$SS_T = \sum_{i=1}^5 \sum_{j=1}^5 y_{ij}^2 - \frac{\bar{y}_{..}^2}{N}$$

$$\begin{aligned}
 SS_T = & (20,3)^2 + (20,2)^2 + (20,5)^2 + (20,6)^2 + (20,4)^2 + (24,1)^2 + (24,2)^2 + \\
 & (24,9)^2 + (24,3)^2 + (24,2)^2 + (30,3)^2 + (30,4)^2 + (30,1)^2 + (30,2)^2 + (30,3)^2 + \\
 & (40,1)^2 + (39,7)^2 + (39)^2 + (39,3)^2 + (39,4)^2 + (47,1)^2 + (47,4)^2 + (47,3)^2 + \\
 & (47,2)^2 + (47,4)^2 - ((808,9)^2 / 25)
 \end{aligned}$$

$$SS_T = 2428,12$$

$$SS_{Tratamientos} = \frac{1}{n} \sum_{i=1}^a y_{i..}^2 - \frac{\bar{y}_{..}^2}{N}$$

$$SS_{Tratamientos} = 1 / 5 ((102)^2 + (121,7)^2 + (151,3)^2 + (197,5)^2 + (236,4)^2 - (808,9)^2 / 25$$

$$SS_{Tratamientos} = 2426,23$$

$$SS_E = SS_T - SS_{Tratamientos}$$

$$SS_E = 2428,12 - 2426,23 = 1,89$$

$$SS_E = 1,89$$

$$MS_{Tratamientos} = 2426,23 / 4 = 606,56$$

$$MS_{Tratamientos} = 606,56$$

$$MS_E = 1,89 / 20 = 0,09$$

$$MS_E = 0,09$$

Tabla 18. Análisis de varianza de los datos de la Dureza.

Fuente de variación	Suma de cuadrados	Grados de Libertad	Cuadrado medio	F _o	Valor P
% de Carbono	(SS _{Tratamientos}) = 2426,23	(a - 1) = 4	MS _{Tratamientos} = 606,56	6739,5	<0,01
Error	(SS _E) = 1,89	(N - a) = 20	MS _E = 0,09	-	-
Total	(SS _T) = 2428,12	(N - 1) = 24	-	-	-

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

Según la **Tabla 18.**, el cuadrado medio de los tratamientos $MS_{Tratamientos} = (606,56)$ resultado de la división de $(SS_{Tratamientos})$, $2426,23 / (a - 1)$ 4; es muchas veces mayor que el cuadrado medio dentro de los tratamientos (o cuadrado medio del error $MS_E = 0,09$), Por lo tanto no es posible que las medias de los tratamientos sean iguales.

6.5 Resultados análisis De la Varianza con un solo factor de una manera mas formal de la Dureza.

Calculando el coeficiente F: $F_o = 606,56 / 0,09 = 6739,5$.

Obtención del F de referencia con un $\alpha = 0,05$ de la tabla de distribucion.

F: $F_{0,05,4,20} = 2,87$ (Tabla. 15) con flecha de color  Por lo tanto $6739,5 > 2,87$, se rechaza H_0 y se concluye que las medias de los tratamientos son diferentes; observándose variabilidad dentro del mismo nivel del contenido de Carbono, expresado según el experimento en la variación del porcentaje de Carbono en el acero aleado objeto de este experimento incide de manera significativa en la Dureza media obtenida. (Montgomery, 2001)

6.6 Comparativo de los resultados obtenidos en el acero original Vs resultados del acero reformulado en la Dureza.

Tabla 19. Cuadro Comparativo de los resultados obtenidos de la Dureza en la acero original Vs resultados del acero reformulado.

Acero	Porcentaje de Carbono	Dureza
Original	0,397 %	31,06 H.R.C.
Reformulado	0,50 %	47,28 H.R.C.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.




Figura 21. Grafico de la Dureza de 31,06 H.R.C.obtenida en el acero original

Fuente: Laboratorio de ensayos Indumil, Sogamoso.




Figura 22. Grafico resultados de Dureza en H.R.C. obtenidos del acero reformulado.

Fuente: Laboratorio de ensayos Indumil, Sogamoso.

En la **Tabla 19.** y la **Figura 21.** y **Figura 22.** Se observó al comparar los datos el cambio en la Dureza por la incidencia del mayor porcentaje de Carbono, aumentándose esa característica Mecánica reformulando el acero con contenido de 0,5% de Carbono en este proyecto aplicado

6.7 Análisis de Resultados.

En los resultados que se obtuvieron del análisis de varianza de un solo factor y verificando cual fue la incidencia de variar el porcentaje de Carbono en las probetas de acero reformulado se evidencia la mayor Resistencia a la tracción y Dureza con el porcentaje de Carbono de 0,50 %.

En las **Tabla 15.** y **Figura 14 y F** **Porcentajes de Carbono** la Resistencia a la tracción por la incidencia del mayor porcentaje de Carbono 0,50 % , aumentándose esa característica Mecánica en este proyecto aplicado.

Igualmente en las **Tabla 19.** y la **Figura 21.** y **Figura 22.** Se observó el cambio en la Dureza al agregar mas porcentaje de Carbono, sé aumento esta característica Mecánica del acero reformulado con contenido de 0,50 % de Carbono en este proyecto aplicado

7. CONCLUSIONES.

- Se logró caracterizar y analizar mediante los ensayos las características químicas y físicas del acero de los dientes de pala importados para obtener unos datos patrón y poder experimentar la variación de un solo factor el porcentaje de Carbono y su incidencia en la resistencia a la tracción y la dureza.
- Se Determinó las características físico – químicas del acero de los dientes importados de composición química, dureza, resistencia a la tracción y metalografía para poder tener un patrón de referencia.
- Se Estableció una nueva variación en la composición química en el porcentaje de Carbono de las probetas a ensayar con un rango de 0,3 a 0,5 % de Carbono.
- Se Obtuvieron los datos de los ensayos resultados del experimento de la variación de un solo factor el porcentaje de C (Carbono); verificando así los cambios en las propiedades físico - mecánicas de la Resistencia a la Tracción y Dureza que se obtuvieron con el contenido de 0,5 % de Carbono en las probetas del acero reformulado incrementándose esas propiedades físico - mecánicas según comparativo de las **Tablas 15.** y **Tabla 19.**
- Al obtener los datos del Experimentos con un solo factor: el análisis de varianza, registro mejorándose las propiedades físico mecánicas de la Dureza del acero original de 31,06 H.R.C a 47,28 H.R.C. en promedio del acero reformulado. La Resistencia a la tracción del acero original se incremento de 46,25 Kgf/mm² del acero original, a 74,298 Kgf/mm² en promedio del acero reformulado.
- Se concluye que las medias de los tratamientos son diferentes; observándose variabilidad dentro del mismo nivel del contenido de Carbono, expresado según el experimento en la variacion del porcentaje de Carbono en el acero aleado objeto de este experimento incide de manera significativa en la Dureza media obtenida y la Resistencia a la Traccion.

- Mediante esta investigacion aplicandole el metodo de analisis de varianza concluyo que el porcentaje de Carbono es el elemento quimico que nos contribuye al incremento de las propiedades fisico mecanicas y se que en un futuro se fabriquen aceros especiales en especial para los dientes de pala con ese porcentaje de Carbono de 0,5 %; para que su durabilidad sea mayor en el uso industrial.

8. RECOMENDACIONES.

- Concluido este proyecto se recomienda que al incrementar el porcentaje de Carbono en los aceros aleados , las propiedades mecanicas de resistencia a la traccion y fisicas de dureza aumentan,lo que proporciona unas mejores caracteristicas a un acero aleado de uso industrial.
- Mediante el analisis de varianza de un solo factor se pudo verificar que se puede utilizar en estos tipos de experimentos para poder llegar a una mejor conclusion de su incidencia de la variacion de un solo factor.
- Al obtener mejores propiedades fisico mecanicas en un acero se recomienda hacer mas experimentos en otros tipos de aceros para poder solucionar muchos problemas de los aceros utilizados en diferentes tipos de repuestos de las industrias.
- Luego de la verificacion con evidencias objetivas se recomienda utilizar esta informacion para ser usada en aceros sometidos al desgaste por friccion.

9. LISTA DE REFERENCIAS.

Biltra. (2017). Influencia de los aleantes en los aceros. Recuperado de
<http://www.biltra.es/asesor/influencia-de-los-aleantes-en-los-aceros/>

Aceros al Carbono. (2013). Recuperado de
<http://www.biltra.es/asesor/influencia-de-los-aleantes-en-los-aceros/>

UTP (2012). Diagrama Hierro Carbono. Recuperado de
<http://blog.utp.edu.co/metalografia/5-5-diagrama-hierro-carbono-puntos-criticos-y-ejemplos-de-regla-de-la-palanca-2-2/>

Deere. (2017). Dientes para Cucharon. Recuperado de
https://www.deere.com/es_LA/parts/parts_by_industry/...teeth/bucket_teeth.page

Wurth. (2017). Diente para pala retro cargadora 1,5 Kg. Recuperado de
<http://www.wurth.es/diente-para-pala-retro-cargadora-1-5kg>

UPCT (2017). Espectrometría de emisión por chispa. Recuperado de
<http://www.upct.es/sait/es/tecnicas-espectrometricas-y-afines/espectrometro-de-emision-por-chispa>.

Shimadzu. (2017). Maquina Universal de ensayos. Recuperado de
<http://www.instruservltda.com/test.html>.

Resistencia a la Tracción.(2017). Recuperado de
[http://www.manufacturingterms.com/Spanish/Tensile-strength-\(TS\).html](http://www.manufacturingterms.com/Spanish/Tensile-strength-(TS).html) .

Struers. (2017). Ensayos de Dureza. Recuperado de
<http://www.struers.com/es-ES/Knowledge/Hardness-testing#hardness-testing-about>.

Montgomery, D.C, (2001). Diseño y análisis de experimentos, segunda edición.

Análisis de la varianza con un factor anova. (2017). Recuperado de
http://ww.ub.edu/aplica_infor/spss/cap4-7.htm.

Revista INGENIERÍA UC. (2006). Influencia del tratamiento térmico y del trabajo en frío en el comportamiento mecánico de láminas de acero ASTM A-569. Recuperado de <http://www.redalyc.org/html/707/70713106/>

CAP. (2000). Efectos de los elementos de aleación. Recuperado de <http://www.infoacero.cl/acero/efectos.htm>.

Métodos de Diseño y Análisis de Experimentos (2017) PIR Mares. Recuperado de <http://www.iuma.ulpgc.es..>

Aleaciones Hierro Carbono. (2017). Recuperado de <https://www.uam.es/docencia/labvfm/labvfm/practicas/practica4/fases%20del%20acero.htm> .

Este P, Sáenz P., Laura A. (2004). Evaluación de la resistencia a fatiga y límite de fatiga de aceros de medio y bajo carbono. Revista INGENIERÍA UC. Recuperado de http://www.redalyc.org/articulo.oa?id=70711110>_ISSN 1316-6832

Fundamentos de la ciencia e ingeniería de materiales, 4th Edition Subsidiary of The McGraw-Hill. (2004). Companies, Inc. ... Traducido de la cuarta edición de FOUNDATIONS OF MATERIALS ... Copyright © MMVI by - The McGraw Hill. Recuperado de <http://chirinossilvaroger.files.wordpress.com/.../fundamentos-de-la-ciencia-e-ingenier...>

Frómeta Salas, Zenaida Paulette, Delás Magdaleón, Francisco.(2009) Influencia del Carbono en las propiedades del acero para refuerzo de hormigón. Tecnología Química, XXIX. Recuperado de <http://www.redalyc.org/articulo.oa?id=445543761008>> ISSN 0041-8420

Anexo 1. Norma ASTM E415–15



Standard Test Method for Analysis of Carbon and Low-Alloy Steel by Spark Atomic Emission Spectrometry¹

This standard is issued under the fixed designation E415; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method covers the simultaneous determination of 21 alloying and residual elements in carbon and low-alloy steels by spark atomic emission vacuum spectrometry in the mass fraction ranges shown **Note 1**.

Element	Composition Range, %	
	Applicable Range, Mass Fraction % ^A	Quantitative Range, Mass Fraction % ^B
Aluminum	0 to 0.093	0.006 to 0.093
Antimony	0 to 0.027	0.006 to 0.027
Arsenic	0 to 0.1	0.003 to 0.1
Boron	0 to 0.007	0.0004 to 0.007
Calcium	0 to 0.003	0.002 to 0.003
Carbon	0 to 1.1	0.02 to 1.1
Chromium	0 to 8.2	0.007 to 8.14
Cobalt	0 to 0.20	0.006 to 0.20
Copper	0 to 0.5	0.006 to 0.5
Manganese	0 to 2.0	0.03 to 2.0
Molybdenum	0 to 1.3	0.007 to 1.3
Nickel	0 to 5.0	0.006 to 5.0
Niobium	0 to 0.12	0.003 to 0.12
Nitrogen	0 to 0.015	0.01 to 0.055
Phosphorous	0 to 0.085	0.006 to 0.085
Silicon	0 to 1.54	0.02 to 1.54
Sulfur	0 to 0.055	0.001 to 0.055
Tin	0 to 0.061	0.005 to 0.061
Titanium	0 to 0.2	0.001 to 0.2
Vanadium	0 to 0.3	0.003 to 0.3
Zirconium	0 to 0.05	0.01 to 0.05

^A Applicable range in accordance with Guide E1763 for results reported in accordance with Practice E1950.

^B Quantitative range in accordance with Practice E1601.

NOTE 1—The mass fraction ranges of the elements listed have been established through cooperative testing² of reference materials.

1.2 This test method covers analysis of specimens having a diameter adequate to overlap and seal the bore of the spark stand opening. The specimen thickness can vary significantly

according to the design of the spectrometer stand, but a thickness between 10 mm and 38 mm has been found to be most practical.

1.3 This test method covers the routine control analysis in iron and steelmaking operations and the analysis of processed material. It is designed for chill-cast, rolled, and forged specimens. Better performance is expected when reference materials and specimens are of similar metallurgical condition and composition. However, it is not required for all applications of this standard.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

- 2.1 ASTM Standards:³
 - E29 Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications
 - E135 Terminology Relating to Analytical Chemistry for Metals, Ores, and Related Materials
 - E305 Practice for Establishing and Controlling Atomic Emission Spectrochemical Analytical Curves
 - E350 Test Methods for Chemical Analysis of Carbon Steel, Low-Alloy Steel, Silicon Electrical Steel, Ingot Iron, and Wrought Iron
 - E406 Practice for Using Controlled Atmospheres in Spectrochemical Analysis
 - E1019 Test Methods for Determination of Carbon, Sulfur, Nitrogen, and Oxygen in Steel, Iron, Nickel, and Cobalt Alloys by Various Combustion and Fusion Techniques
 - E1329 Practice for Verification and Use of Control Charts in Spectrochemical Analysis
 - E1601 Practice for Conducting an Interlaboratory Study to Evaluate the Performance of an Analytical Method
 - E1763 Guide for Interpretation and Use of Results from

¹ This test method is under the jurisdiction of ASTM Committee E01 on Analytical Chemistry for Metals, Ores, and Related Materials and is the direct responsibility of Subcommittee E01.01 on Iron, Steel, and Ferroalloys.

Current edition approved Nov. 15, 2015. Published March 2016. Originally approved in 1971. Last previous edition approved in 2014 as E415 – 14. DOI: 10.1520/E0415-15.

² Supporting data have been filed at ASTM International Headquarters and may be obtained by requesting Research Report RR:E01-1122. Contact ASTM Customer Service at service@astm.org.

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For Annual Book of ASTM Standards volume information, refer to the standard's Document Summary page on the ASTM website.

Interlaboratory Testing of Chemical Analysis Methods
(Withdrawn 2015)⁴

E1806 Practice for Sampling Steel and Iron for Determination of Chemical Composition

E1950 Practice for Reporting Results from Methods of Chemical Analysis

E2972 Guide for Production, Testing, and Value Assignment of In-House Reference Materials for Metals, Ores, and Other Related Materials

2.2 Other ASTM Documents

ASTM MNL 7 Manual on Presentation of Data and Control Chart Analysis⁵

3. Terminology

3.1 For definitions of terms used in this test method, refer to Terminology E135.

4. Summary of Test Method

4.1 A capacitor discharge is produced between the flat, ground surface of the disk specimen and a conically shaped electrode. The discharge is terminated at a predetermined intensity time integral of a selected iron line, or at a predetermined time, and the relative radiant energies of the analytical lines are recorded. The most sensitive lines of arsenic, boron, carbon, nitrogen, phosphorus, sulfur, and tin lie in the vacuum ultraviolet region. The absorption of the radiation by air in this region is overcome by evacuating the spectrometer or by use of a vacuum ultraviolet (VUV) transparent gas and flushing the spark chamber with argon.

5. Significance and Use

5.1 This test method for the spectrometric analysis of metals and alloys is primarily intended to test such materials for compliance with compositional specifications. It is assumed that all who use this test method will be analysts capable of performing common laboratory procedures skillfully and safely. It is expected that work will be performed in a properly equipped laboratory.

6. Apparatus

6.1 Sampling Devices:

6.1.1 Refer to Practice E1806 for devices and practices to sample liquid and solid iron and steel.

6.2 *Excitation Source*, capable of providing electrical parameters to spark a sample. See 11.1 for details.

6.3 *Spark Chamber*, automatically flushed with argon. The spark chamber shall be mounted directly on the spectrometer and shall be provided with a spark stand to hold a flat specimen and a lower counter electrode of rod form.

6.3.1 Follow the manufacturer's recommendations for cleaning the spark chamber. During continuous operation, this typically should be done every 24 h. Follow the manufacturer's recommendations for cleaning the entrance lens or window

(verifier data or other reference sample intensity data can typically indicate when this is necessary).

6.4 *Spectral Lines*—Table 1 lists spectral lines and internal standards usable for carbon and low alloy steel. The spectrometer must be able to measure at least one of the listed spectral lines for each of the listed elements. Spectral lines other than those listed in Table 1 may be used provided it can be shown experimentally that equivalent precision and accuracy are obtained.

6.5 *Measuring System*, spectrometer capable of converting light intensities to measurable electrical signals. The measuring system may consist of one of the following configurations:

6.5.1 A photomultiplier (PMT) array having individual voltage adjustments, capacitors in which the output of each photomultiplier is stored, a voltage measuring system to register the voltages on the capacitors either directly or indirectly, and the necessary switching arrangements to provide the desired sequence of operation.

6.5.2 A semiconductor detector array (CCD or CMOS), pixel selection electronics to reset the pixels and to transport the voltage of an individual pixel to one or more output ports of the detector arrays, and a voltage measuring system to register the voltage of said output ports.

6.5.3 A hybrid design using both photomultipliers and semiconductor arrays.

6.6 *Optical Path*—If the instrument is operated using a VUV transparent gas, check the manufacturer's suggested gas purity. It may be necessary to have a gas purification system consisting of a circulation pump and a cleaning cartridge to keep the O₂ (g) residual <500 ng/g and H₂O (g) residual <1 µg/g and remove impurities of nitrogen and hydrocarbons. If the instrument is using a vacuum pump, it should be capable of maintaining a vacuum of 3.33 Pa (25 µm Hg) or less.

NOTE 2—A pump with a displacement of at least 0.23 m³/min (8 ft³/min) is usually adequate.

6.7 *Gas System*, consisting of an argon supply with pressure and flow regulation. Automatic sequencing shall be provided to actuate the flow at a given rate for a specific time interval. The flow rate may be manually or automatically set. The argon system shall be in accordance with Practice E406.

7. Reagents and Materials

7.1 *Counter Electrodes*—The counter electrodes can be silver or thoriated tungsten rods, or other material, provided it can be shown experimentally that equivalent precision and bias are obtained. The rods can vary in diameter from 1.5 mm to 6.5 mm (depending on the instrument design) and typically are machined to a 90° or 120° angled tip.

7.1.1 A black deposit will collect on the tip of the electrode. This deposit should be removed between specimens (typically with a wire brush). If not removed, it can reduce the overall intensity of the spectral radiation or transfer slight amounts of contamination between specimens, or both. The number of acceptable burns on an electrode varies from one instrument to another, and should be established in each laboratory.

NOTE 3—It has been reported that thousands of burns can be performed on a thoriated tungsten electrode before replacement is necessary.

⁴ The last approved version of this historical standard is referenced on www.astm.org.

⁵ ASTM Manual Series, ASTM International, 8th edition, 2010.

TABLE 1 Internal Standard and Analytical Lines

Element	Wavelength, λ , nm	Line Classification ^A	Possible Interference ^B
Aluminum	396.15		Mo
	394.40		V, Mn, Mo, Ni
	308.22		V, Mn
Antimony	217.6		Ni, Nb, Mn, W
Arsenic	189.04		V, Cr
	197.20		Mo, W
	193.76		Mn
Boron	345.13		
	182.64		S, Mn, Mo
	182.59		W, Mn, Cu
Calcium	393.37		
	396.85		Nb
Carbon	165.81		Cr
	193.09		Al
Chromium	312.26		V
	313.21		
	425.44		
	298.92		Mn, V, Ni, Nb, Mo
	267.72		Mn, Mo, W
Cobalt	345.35		Cr, Mo
	228.62		Ni, Cr
	258.03		Fe, Mn, W
Copper	212.3		Si
	324.75		Mn, Nb
	327.40		Nb
	224.26		W, Ni
	213.60		Mo, Cr
	510.55		W
	136.14		
	157.40		
	172.24		
	174.28		
	179.34		
	182.88		
	205.13		
	216.20		
	217.81		
	218.65		
	226.76		
	235.12		
	239.15		
	277.21		
	281.33		
	285.18		
	296.69		
	297.05		
	299.95		
	300.81		
	303.74		
	304.76		
Iron (IS)	305.91		
	316.79		
	517.16		
	321.33		
	487.21		
	458.38		
	413.70		
	410.75		
	383.63		
	363.83		
	339.93		
	328.68		
	308.37		
	282.33		
	249.59		

TABLE 1 *Continued*

Element	Wavelength, λ , nm	Line Classification ^A	Possible Interference ^B
	226.76		
	218.65		
	216.20		
	193.53		
	190.48		
	187.75		
	149.65		
	271.44		
	273.07		
	492.39		Co
Lead	405.75		Mn
Manganese	293.31		Cr, Mo, Ni
	255.86		Zr
	263.82		Al, W
Molybdenum	379.83		Mn
	202.03		
	277.54		Cu, V, Co, Mn
	281.61		Mn
	386.41		V, Cr
Nickel	471.44		
	227.73		
	341.48		
	352.45		
	231.60		Co, Ti
	227.02		Nb, W
	243.79		Co, Fe, Ni
Niobium	313.08		Ti, V
	319.50		Mo, Al, V
Nitrogen	149.26		Fe, Ti, Si, Mn, Cu, Ni and nitride forming elements such as Ti
Phosphorus	178.29		Mo
Silicon	288.16		Mo, Cr, W
	251.61		Fe, V
	212.41		Mo, Ni, V, Cu, Nb
	390.55		Cr, Cu, W, Ti
Sulfur	180.73		Mn
Tin	147.52		
	189.99		Mn, Mo, Al
Titanium	308.80		Cu, Co
	337.28		Nb
Tungsten	324.20		Nb
	400.88		
	202.99		Ti, V, Mn
	220.50		Co
Vanadium	437.92		
	310.23		Fe, Mo, Nb, Ni
Zirconium	468.78		
	349.62		
	343.82		W
	206.19		W

^A The numerals I or II in the line classification column indicate that the line has been classified in a term array and definitely assigned to the normal atom (I) or to the singly ionized atom (II).

^B Interferences are dependent upon instrument design, spectrum line choices, and excitation conditions, and those listed require confirmation based upon specimens selected especially to demonstrate suspected interferences.

7.2 *Inert Gas, Argon*, in accordance with Practice E406.

8. Reference Materials

8.1 *Certified Reference Materials (CRMs)*—These are available from the National Institute of Standards and Technology (NIST) and other sources and span all or part of the mass fraction ranges listed in 1.1. They are used to calibrate the spectrometer for the elements of interest or to validate the performance of the test method. It is not recommended to use CRMs as verifiers or to establish the repeatability of the chemical measurement process.

NOTE 4—Certified Reference Materials manufactured by NIST are trademarked with the name, “Standard Reference Material.”

8.2 *Reference Materials (RMs)*—These are available from multiple suppliers or can be developed in house. Reference Materials are typically used in control procedures (verifiers) and in drift correction (standardization) of the spectrometer, and they may be useful in calibrations. These reference materials shall be homogenous and contain appropriate mass fractions of each element for the intended purpose. Refer to Guide E2972 for production of your own reference materials.

8.3 Several issues can impact the selection and use of CRMs and RMs:

8.3.1 Samples and reference materials may exhibit differences in metallurgical structure, in particular having different sizes, compositions, and distributions of inclusions. Inhomogeneous distribution of inclusions can worsen repeatability of individual measurements of elements found in the inclusions. Some inclusions may be removed during preburn steps prior to integration of intensities, causing low results. Typical samples can be used to determine repeatability of individual measurements to yield estimates consistent with performance for actual samples.

8.3.2 For certain elements, there may be no available reference materials with metallurgical structure similar to typical samples. Therefore, calibrations may be biased. It is recommended to validate results using typical samples analyzed using Test Methods E350 and E1019.

9. Preparation of Specimens and Reference Materials

9.1 The specimens and reference materials shall be prepared in the same manner. A specimen cut from a large sample section shall be of sufficient size and thickness for preparation and to properly fit the spectrometer stand. A 10-mm to 38-mm thick specimen is normally most practical.

9.2 Ensure that the specimens are free from voids and pits in the region to be measured (Note 5). Initially, grind the surface with a 50-grit to 80-grit abrasive belt or disc (wet or dry) or mill the surface. If wet grinding, perform the final grind with a dry abrasive belt or disc. A finer abrasive grinding media (for example, 120-grit) may be used for the final grind, but is not essential.

NOTE 5—Specimen porosity is undesirable because it leads to the improper “diffuse-type” rather than the desired “concentrated-type” discharge. The specimen surface should be kept clean because the specimen is the electron emitter, and electron emission is inhibited by oily, dirty surfaces.

9.2.1 Reference materials and specimens shall be refinished dry on an abrasive belt or disc before being remeasured on the same area.

10. Preparation of Apparatus

NOTE 6—The instructions given in this test method apply to most spectrometers. However, some settings and adjustments may require modification, and additional preparation of the equipment may be required. It is not within the scope of an ASTM test method to prescribe the minute details of the apparatus preparation, which may differ not only for each manufacturer, but also for different equipment from the same manufacturer. For a description of and further details of operation for a particular spectrometer, refer to the manufacturer’s manual(s).

10.1 Program the spectrometer to use the internal standard lines and one of the analytical lines for each element listed in Table 1. Multiple lines may be used for a given element (for example, nickel) depending on the mass fraction range and the individual spectrometer software.

10.2 Test the positioning of the spectrometer entrance slit to ensure that peak radiation is entering the spectrometer chamber. This shall be done initially and as often as necessary to maintain proper entrance slit alignment. Follow the manufacturer’s recommended procedures. The laboratory will determine the frequency of positioning the alignment based on instrument performance.

10.3 Exit slit positioning and alignment is normally performed by the manufacturer at spectrometer assembly. Under normal circumstances, further exit slit alignment is not necessary (Note 7).

NOTE 7—The manner and frequency of positioning or checking the position of the exit slits will depend on factors such as the type of spectrometer, the variety of analytical problems encountered, and the frequency of use. Each laboratory should establish a suitable check procedure utilizing qualified service engineers.

11. Burn and Exposure

11.1 Electrical Parameters:

11.1.1 Burn parameters are normally established by the spectrometer manufacturer. The following ranges are historical guidelines and newer instruments may vary from these:

Triggered Capacitor Discharge	
Capacitance, μF	10 to 15
Inductance, μH	50 to 70
Resistance, Ω	3 to 5
Potential, V	940 to 1000
Current, A, r-f	0.3 to 0.8
Number of discharges	60

11.1.2 When parameter values are established, maintain them carefully. The variation of the power supply voltage shall not exceed $\pm 5\%$ and preferably should be held within $\pm 2\%$.

11.1.3 *Initiation Circuit*—The initiator circuit parameters shall be adequate to uniformly trigger the capacitor discharge. The following settings are historical guidelines and newer instruments may vary from these:

Capacitance, μF	0.0025
Inductance, μH	residual
Resistance, Ω	2.5
Peak voltage, V	18 000

11.1.4 *Other Electrical Parameters*—Excitation units, on which the precise parameters given in 11.1.1 and 11.1.3 are not

available, may be used provided that it can be shown experimentally that equivalent precision and accuracy are obtained.

11.2 Burn and Measurement Conditions—The following ranges are normally adequate:

Argon flush period, s	5 to 15	
Preburn period, s	5 to 20	
Exposure period, s	3 to 30	
Argon flow	ft ³ /h	L/min
Flush	5 to 45	2.5 to 25
Preburn	5 to 45	2.5 to 25
Exposure	5 to 30	2.5 to 15

11.2.1 Select preburn and exposure periods after a study of volatilization rates during specimen burns. Once established, maintain the parameters consistently.

11.2.2 A high-purity argon atmosphere is required at the analytical gap. Molecular gas impurities, such as nitrogen, oxygen, hydrocarbons, or water vapor, either in the gas system or from improperly prepared specimens, should be minimized.

11.3 Electrode System—The specimen, electrically negative, serves as one electrode. The opposite electrode is a tungsten or silver rod, the tip of which has been machined to a 90° or 120° angled cone. Use either a 3 mm, 4 mm, or 5 mm (± 0.1 mm) analytical gap. Condition a fresh counter electrode with two burns to six burns using the operating conditions described in **11.1** and **11.2**.

11.4 Photomultiplier Potentials—The sensitivities of the photomultipliers are normally established and set by the spectrometer manufacturer based on the particular wavelengths selected.

11.5 Semiconductor Detector Array—In newer instruments semiconductor detector arrays are replacing PMTs. The width of the individual pixels shall be similar to the width of the exit slits used in conventional instruments equipped with PMTs.

12. Calibration, Standardization, and Verification

12.1 Calibration—Using the conditions given in **11.1** – **11.3**, measure calibrants and potential drift correction samples in a random sequence, bracketing these with measurements of any materials intended for use as verifiers. (A calibrant may be used later as a verifier. See **8.1**.) There shall be at least three calibrants for each element, spanning the required mass fraction range. Measure each calibrant, drift correction sample, and verifier two times to four times and use the average value. If the spectrometer system and software permit, repeat with different random sequences at least two times. Using the averages of the data for each point, determine analytical curves as directed in the spectrometer manufacturer's software or Practice **E305**.

12.2 Standardization—Following the manufacturer's recommendations, standardize on an initial setup or anytime that it is known or suspected that readings have shifted. Make the necessary corrections either by adjusting the controls on the readout or by applying arithmetic corrections. Standardization shall be done anytime verification indicates that readings have gone out of statistical control. In the case of automatic corrections conducted by the spectrometer software, observe the standardization factors and/or offsets. The factors and/or

offsets are often presented in the spectrometer software after standardization and/or stored in log files. Refer to your instrument manual or instrument manufacturer for access to this information.

12.3 Verification—Verify that the instrument's standardization is valid immediately after each standardization and as required in accordance with **12.3.2**.

12.3.1 Analyze verifiers in accordance with Section 13. If results do not fall within the control limits established in **12.4, run another standardization or investigate why the instrument may be malfunctioning.**

12.3.2 Each laboratory shall determine the necessary frequency of verification based on statistical analysis. Typically every 4 h to 8 h is practical and adequate. If the results are not within the control limits established in **12.4, perform a standardization and repeat verification. Repeat standardization as necessary so verification results are within control limits or investigate further for instrument problems.**

12.4 Quality Control—Establish control limits in accordance with ASTM MNL 7, Practice **E1329**, or other equivalent quality control procedure.

13. Measurements

13.1 Place the prepared surface of the specimen on the sample stand so that measurement shall impinge on a location approximately 6 mm ($\frac{1}{4}$ in.) from the edge of the specimen.

NOTE 8—With certain spectrometers, a properly burned specimen usually exhibits a dark ring around the pitted sparked area. With that equipment, a smooth texture, white burn without the characteristic dark ring indicates an improperly burned specimen. If boron nitride disks are used to mechanically restrict the burned area of the sample, a properly burned specimen may not exhibit a dark ring.

13.2 Measure specimens in duplicate and report the average of the duplicate results.

14. Calculation

14.1 Using the average results obtained in **13.2, calculate the mass fractions of the elements from the analytical curves developed in **12.1**.**

14.2 Rounding of test results obtained using this test method shall be performed in accordance with the Rounding Method of Practice **E29, unless an alternative rounding method is specified by the customer or applicable material specification.**

15. Precision and Bias

15.1 Supporting data have been filed at ASTM International Headquarters and may be obtained by requesting RR:E01-1122.² The interlaboratory test data summarized in **Table 2 have been evaluated in accordance with Practice **E1601**.**

15.2 Precision—Up to eight laboratories cooperated in performing this test method with thirteen unknown samples and obtained the statistical information summarized in **Table 2**.

15.3 Bias—Differences between average composition determined by this method and the certified compositions provides the bias found in the interlaboratory study. Bias information is found in **Table 2**.

TABLE 2 Statistical Information

Material	Number of Laboratories	Certified Value, %	Xbar	r	R	Bias
Aluminum						
Sample 1	7	0.016	0.0175	0.0034	0.0047	0.0015
Sample 2	7	0.041	0.0413	0.0037	0.0067	0.0003
Sample 3	8	0.015	0.0174	0.0013	0.0028	0.0024
Sample 4	8	0.018	0.0200	0.0006	0.0024	0.0020
Sample 5	8	0.062	0.0668	0.0042	0.0111	0.0048
Sample 6	8	0.0009	0.0023	0.0002	0.0022	0.0014
Sample 7	8	0.093	0.0890	0.0031	0.0152	-0.0040
Sample 8	7	0.021	0.0234	0.0015	0.0031	0.0024
Sample 9	7	0.03	0.0333	0.0017	0.0037	0.0033
Sample 10	8	0.024	0.0256	0.0009	0.0028	0.0016
Sample 11	8	0.027	0.0286	0.0010	0.0032	0.0016
Sample 12	8	0.017	0.0201	0.0012	0.0043	0.0031
Sample 13	7		0.0031	0.0010	0.0027	
Antimony						
Sample 1	7	0.027	0.0272	0.0026	0.0098	0.0002
Sample 2	5		0.0008	0.0007	0.0012	
Sample 3	7		0.0014	0.0009	0.0022	
Sample 4	6		0.0009	0.0007	0.0022	
Sample 5	6	0.0004	0.0011	0.0007	0.0024	0.0007
Sample 6	8	0.0025	0.0026	0.0011	0.0033	0.0001
Sample 7	8	0.006	0.0062	0.0011	0.0029	0.0002
Sample 8	7	0.002	0.0017	0.0007	0.0022	-0.0003
Sample 9	5		0.0006	0.0005	0.0011	
Sample 10	8	0.003	0.0019	0.0012	0.0037	-0.0011
Sample 11	6		0.0010	0.0008	0.0024	
Sample 12	8		0.0015	0.0008	0.0028	
Sample 13	7		0.0024	0.0010	0.0047	
Arsenic						
Sample 1	6	0.05	0.0459	0.0024	0.0116	-0.0041
Sample 2	6	0.003	0.0033	0.0008	0.0014	0.0003
Sample 3	7		0.0052	0.0008	0.0047	
Sample 4	7	(<0.005)	0.0004	0.0006	0.0009	
Sample 5	7	0.0035	0.0037	0.0008	0.0014	0.0002
Sample 6	7	0.0056	0.0071	0.0010	0.0021	0.0015
Sample 7	7	(0.005)	0.0065	0.0008	0.0048	
Sample 8	6	0.007	0.0074	0.0008	0.0037	0.0004
Sample 9	6		0.0041	0.0009	0.0034	
Sample 10	7	0.004	0.0053	0.0008	0.0035	0.0013
Sample 11	7	0.0044	0.0050	0.0009	0.0014	0.0006
Sample 12	7	0.007	0.0079	0.0012	0.0076	0.0009
Sample 13	6	0.07	0.0654	0.0077	0.0196	-0.0046
Boron						
Sample 1	4	(0.00002)	0.0002	0.0001	0.0002	
Sample 2	7	(0.0002)	0.0003	0.0001	0.0002	
Sample 3	8		0.0004	0.0001	0.0004	
Sample 4	8	(<0.0005)	0.0005	0.0001	0.0002	
Sample 5	7		0.0002	0.0001	0.0002	
Sample 6	8	0.0002	0.0003	0.0000	0.0002	0.0001
Sample 7	8	0.0047	0.0045	0.0004	0.0020	-0.0002
Sample 8	5		0.0002	0.0001	0.0005	
Sample 9	4		0.0003	0.0000	0.0004	
Sample 10	7		0.0002	0.0001	0.0002	
Sample 11	8		0.0003	0.0001	0.0004	
Sample 12	8	(0.0004)	0.0004	0.0001	0.0006	
Sample 13	7		0.0005	0.0001	0.0002	
Calcium						
Sample 1	3	(<0.0001)	0.0001	0.0001	0.0003	
Sample 2	4	(0.0005)	0.0001	0.0001	0.0001	
Sample 3	8		0.0003	0.0001	0.0003	
Sample 4	6	(0.001)	0.0002	0.0001	0.0002	
Sample 5	4	(<0.0005)	0.0001	0.0001	0.0002	
Sample 6	8	0.0012	0.0012	0.0003	0.0008	0.0000
Sample 7	8		0.0006	0.0001	0.0004	
Sample 8	7		0.0003	0.0002	0.0004	
Sample 9	7	0.002	0.0018	0.0004	0.0008	-0.0002
Sample 10	7	0.0003	0.0002	0.0001	0.0002	-0.0001
Sample 11	6		0.0001	0.0001	0.0002	
Sample 12	3	(0.0001)	0.0001	0.0000	0.0002	
Sample 13	7		0.0003	0.0003	0.0004	
Carbon						
Sample 1	7	0.211	0.2169	0.0073	0.0252	0.0059
Sample 2	7	0.142	0.1525	0.0084	0.0230	0.0105
Sample 3	8	0.13	0.1384	0.0072	0.0167	0.0084

TABLE 2 *Continued*

Material	Number of Laboratories	Certified Value, %	Xbar	r	R	Bias
Sample 4	8	0.658	0.6605	0.0075	0.0163	0.0025
Sample 5	8	0.483	0.4892	0.0092	0.0124	0.0062
Sample 6	8	0.457	0.4687	0.0110	0.0156	0.0117
Sample 7	8	0.332	0.3251	0.0202	0.0279	-0.0069
Sample 8	7	0.128	0.1305	0.0045	0.0076	0.0025
Sample 9	7	0.12	0.1196	0.0039	0.0142	-0.0004
Sample 10	8	1.03	1.024	0.0170	0.0227	-0.006
Sample 11	8	0.255	0.2530	0.0072	0.0137	-0.0020
Sample 12	8	0.107	0.1114	0.0040	0.0115	0.0044
Sample 13	7	0.376	0.3593	0.0280	0.0280	-0.0167
Chromium						
Sample 1	7	0.081	0.0797	0.0020	0.0066	-0.0013
Sample 2	7	0.044	0.0444	0.0009	0.0051	0.0004
Sample 3	8	4.22	4.209	0.0327	3.3209	-0.011
Sample 4	8	0.16	0.1564	0.0030	0.0133	-0.0036
Sample 5	8	0.021	0.0190	0.0012	0.0035	-0.0020
Sample 6	8	0.098	0.0973	0.0013	0.0079	-0.0007
Sample 7	8	5.11	5.086	0.0432	3.5334	-0.024
Sample 8	7	2.09	2.095	0.0169	0.0832	0.005
Sample 9	7	2.56	2.557	0.0167	0.1249	-0.003
Sample 10	8	1.36	1.356	0.0221	0.0911	-0.004
Sample 11	8	0.34	0.3334	0.0023	0.0255	-0.0066
Sample 12	8	8.22	8.143	0.0789	0.8918	-0.077
Sample 13	7	0.062	0.0650	0.0083	0.0083	0.0030
Cobalt						
Sample 1	7	0.19	0.1885	0.0011	0.0217	-0.0015
Sample 2	7	0.005	0.0033	0.0002	0.0028	-0.0017
Sample 3	8	0.011	0.0116	0.0006	0.0026	0.0006
Sample 4	8	0.0019	0.0020	0.0009	0.0024	0.0001
Sample 5	8	0.005	0.0038	0.0006	0.0025	-0.0012
Sample 6	8	0.0078	0.0072	0.0007	0.0032	-0.0006
Sample 7	8	0.006	0.0071	0.0009	0.0026	0.0011
Sample 8	7	0.01	0.0096	0.0006	0.0033	-0.0004
Sample 9	7		0.0088	0.0009	0.0029	
Sample 10	8	0.007	0.0068	0.0009	0.0028	-0.0002
Sample 11	8	0.01	0.0093	0.0009	0.0022	-0.0007
Sample 12	8	0.016	0.0160	0.0008	0.0041	0.0000
Sample 13	7		0.0061	0.0009	0.0032	
Copper						
Sample 1	7	0.023	0.0231	0.0011	0.0030	0.0001
Sample 2	7	0.03	0.0339	0.0014	0.0034	0.0039
Sample 3	8	0.11	0.1151	0.0045	0.0101	0.0051
Sample 4	8	0.151	0.1518	0.0070	0.0146	0.0008
Sample 5	8	0.015	0.0145	0.0007	0.0032	-0.0005
Sample 6	8	0.299	0.2993	0.0039	0.0254	0.0003
Sample 7	8	0.057	0.0569	0.0025	0.0058	-0.0001
Sample 8	7	0.177	0.1784	0.0034	0.0104	0.0014
Sample 9	7	0.08	0.0797	0.0034	0.0061	-0.0003
Sample 10	8	0.106	0.1068	0.0081	0.0130	0.0008
Sample 11	8	0.11	0.1094	0.0049	0.0103	-0.0006
Sample 12	8	0.115	0.1190	0.0050	0.0097	0.0040
Sample 13	7	0.051	0.0511	0.0031	0.0047	0.0001
Manganese						
Sample 1	7	0.316	0.3153	0.0033	0.0130	-0.0007
Sample 2	7	1.12	1.148	0.0200	0.0373	0.028
Sample 3	8	0.44	0.4549	0.0058	0.0161	0.0149
Sample 4	8	0.82	0.8319	0.0176	0.0336	0.0119
Sample 5	8	0.72	0.7330	0.0081	0.0265	0.0130
Sample 6	8	0.772	0.7825	0.0116	0.0298	0.0105
Sample 7	8	0.169	0.1713	0.0033	0.0091	0.0023
Sample 8	7	0.441	0.4437	0.0066	0.0168	0.0027
Sample 9	7	0.55	0.5584	0.0075	0.0226	0.0084
Sample 10	8	0.33	0.3340	0.0075	0.0182	0.0040
Sample 11	8	1.42	1.445	0.0132	0.0551	0.025
Sample 12	8	0.333	0.3374	0.0028	0.0131	0.0044
Sample 13	7	0.8	0.8070	0.0251	0.0402	0.0070
Molybdenum						
Sample 1	7	0.05	0.0517	0.0016	0.0024	0.0017
Sample 2	7	0.008	0.0083	0.0002	0.0034	0.0003
Sample 3	8	0.47	0.4743	0.0095	0.0270	0.0043
Sample 4	8	0.019	0.0204	0.0009	0.0033	0.0014
Sample 5	8	0.005	0.0051	0.0004	0.0037	0.0001
Sample 6	8	0.0419	0.0417	0.0019	0.0026	-0.0002
Sample 7	8	1.28	1.307	0.0415	0.1200	0.027

TABLE 2 *Continued*

Material	Number of Laboratories	Certified Value, %	Xbar	r	R	Bias
Sample 8	7	0.89	0.9044	0.0163	0.0798	0.0144
Sample 9	7	1.02	1.035	0.0128	0.1032	0.015
Sample 10	8	0.044	0.0448	0.0013	0.0024	0.0008
Sample 11	8	0.42	0.4210	0.0103	0.0168	0.0010
Sample 12	8	0.9	0.8976	0.0215	0.0490	-0.0024
Sample 13	7	0.2	0.1978	0.0228	0.0228	-0.0022
Nickel						
Sample 1	7	0.43	0.4286	0.0044	0.0347	-0.0014
Sample 2	7	0.029	0.0316	0.0006	0.0027	0.0026
Sample 3	8	0.12	0.1290	0.0020	0.0091	0.0090
Sample 4	8	0.163	0.1682	0.0031	0.0116	0.0052
Sample 5	8	0.015	0.0146	0.0007	0.0031	-0.0004
Sample 6	8	0.154	0.1573	0.0018	0.0119	0.0033
Sample 7	8	0.445	0.4486	0.0074	0.0363	0.0036
Sample 8	7	0.197	0.1999	0.0021	0.0159	0.0029
Sample 9	7	0.25	0.2498	0.0033	0.0178	-0.0002
Sample 10	8	0.135	0.1356	0.0035	0.0115	0.0006
Sample 11	8	1.74	1.728	0.0237	0.0867	-0.012
Sample 12	8	0.123	0.1213	0.0023	0.0105	-0.0017
Sample 13	7	0.069	0.0694	0.0019	0.0071	0.0004
Niobium						
Sample 1	7	0.003	0.0031	0.0003	0.0013	0.0001
Sample 2	7	0.041	0.0415	0.0015	0.0074	0.0005
Sample 3	8	0.002	0.0064	0.0004	0.0028	0.0044
Sample 4	8	0.024	0.0245	0.0021	0.0048	0.0005
Sample 5	5	(<0.002)	0.0003	0.0002	0.0006	
Sample 6	7	0.0009	0.0005	0.0002	0.0007	-0.0004
Sample 7	8	0.122	0.1178	0.011	0.0215	-0.0042
Sample 8	7	(<0.003)	0.0036	0.0003	0.0018	
Sample 9	7		0.0044	0.0003	0.0018	
Sample 10	8		0.0021	0.0003	0.0015	
Sample 11	8		0.0013	0.0003	0.0022	
Sample 12	8	0.076	0.0839	0.0019	0.0139	0.0079
Sample 13	6		0.0005	0.0003	0.0006	0.0005
Nitrogen						
Sample 1	7	0.0099	0.0083	0.0008	0.0048	-0.0016
Sample 2	7		0.0078	0.0010	0.0050	
Sample 3	8	0.018	0.0228	0.0684	0.0684	0.0048
Sample 4	6		0.0011	0.0004	0.0029	
Sample 5	8	0.0056	0.0040	0.0009	0.0050	-0.0016
Sample 6	8	0.0106	0.0099	0.0010	0.0055	-0.0007
Sample 7	8	0.0076	0.0094	0.0013	0.0054	0.0018
Sample 8	7	0.0097	0.0102	0.0012	0.0056	0.0005
Sample 9	7		0.0101	0.0009	0.0064	
Sample 10	8	0.0084	0.0075	0.0007	0.0048	-0.0009
Sample 11	8	0.0066	0.0071	0.0008	0.0051	0.0005
Sample 12	6	0.055	0.0564	0.0026	0.0233	0.0014
Sample 13	7		0.0106	0.0010	0.0051	
Phosphorous						
Sample 1	7	0.018	0.0170	0.0007	0.0043	-0.0010
Sample 2	7	0.016	0.0183	0.0012	0.0053	0.0023
Sample 3	8	0.017	0.0159	0.0008	0.0047	-0.0011
Sample 4	8	0.011	0.0112	0.0010	0.0043	0.0002
Sample 5	8	0.01	0.0090	0.0007	0.0029	-0.0010
Sample 6	8	0.0096	0.0101	0.0018	0.0034	0.0005
Sample 7	8	0.006	0.0064	0.0008	0.0029	0.0004
Sample 8	7	0.012	0.0129	0.0008	0.0034	0.0009
Sample 9	7	0.01	0.0088	0.0006	0.0017	-0.0012
Sample 10	8	0.013	0.0164	0.0564	0.0567	0.0034
Sample 11	8	0.01	0.0087	0.0008	0.0019	-0.0013
Sample 12	8	0.008	0.0078	0.0008	0.0020	-0.0002
Sample 13	7	0.061	0.0584	0.0068	0.0105	-0.0026
Silicon						
Sample 1	7	0.015	0.0127	0.0010	0.0071	-0.0023
Sample 2	7	0.058	0.0668	0.0012	0.0088	0.0088
Sample 3	8	0.27	0.2787	0.0043	0.0117	0.0087
Sample 4	8	0.5	0.4959	0.0074	0.0153	-0.0041
Sample 5	8	0.24	0.2251	0.0036	0.0094	-0.0149
Sample 6	8	0.21	0.2111	0.0030	0.0111	0.0011
Sample 7	8	0.775	0.7541	0.0157	0.0330	-0.0209
Sample 8	7	0.255	0.2520	0.0022	0.0100	-0.0030
Sample 9	7	0.32	0.3211	0.0039	0.0117	0.0011
Sample 10	8	0.32	0.3217	0.0057	0.0116	0.0017
Sample 11	8	1.54	1.519	0.0217	0.0612	-0.021

TABLE 2 *Continued*

Material	Number of Laboratories	Certified Value, %	Xbar	r	R	Bias
Sample 12	8	0.327	0.3322	0.0043	0.0197	0.0052
Sample 13	7	0.31	0.3044	0.0082	0.0135	-0.0056
Sulfur						
Sample 1	7	0.005	0.0460	0.0024	0.3116	0.0410
Sample 2	7	0.008	0.0076	0.0008	0.0031	-0.0004
Sample 3	8	0.015	0.0146	0.0010	0.0021	-0.0004
Sample 4	8	0.012	0.0135	0.0018	0.0044	0.0015
Sample 5	8	0.025	0.0232	0.0039	0.0064	-0.0018
Sample 6	8	0.0234	0.0221	0.0035	0.0054	-0.0013
Sample 7	8	0.033	0.0321	0.0038	0.0063	-0.0009
Sample 8	7	0.026	0.0241	0.0026	0.0056	-0.0019
Sample 9	7	0.003	0.0013	0.0005	0.0014	-0.0017
Sample 10	8	0.014	0.0144	0.0032	0.0046	0.0004
Sample 11	8	0.004	0.0046	0.0007	0.0007	0.0006
Sample 12	8	0.008	0.0076	0.0005	0.0023	-0.0004
Sample 13	7	0.047	0.0454	0.0082	0.0112	-0.0016
Tin						
Sample 1	7	0.061	0.0588	0.0011	0.0079	-0.0022
Sample 2	7	0.002	0.0028	0.0008	0.0022	0.0008
Sample 3	8	0.008	0.0073	0.0003	0.0014	-0.0007
Sample 4	8	0.026	0.0263	0.0010	0.0028	0.0003
Sample 5	7	(0.0006)	0.0015	0.0002	0.0014	
Sample 6	8	0.0124	0.0127	0.0006	0.0016	0.0003
Sample 7	8	0.005	0.0049	0.0003	0.0023	-0.0001
Sample 8	7	0.013	0.0135	0.0003	0.0015	0.0005
Sample 9	7		0.0047	0.0002	0.0019	
Sample 10	8	0.006	0.0064	0.0010	0.0013	0.0004
Sample 11	8	0.006	0.0075	0.0003	0.0013	0.0015
Sample 12	8	0.009	0.0094	0.0021	0.0022	0.0004
Sample 13	7	0.054	0.0481	0.0043	0.0062	-0.0059
Titanium						
Sample 1	7	0.004	0.0036	0.0002	0.0008	-0.0004
Sample 2	7	0.008	0.0076	0.0003	0.0009	-0.0004
Sample 3	8	0.003	0.0036	0.0002	0.0005	0.0006
Sample 4	8	0.015	0.0156	0.0011	0.0016	0.0006
Sample 5	7	(0.001)	0.0011	0.0001	0.0006	
Sample 6	8	0.0009	0.0009	0.0001	0.0006	0.0000
Sample 7	8	0.034	0.0358	0.0028	0.0040	0.0018
Sample 8	7	(0.001)	0.0012	0.0001	0.0006	
Sample 9	7		0.0017	0.0001	0.0006	
Sample 10	8	0.003	0.0020	0.0010	0.0012	-0.0010
Sample 11	8	0.003	0.0037	0.0004	0.0007	0.0007
Sample 12	8	(0.002)	0.0027	0.0001	0.0006	
Sample 13	7	0.01	0.0112	0.0022	0.0028	0.0012
Vanadium						
Sample 1	7	0.01	0.0106	0.0008	0.0019	0.0006
Sample 2	7	0.012	0.0122	0.0007	0.0024	0.0002
Sample 3	8	0.016	0.0194	0.0008	0.0021	0.0034
Sample 4	8	0.012	0.0124	0.0010	0.0030	0.0004
Sample 5	7	(<0.002)	0.0012	0.0002	0.0014	
Sample 6	8	0.0295	0.0298	0.0009	0.0029	0.0003
Sample 7	8	0.802	0.8233	0.0205	0.0403	0.0213
Sample 8	7	0.003	0.0036	0.0005	0.0013	0.0006
Sample 9	7	0.015	0.0134	0.0009	0.0020	-0.0016
Sample 10	8	0.005	0.0046	0.0004	0.0015	-0.0004
Sample 11	8	0.003	0.0020	0.0003	0.0020	-0.0010
Sample 12	8	0.236	0.2366	0.0062	0.0163	0.0006
Sample 13	7		0.0036	0.0025	0.0031	
Zirconium						
Sample 1	6	(0.01)	0.0278	0.0096	0.0108	
Sample 2	6	0.022	0.0173	0.0055	0.0061	-0.0047
Sample 3	7		0.0005	0.0002	0.0019	
Sample 4	7		0.0003	0.0001	0.0006	
Sample 5	7		0.0002	0.0001	0.0004	
Sample 6	7	0.0007	0.0003	0.0001	0.0005	-0.0004
Sample 7	7	0.052	0.0513	0.0126	0.0190	-0.0007
Sample 8	5		0.0004	0.0001	0.0015	
Sample 9	6		0.0005	0.0006	0.0023	
Sample 10	7		0.0003	0.0002	0.0008	
Sample 11	7		0.0003	0.0001	0.0011	
Sample 12	7	(0.001)	0.0007	0.0001	0.0034	
Sample 13	6		0.0003	0.0001	0.0006	

16. Keywords

16.1 carbon steel; low-alloy steel; spark atomic emission; spectrometric analysis; spectrometry

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; <http://www.copyright.com/>

Anexo 2. Norma ASTM_E 18-15



Standard Test Methods for Rockwell Hardness of Metallic Materials^{1,2}

This standard is issued under the fixed designation E18; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the U.S. Department of Defense.

1. Scope*

1.1 These test methods cover the determination of the Rockwell hardness and the Rockwell superficial hardness of metallic materials by the Rockwell indentation hardness principle. This standard provides the requirements for Rockwell hardness machines and the procedures for performing Rockwell hardness tests.

1.2 This standard includes additional requirements in annexes:

Verification of Rockwell Hardness Testing Machines	Annex A1
Rockwell Hardness Standardizing Machines	Annex A2
Standardization of Rockwell Indenters	Annex A3
Standardization of Rockwell Hardness Test Blocks	Annex A4
Guidelines for Determining the Minimum Thickness of a Test Piece	Annex A5
Hardness Value Corrections When Testing on Convex Cylindrical Surfaces	Annex A6

1.3 This standard includes nonmandatory information in appendixes which relates to the Rockwell hardness test.

List of ASTM Standards Giving Hardness Values	Appendix X1
Corresponding to Tensile Strength	
Examples of Procedures for Determining Rockwell Hardness Uncertainty	Appendix X2

1.4 *Units*—At the time the Rockwell hardness test was developed, the force levels were specified in units of kilograms-force (kgf) and the indenter ball diameters were specified in units of inches (in.). This standard specifies the units of force and length in the International System of Units (SI); that is, force in Newtons (N) and length in millimeters (mm). However, because of the historical precedent and continued common usage, force values in kgf units and ball diameters in inch units are provided for information and much of the discussion in this standard refers to these units.

1.5 The test principles, testing procedures, and verification procedures are essentially identical for both the Rockwell and

¹ These test methods are under the jurisdiction of ASTM Committee E28 on Mechanical Testing and are the direct responsibility of Subcommittee E28.06 on Indentation Hardness Testing.

Current edition approved Feb. 1, 2015. Published March 2015. Originally approved in 1932. Last previous edition approved in 2014 as E18 – 14a. DOI: 10.1520/E0018-15.

² In this test method, the term Rockwell refers to an internationally recognized type of indentation hardness test as defined in Section 3, and not to the hardness testing equipment of a particular manufacturer.

Rockwell superficial hardness tests. The significant differences between the two tests are that the test forces are smaller for the Rockwell superficial test than for the Rockwell test. The same type and size indenters may be used for either test, depending on the scale being employed. Accordingly, throughout this standard, the term Rockwell will imply both Rockwell and Rockwell superficial unless stated otherwise.

1.6 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:³

- [A370](#) Test Methods and Definitions for Mechanical Testing of Steel Products
[A623](#) Specification for Tin Mill Products, General Requirements
[A623M](#) Specification for Tin Mill Products, General Requirements [Metric]
[B19](#) Specification for Cartridge Brass Sheet, Strip, Plate, Bar, and Disks
[B36/B36M](#) Specification for Brass Plate, Sheet, Strip, And Rolled Bar
[B96/B96M](#) Specification for Copper-Silicon Alloy Plate, Sheet, Strip, and Rolled Bar for General Purposes and Pressure Vessels
[B103/B103M](#) Specification for Phosphor Bronze Plate, Sheet, Strip, and Rolled Bar
[B121/B121M](#) Specification for Leaded Brass Plate, Sheet, Strip, and Rolled Bar
[B122/B122M](#) Specification for Copper-Nickel-Tin Alloy, Copper-Nickel-Zinc Alloy (Nickel Silver), and Copper-Nickel Alloy Plate, Sheet, Strip, and Rolled Bar
[B130](#) Specification for Commercial Bronze Strip for Bullet Jackets
[B134/B134M](#) Specification for Brass Wire

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For Annual Book of ASTM Standards volume information, refer to the standard's Document Summary page on the ASTM website.

B152/B152M Specification for Copper Sheet, Strip, Plate, and Rolled Bar

B370 Specification for Copper Sheet and Strip for Building Construction

E29 Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications

E92 Test Method for Vickers Hardness of Metallic Materials (Withdrawn 2010)⁴

E140 Hardness Conversion Tables for Metals Relationship Among Brinell Hardness, Vickers Hardness, Rockwell Hardness, Superficial Hardness, Knoop Hardness, Sclerometer Hardness, and Leeb Hardness

E384 Test Method for Knoop and Vickers Hardness of Materials

E691 Practice for Conducting an Interlaboratory Study to Determine the Precision of a Test Method

2.2 *American Bearings Manufacturer Association Standard:*

ABMA 10-1989 Metal Balls⁵

2.3 *ISO Standards:*

ISO 6508-1 Metallic Materials—Rockwell Hardness Test—Part 1: Test Method (scales A, B, C, D, E, F, G, H, K, N, T)⁶

ISO/IEC 17011 Conformity Assessment—General Requirements for Accreditation Bodies Accrediting Conformity Assessment Bodies⁶

ISO/IEC 17025 General Requirements for the Competence of Testing and Calibration Laboratories⁶

2.4 *Society of Automotive Engineers (SAE) Standard:*

SAE J417 Hardness Tests and Hardness Number Conversions⁷

3. Terminology and Equations

3.1 Definitions:

3.1.1 *calibration*—determination of the values of the significant parameters by comparison with values indicated by a reference instrument or by a set of reference standards.

3.1.2 *verification*—checking or testing to assure conformance with the specification.

3.1.3 *standardization*—to bring in conformance to a known standard through verification or calibration.

3.1.4 *Rockwell hardness test*—an indentation hardness test using a verified machine to force a diamond spherconical indenter or tungsten carbide (or steel) ball indenter, under specified conditions, into the surface of the material under test, and to measure the difference in depth of the indentation as the force on the indenter is increased from a specified preliminary test force to a specified total test force and then returned to the preliminary test force.

⁴ The last approved version of this historical standard is referenced on www.astm.org.

⁵ Available from American Bearing Manufacturers Association (ABMA), 2025 M Street, NW, Suite 800, Washington, DC 20036.

⁶ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

⁷ Available from Society of Automotive Engineers (SAE), 400 Commonwealth Dr., Warrendale, PA 15096-0001, <http://www.sae.org>.

3.1.5 *Rockwell superficial hardness test*—same as the Rockwell hardness test except that smaller preliminary and total test forces are used with a shorter depth scale.

3.1.6 *Rockwell hardness number*—a number derived from the net increase in the depth of indentation as the force on an indenter is increased from a specified preliminary test force to a specified total test force and then returned to the preliminary test force.

3.1.7 *Rockwell hardness machine*—a machine capable of performing a Rockwell hardness test and/or a Rockwell superficial hardness test and displaying the resulting Rockwell hardness number.

3.1.7.1 *Rockwell hardness testing machine*—a Rockwell hardness machine used for general testing purposes.

3.1.7.2 *Rockwell hardness standardizing machine*—a Rockwell hardness machine used for the standardization of Rockwell hardness indenters, and for the standardization of Rockwell hardness test blocks. The standardizing machine differs from a regular Rockwell hardness testing machine by having tighter tolerances on certain parameters.

3.2 Equations:

3.2.1 The average \bar{H} of a set of n hardness measurements H_1, H_2, \dots, H_n is calculated as:

$$\bar{H} = \frac{H_1 + H_2 + \dots + H_n}{n} \quad (1)$$

3.2.2 The error E in the performance of a Rockwell hardness machine at each hardness level, relative to a standardized scale, is determined as:

$$E = \bar{H} - H_{STD} \quad (2)$$

where:

\bar{H} = average of n hardness measurements H_1, H_2, \dots, H_n made on a standardized test block as part of a performance verification, and

H_{STD} = certified average hardness value of the standardized test block.

3.2.3 The repeatability R in the performance of a Rockwell hardness machine at each hardness level, under the particular verification conditions, is estimated by the range of n hardness measurements made on a standardized test block as part of a performance verification, defined as:

$$R = H_{max} - H_{min} \quad (3)$$

where:

H_{max} = highest hardness value, and
 H_{min} = lowest hardness value.

4. Significance and Use

4.1 The Rockwell hardness test is an empirical indentation hardness test that can provide useful information about metallic materials. This information may correlate to tensile strength, wear resistance, ductility, and other physical characteristics of metallic materials, and may be useful in quality control and selection of materials.

4.2 Rockwell hardness tests are considered satisfactory for acceptance testing of commercial shipments, and have been used extensively in industry for this purpose.

4.3 Rockwell hardness testing at a specific location on a part may not represent the physical characteristics of the whole part or end product.

4.4 Adherence to this standard test method provides traceability to national Rockwell hardness standards except as stated otherwise.

5. Principles of Test and Apparatus

5.1 *Rockwell Hardness Test Principle*—The general principle of the Rockwell indentation hardness test is illustrated in Fig. 1. The test is divided into three steps of force application and removal.

Step 1—The indenter is brought into contact with the test specimen, and the preliminary test force F_0 is applied. After holding the preliminary test force for a specified dwell time, the baseline depth of indentation is measured.

Step 2—The force on the indenter is increased at a controlled rate by the additional test force F_1 to achieve the total test force F . The total test force is held for a specified dwell time.

Step 3—The additional test force is removed, returning to the preliminary test force. After holding the preliminary test force for a specified dwell time, the final depth of indentation is measured. The Rockwell hardness value is derived from the difference h in the final and baseline indentation depths while under the preliminary test force. The preliminary test force is removed and the indenter is removed from the test specimen.

5.1.1 There are two general classifications of the Rockwell test: the Rockwell hardness test and the Rockwell superficial hardness test. The significant difference between the two test classifications is in the test forces that are used. For the Rockwell hardness test, the preliminary test force is 10 kgf (98 N) and the total test forces are 60 kgf (589 N), 100 kgf (981 N), and 150 kgf (1471 N). For the Rockwell superficial hardness test, the preliminary test force is 3 kgf (29 N) and the total test forces are 15 kgf (147 N), 30 kgf (294 N), and 45 kgf (441 N).

5.1.2 Indenters for the Rockwell hardness test include a diamond spherconical indenter and tungsten carbide ball indenters of specified diameters.




FIG. 1 Rockwell Hardness Test Method (Schematic Diagram)

5.1.2.1 Steel indenter balls may be used only for testing thin sheet tin mill products specified in Specifications A623 and A623M using the HR15T and HR30T scales with a diamond spot anvil. Testing of this product may give significantly differing results using a tungsten carbide ball as compared to historical test data using a steel ball.

NOTE 1—Previous editions of this standard have stated that the steel ball was the standard type of Rockwell indenter ball. The tungsten carbide ball is considered the standard type of Rockwell indenter ball. The use of tungsten carbide balls provide an improvement to the Rockwell hardness test because of the tendency of steel balls to flatten with use, which results in an erroneously elevated hardness value. The user is cautioned that Rockwell hardness tests comparing the use of steel and tungsten carbide balls have been shown to give different results. For example, depending on the material tested and its hardness level, Rockwell B scale tests using a tungsten carbide ball indenter have given results approximately one Rockwell point lower than when a steel ball indenter is used.

5.1.3 The Rockwell hardness scales are defined by the combinations of indenter and test forces that may be used. The standard Rockwell hardness scales and typical applications of the scales are given in Tables 1 and 2. Rockwell hardness values shall be determined and reported in accordance with one of these standard scales.

5.2 *Calculation of the Rockwell Hardness Number*—During a Rockwell test, the force on the indenter is increased from a preliminary test force to a total test force, and then returned to the preliminary test force. The difference in the two indentation depth measurements, while under the preliminary test force, is measured as h (see Fig. 1).

5.2.1 The unit measurement for h is mm. From the value of h , the Rockwell hardness number is derived. The Rockwell hardness number is calculated as:

5.2.1.1 For scales using a diamond spherconical indenter (see Tables 1 and 2):

$$\text{Rockwell Hardness} = 100 - \frac{h}{0.002} \quad (4)$$

$$\text{Rockwell Superficial Hardness} = 100 - \frac{h}{0.001} \quad (5)$$

where h is in mm.

5.2.1.2 For scales using a ball indenter (see Tables 1 and 2):

$$\text{Rockwell Hardness} = 130 - \frac{h}{0.002} \quad (6)$$

$$\text{Rockwell Superficial Hardness} = 100 - \frac{h}{0.001} \quad (7)$$

where h is in mm.

5.2.2 The Rockwell hardness number is an arbitrary number, which, by method of calculation, results in a higher number for harder material.

5.2.3 Rockwell hardness values shall not be designated by a number alone because it is necessary to indicate which indenter and forces have been employed in making the test (see Tables 1 and 2). Rockwell hardness numbers shall be quoted with a scale symbol representing the indenter and forces used. The hardness number is followed by the symbol HR and the scale designation. When a ball indenter is used, the scale designation

TABLE 1 Rockwell Hardness Scales

Scale Symbol	Indenter	Total Test Force, kgf	Dial Figures	Typical Applications of Scales
B	1/16-in. (1.588-mm) ball	100	red	Copper alloys, soft steels, aluminum alloys, malleable iron, etc.
C	diamond	150	black	Steel, hard cast irons, pearlitic malleable iron, titanium, deep case hardened steel, and other materials harder than B100.
A	diamond	60	black	Cemented carbides, thin steel, and shallow case-hardened steel.
D	diamond	100	black	Thin steel and medium case hardened steel, and pearlitic malleable iron.
E	1/8-in. (3.175-mm) ball	100	red	Cast iron, aluminum and magnesium alloys, bearing metals.
F	1/16-in. (1.588-mm) ball	60	red	Annealed copper alloys, thin soft sheet metals.
G	1/16-in. (1.588-mm) ball	150	red	Malleable irons, copper-nickel-zinc and cupro-nickel alloys. Upper limit G92 to avoid possible flattening of ball.
H	1/8-in. (3.175-mm) ball	60	red	Aluminum, zinc, lead.
K	1/8-in. (3.175-mm) ball	150	red	
L	1/4-in. (6.350-mm) ball	60	red	
M	1/4-in. (6.350-mm) ball	100	red	
P	1/4-in. (6.350-mm) ball	150	red	
R	1/2-in. (12.70-mm) ball	60	red	
S	1/2-in. (12.70-mm) ball	100	red	
V	1/2-in. (12.70-mm) ball	150	red	

TABLE 2 Rockwell Superficial Hardness Scales

Total Test Force, kgf (N)	N Scale, Diamond Indenter	T Scale, 1/16-in. (1.588-mm) Ball	W Scale, 1/8-in. (3.175-mm) Ball	X Scale, 1/4-in. (6.350-mm) Ball	Y Scale, 1/2-in. (12.70-mm) Ball
15 (147)	15N	15T	15W	15X	15Y
30 (294)	30N	30T	30W	30X	30Y
45 (441)	45N	45T	45W	45X	45Y

is followed by the letter “W” to indicate the use of a tungsten carbide ball or the letter “S” to indicate the use of a steel ball (see [5.1.2.1](#)).

5.2.3.1 Examples:

64 HRC = Rockwell hardness number of 64 on Rockwell C scale

81 HR30N = Rockwell superficial hardness number of 81 on the Rockwell 30N scale

72 HRBW = Rockwell hardness number of 72 on the Rockwell B scale using a tungsten carbide ball indenter

5.2.4 A reported Rockwell hardness number or the average value of Rockwell hardness measurements shall be rounded in accordance with Practice [E29](#) with a resolution no greater than the resolution of the hardness value display of the testing machine. Typically, the resolution of a Rockwell hardness number should not be greater than 0.1 Rockwell units.

NOTE 2—When the Rockwell hardness test is used for the acceptance testing of commercial products and materials, the user should take into account the potential measurement differences between hardness testing machines allowed by this standard (see Section 10, Precision and Bias). Because of the allowable ranges in the tolerances for the repeatability and error of a testing machine, as specified in the verification requirements of [Annex A1](#), one testing machine may have a test result that is one or more hardness points different than another testing machine, yet both machines can be within verification tolerances (see [Table A1.3](#)). Commonly for acceptance testing, Rockwell hardness values are rounded to whole numbers following Practice [E29](#). Users are encouraged to address rounding practices with regards to acceptance testing within their quality management system, and make any special requirements known during contract review.

5.3 Rockwell Testing Machine—The Rockwell testing machine shall make Rockwell hardness determinations by applying the test forces and measuring the depth of indentation in accordance with the Rockwell hardness test principle.

5.3.1 See the Equipment Manufacturer’s Instruction Manual for a description of the machine’s characteristics, limitations, and respective operating procedures.

5.3.2 The Rockwell testing machine shall automatically convert the depth measurements to a Rockwell hardness number and indicate the hardness number and Rockwell scale by an electronic device or by a mechanical indicator.

5.4 Indenters—The standard Rockwell indenters are either diamond spherocoinal indenter or tungsten carbide balls of 1.588 mm (1/16 in.), 3.175 mm (1/8 in.), 6.350 mm (1/4 in.), or 12.70 mm (1/2 in.) in diameter. Indenters shall meet the requirements defined in [Annex A3](#). Steel ball indenters may be used in certain circumstances (see [5.1.2.1](#)).

5.4.1 Dust, dirt, or other foreign materials shall not be allowed to accumulate on the indenter, as this will affect the test results.

NOTE 3—Indenters certified to revision E18-07 or later meet the requirements of this standard.

5.5 Specimen Support—A specimen support or “anvil” shall be used that is suitable for supporting the specimen to be tested. The seating and supporting surfaces of all anvils shall be clean and smooth and shall be free from pits, deep scratches, and foreign material. Damage to the anvil may occur from testing too thin material or accidental contact of the anvil by the indenter. If the anvil is damaged from any cause, it shall be repaired or replaced. Anvils showing the least visibly perceptible damage may give inaccurate results, particularly on thin material.

5.5.1 Common specimen support anvils should have a minimum hardness of 58 HRC. Some specialty support anvils require a lower material hardness.

5.5.2 Flat pieces should be tested on a flat anvil that has a smooth, flat bearing surface whose plane is perpendicular to the axis of the indenter.

5.5.3 Small diameter cylindrical pieces shall be tested with a hard V-grooved anvil with the axis of the V-groove directly under the indenter, or on hard, parallel, twin cylinders properly positioned and clamped in their base. These types of specimen supports shall support the specimen with the apex of the cylinder directly under the indenter.

5.5.4 For thin materials or specimens that are not perfectly flat, an anvil having an elevated, flat “spot” 3 mm ($\frac{1}{8}$ in.) to 12.5 mm ($\frac{1}{2}$ in.) in diameter should be used. This spot shall be polished smooth and flat. Very soft material should not be tested on the “spot” anvil because the applied force may cause the penetration of the anvil into the under side of the specimen regardless of its thickness.

5.5.5 When testing thin sheet metal with a ball indenter, it is recommended that a diamond spot anvil be used. The highly polished diamond surface shall have a diameter between 4.0 mm (0.157 in.) and 7.0 mm (0.2875 in.) and be centered within 0.5 mm (0.02 in.) of the test point.

5.5.5.1 CAUTION: A diamond spot anvil should only be used with a maximum total test force of 45 kgf (441 N) and a ball indenter. This recommendation should be followed except when directed otherwise by material specification.

5.5.6 Special anvils or fixtures, including clamping fixtures, may be required for testing pieces or parts that cannot be supported by standard anvils. Auxiliary support may be used for testing long pieces with so much overhang that the piece is not firmly seated by the preliminary force.

5.6 *Verification*—Rockwell testing machines shall be verified periodically in accordance with [Annex A1](#).

5.7 *Test Blocks*—Test blocks meeting the requirements of [Annex A4](#) shall be used to verify the testing machine in accordance with [Annex A1](#).

NOTE 4—Test blocks certified to revision E18-07 or later meet the requirements of this standard.

NOTE 5—It is recognized that appropriate standardized test blocks are not available for all geometric shapes, or materials, or both.

6. Test Piece

6.1 For best results, both the test surface and the bottom surface of the test piece should be smooth, even and free from oxide scale, foreign matter, and lubricants. An exception is made for certain materials such as reactive metals that may adhere to the indenter. In such situations, a suitable lubricant such as kerosene may be used. The use of a lubricant shall be defined on the test report.

6.2 Preparation shall be carried out in such a way that any alteration of the surface hardness of the test surface (for example, due to heat or cold-working) is minimized.

6.3 The thickness of the test piece or of the layer under test should be as defined in tables and presented graphically in [Annex A5](#). These tables were determined from studies on strips of carbon steel and have proven to give reliable results. For all other materials, it is recommended that the thickness should exceed 10 times the depth of indentation. In general, no

deformation should be visible on the back of the test piece after the test, although not all such marking is indicative of a bad test.

6.3.1 Special consideration should be made when testing parts that exhibit hardness gradients; for example, parts that were case-hardened by processes such as carburizing, carbonitriding, nitriding, induction, etc. The minimum thickness guidelines given in [Annex A5](#) only apply to materials of uniform hardness, and should not be used to determine the appropriate scale for measuring parts with hardness gradients. The selection of an appropriate Rockwell scale for parts with hardness gradients should be made by special agreement.

NOTE 6—A table listing the minimum effective case depth needed for different Rockwell scales is given in SAE J417.

6.4 When testing on convex cylindrical surfaces, the result may not accurately indicate the true Rockwell hardness; therefore, the corrections given in [Annex A6](#) shall be applied. For diameters between those given in the tables, correction factors may be derived by linear interpolation. Tests performed on diameters smaller than those given in [Annex A6](#) are not acceptable. Corrections for tests on spherical and concave surfaces should be the subject of special agreement.

NOTE 7—A table of correction values to be applied to test results made on spherical surfaces is given in ISO 6508-1.

6.5 When testing small diameter specimens, the accuracy of the test will be seriously affected by alignment between the indenter and the test piece, by surface finish, and by the straightness of the cylinder.

7. Test Procedure

7.1 A daily verification of the testing machine shall be performed in accordance with [A1.5](#) prior to making hardness tests. Hardness measurements shall be made only on the calibrated surface of the test block.

7.2 Rockwell hardness tests should be carried out at ambient temperature within the limits of 10 to 35°C (50 to 95°F). Users of the Rockwell hardness test are cautioned that the temperature of the test material and the temperature of the hardness tester may affect test results. Consequently, users should ensure that the test temperature does not adversely affect the hardness measurement.

7.3 The test piece shall be supported rigidly so that displacement of the test surface is minimized (see [5.5](#)).

7.4 *Test Cycle*—This standard specifies the Rockwell test cycle by stating recommendations or requirements for five separate parts of the cycle. These parts are illustrated for a Rockwell C scale test in [Fig. 2](#), and defined as follows:

(1) *Contact Velocity*, v_A —The velocity of the indenter at the point of contact with the test material.

(2) *Preliminary Force Dwell Time*, t_{PF} —The dwell time beginning when the preliminary force is fully applied and ending when the first baseline depth of indentation is measured, (also see [7.4.1.3](#)).

(3) *Additional Force Application Time*, t_{TA} —The time for applying the additional force to obtain the full total force.

(4) *Total Force Dwell Time*, t_{TF} —The dwell time while the total force is fully applied.




FIG. 2 Schematic of Force-Time Plot (a) and Indenter Depth-Time Plot (b) of an HRC Test Illustrating the Test Cycle Parts

(5) *Dwell Time for Elastic Recovery, t_R* —The dwell time at the preliminary force level, beginning when the additional force is fully removed, and ending when the second and final depth of indentation is measured.

7.4.1 The standard Rockwell test cycle is specified in **Table 3**. The test cycle used for Rockwell hardness tests shall be in accordance with these test cycle values and tolerances (see **Note 8**), with the following exceptions.

7.4.1.1 *Precautions for Materials Having Excessive Time-Dependent Plasticity (Indentation Creep)*—In the case of materials exhibiting excessive plastic flow after application of the total test force, special considerations may be necessary since the indenter will continue to penetrate. When materials require the use of a longer total force dwell time than for the standard test cycle stated in **Table 3**, this should be specified in the product specification. In these cases, the actual extended

total force dwell time used shall be recorded and reported after the test results (for example, 65 HRFW, 10 s).

7.4.1.2 There are testing conditions that may require that the indenter contact velocity exceed the recommended maximum stated in **Table 3**. The user should ensure that the higher contact velocity does not cause a shock or overload which would affect the hardness result. It is recommended that comparison tests be made on the same test material using a test cycle within the requirements stated in **Table 3**.

7.4.1.3 For testing machines that take 1 s or longer to apply the preliminary force t_{PA} , the preliminary force dwell time value t_{PF} shall be adjusted before comparing the parameter with the tolerances of **Table 3** by adding to it one half of t_{PA} as $\frac{t_{PA}}{2} + t_{PF}$. For testing machines that apply the preliminary force t_{PA} in 1 s or less, this adjustment to the preliminary force dwell time value t_{PF} is optional.

NOTE 8—It is recommended that the test cycle to be used with the hardness machine match, as closely as possible, the test cycle used for the indirect verification of the hardness machine. Varying the values of the testing cycle parameters within the tolerances of **Table 3** can produce different hardness results.

7.5 Test Procedure—There are many designs of Rockwell hardness machines, requiring various levels of operator control. Some hardness machines can perform the Rockwell hardness test procedure automatically with almost no operator influence, while other machines require the operator to control most of the test procedure.

7.5.1 Bring the indenter into contact with the test surface in a direction perpendicular to the surface and, if possible, at a velocity within the recommended maximum contact velocity v_A .

7.5.2 Apply the preliminary force F_0 of 10 kgf (98 N) for the Rockwell hardness test or 3 kgf (29 N) for the Rockwell superficial hardness test.

7.5.3 Maintain the preliminary force for the specified preliminary force dwell time t_{PF} .

7.5.4 At the end of the preliminary force dwell time t_{PF} , immediately establish the reference position of the baseline depth of indentation (see manufacturer's Instruction Manual).

7.5.5 Increase the force by the value of the additional test force F_1 needed to obtain the required total test force F for a given hardness scale (see **Tables 1** and **2**). The additional force F_1 shall be applied in a controlled manner within the specified application time range t_{TA} .

7.5.6 Maintain the total force F for the specified total force dwell time t_{TF} .

7.5.7 Remove the additional test force F_1 while maintaining the preliminary test force F_0 .

7.5.8 Maintain the preliminary test force F_0 for an appropriate time to allow elastic recovery in the test material and the stretch of the frame to be factored out.

7.5.9 At the end of the dwell time for elastic recovery, immediately establish the final depth of indentation (see manufacturer's Instruction Manual). The testing machine shall calculate the difference between the final and baseline depth measurements and indicate the resulting Rockwell hardness value. The Rockwell hardness number is derived from the

TABLE 3 Test Cycle Tolerances

Test Cycle Parameter	Tolerance
Indenter contact velocity, v_A (recommended)	$\leq 2.5 \text{ mm/s}$
Dwell time for preliminary force, t_{PF} (when the time to apply the preliminary force $t_{PA} \geq 1 \text{ s}$, then calculate this parameter as $\frac{t_{PA}}{2} + t_{PF}$)	0.1 to 4.0 s
Time for application of additional force, t_{TA}	1.0 to 8.0 s
Dwell time for total force, t_{TF}	2.0 to 6.0 s
Dwell time for elastic recovery, t_R	0.2 to 5.0 s

differential increase in depth of indentation as defined in Eq 4, Eq 5, Eq 6, and Eq 7.

7.6 Throughout the test, the apparatus shall be protected from shock or vibration that could affect the hardness measurement result.

7.7 After each change, or removal and replacement, of the indenter or the anvil, at least two preliminary indentations shall be made to ensure that the indenter and anvil are seated properly. The results of the preliminary indentations shall be disregarded.

7.8 After each change of a test force or removal and replacement of the indenter or the anvil, it is strongly recommended that the operation of the machine be checked in accordance with the daily verification method specified in Annex A1.

7.9 *Indentation Spacing*—The hardness of the material immediately surrounding a previously made indentation will usually increase due to the induced residual stress and work-hardening caused by the indentation process. If a new indentation is made in this affected material, the measured hardness value will likely be higher than the true hardness of the material as a whole. Also, if an indentation is made too close to the edge of the material or very close to a previously made indentation, there may be insufficient material to constrain the deformation zone surrounding the indentation. This can result in an apparent lowering of the hardness value. Both of these circumstances can be avoided by allowing appropriate spacing between indentations and from the edge of the material.

7.9.1 The distance between the centers of two adjacent indentations shall be at least three times the diameter d of the indentation (see Fig. 3).

7.9.2 The distance from the center of any indentation to an edge of the test piece shall be at least two and a half times the diameter of the indentation (see Fig. 3).

8. Conversion to Other Hardness Scales or Tensile Strength Values

8.1 There is no general method of accurately converting the Rockwell hardness numbers on one scale to Rockwell hardness numbers on another scale, or to other types of hardness numbers, or to tensile strength values. Such conversions are, at best, approximations and, therefore, should be avoided except




FIG. 3 Schematic of Minimum Indentation Spacing

for special cases where a reliable basis for the approximate conversion has been obtained by comparison tests.

NOTE 9—The Standard Hardness Conversion Tables for Metals, E140, give approximate conversion values for specific materials such as steel, austenitic stainless steel, nickel and high-nickel alloys, cartridge brass, copper alloys, and alloyed white cast irons. The Rockwell hardness data in the conversion tables of E140 was determined using steel ball indenters.

NOTE 10—ASTM standards giving approximate hardness-tensile strength relationships are listed in Appendix X1.

9. Report

9.1 The test report shall include the following information:

9.1.1 The Rockwell hardness number. All reports of Rockwell hardness numbers shall indicate the scale used. The reported number shall be rounded in accordance with Practice E29 (see 5.2.4 and Note 2),

9.1.2 The total force dwell time, if outside the specified standard test cycle tolerances (see Table 3), and

9.1.3 The ambient temperature at the time of test, if outside the limits of 10 to 35°C (50 to 95°F), unless it has been shown not to affect the measurement result.

10. Precision and Bias^{8, 9}

10.1 *Precision*—A Rockwell hardness precision and bias study was conducted in 2000 in accordance with Practice E691. Tests were performed in the following six Rockwell scales: HRA, HRC, HRBS, HR30N, HR30TS, and HRES. The tests in the HRBS, HR30TS and HRES scales were made using steel ball indenters. A total of 18 Rockwell scale hardness test blocks of the type readily available were used for this study. Test blocks at three different hardness levels (high, medium, and low) in each scale were tested three times each. The results from the first study are filed under ASTM Research Report RR:E28-1021.^{8,9}

10.2 Starting with version E18-05, this standard changed from the use of steel balls to carbide balls for all scales that use a ball indenter. Due to this change, a second study was conducted in 2006. The second study was performed in accordance with Practice E691 and was identical to the initial study except it was limited to the HRBW, HR30TW, and HREW scales, all of which use carbide ball indenters. The results from that study are filed under ASTM Research Report RR:E28-1022.

10.3 A total of 14 different labs participated in the two studies. Eight participated in the first study and nine in the second study. Three labs participated in both studies. The labs chosen to participate in this study were a combination of commercial testing labs (6), in-house labs (5) and test block manufacturer's calibration labs (3). Each lab was instructed to test each block in three specific locations around the surface of the blocks. All testing was to be done according to ASTM E18-05.

10.4 The results given in Table 4 may be useful in interpreting measurement differences. It is a combination of the two

⁸ Supporting data have been filed at ASTM International Headquarters and may be obtained by requesting Research Report RR:E28-1021.

⁹ Supporting data have been filed at ASTM International Headquarters and may be obtained by requesting Research Report RR:E28-1022.

TABLE 4 Results of the Precision and Bias Study

Test Block	Average Hardness	S _r	S _R	r _{PB}	R _{PB}
Data from 2000 study					
62.8 HRA	62.50	0.164	0.538	0.459	1.506
73.1 HRA	73.04	0.138	0.358	0.387	1.002
83.9 HRA	84.54	0.085	0.468	0.238	1.309
25.0 HRC	24.99	0.335	0.440	0.937	1.232
45.0 HRC	45.35	0.156	0.259	0.438	0.725
65.0 HRC	65.78	0.153	0.389	0.427	1.089
45.9 HR30N	46.75	0.299	2.489	0.837	6.969
64.0 HR30N	64.74	0.248	0.651	0.694	1.822
81.9 HR30N	82.52	0.195	0.499	0.547	1.396
Data from 2006 study					
40 HRBW	43.90	0.492	0.668	1.378	1.871
60 HRBW	61.77	0.663	0.697	1.855	1.953
95 HRBW	91.09	0.250	0.292	0.701	0.817
62 HREW	64.07	0.346	0.675	0.970	1.890
81 HREW	81.61	0.232	0.406	0.649	1.136
100 HREW	96.22	0.177	0.322	0.497	0.901
22 HR30TW	18.33	0.702	0.901	1.965	2.522
56 HR30TW	58.0	0.476	0.517	1.333	1.447
79 HR30TW	81.0	0.610	0.851	1.709	2.382

studies. The diamond scales, HRC, HRA, and HR30N are from the first study and the ball scales, HRBW, HREW, and HR30TW are from the second study. This combination reflects the testing that is being done currently.

10.5 The value of r_{PB} indicates the typical amount of variation that can be expected between test results obtained for the same material by the same operator using the same hardness tester on the same day. When comparing two test results made under these conditions, a measurement difference of less than the r_{PB} value for that Rockwell scale is an indication that the results may be equivalent.

10.6 The value of R_{PB} indicates the typical amount of variation that can be expected between test results obtained for

the same material by different operators using different hardness testers on different days. When comparing two test results made under these conditions, a measurement difference of less than the R_{PB} value for that Rockwell scale is an indication that the results may be equivalent.

10.7 Any judgments based on 10.5 and 10.6 would have an approximately 95 % probability of being correct.

10.8 This precision and bias study was conducted on a selected number of the most commonly used Rockwell scales. For Rockwell scales not listed, the r_{PB} and R_{PB} values may be estimated using the conversion tables of E140 to determine a corresponding increment of hardness for the scale of interest at the hardness level of interest. The user is cautioned that estimating the r_{PB} and R_{PB} values in this way, decreases the probability of them being correct.

10.9 Although the precision values given in Table 4 provide guidance on interpreting differences in Rockwell hardness measurement results, a complete evaluation of measurement uncertainty will provide a more definitive interpretation of the results for the specific testing conditions.

10.10 The data generally indicated reasonable precision except for the 45.9 HR30N scale. In that scale the S_R and R_{PB} values are very high compared to all of the other scales. An examination of the raw data reveled that one lab's results were much higher than the others, significantly affecting the overall results in that scale. The results from all of the other scales seem to be reasonable.

10.11 *Bias*—There are no recognized standards by which to fully estimate the bias of this test method.

11. Keywords

hardness; mechanical test; metals; Rockwell

ANNEXES

(Mandatory Information)

A1. VERIFICATION OF ROCKWELL HARDNESS TESTING MACHINES

A1.1 Scope

A1.1.1 Annex A1 specifies three types of procedures for verifying Rockwell hardness testing machines: *direct verification*, *indirect verification*, and *daily verification*.

A1.1.2 Direct verification is a process for verifying that critical components of the hardness testing machine are within allowable tolerances by directly measuring the test forces, depth measuring system, machine hysteresis, and testing cycle.

A1.1.3 Indirect verification is a process for periodically verifying the performance of the testing machine by means of standardized test blocks and indenters.

A1.1.4 The daily verification is a process for monitoring the performance of the testing machine between indirect verifications by means of standardized test blocks.

A1.1.5 Adherence to this standard and annex provides traceability to national standards, except as stated otherwise.

A1.2 General Requirements

A1.2.1 The testing machine shall be verified at specific instances and at periodic intervals as specified in Table A1.1, and when circumstances occur that may affect the performance of the testing machine.

A1.2.2 The temperature at the verification site shall be measured with an instrument having an accuracy of at least $\pm 2.0^{\circ}\text{C}$ or $\pm 3.6^{\circ}\text{F}$. It is recommended that the temperature be monitored throughout the verification period, and significant temperature variations be recorded and reported. The temperature at the verification site does not need to be measured for a

TABLE A1.1 Verification Schedule for a Rockwell Testing Machine

Verification Procedure	Schedule
Direct verification	When a testing machine is new, or when adjustments, modifications or repairs are made that could affect the application of the test forces, the depth measuring system, or the machine hysteresis. When a testing machine fails an indirect verification (see A1.4.9.4).
Indirect verification	Recommended every 12 months, or more often if needed. Shall be no longer than every 18 months. When a testing machine is installed or moved, [only a partial indirect verification is performed by following the procedure given in A1.4.7 for verifying the as-found condition]. This does not apply to machines that are designed to be moved or that move prior to each test, when it has been previously demonstrated that such a move will not affect the hardness result. Following a direct verification. To qualify an indenter that was not verified in the last indirect verification, (only a partial indirect verification is performed, see A1.4.10).
Daily verification	Required each day that hardness tests are to be made. Recommended whenever the indenter, anvil, or test force is changed.

daily verification or when qualifying additional user's indenters in accordance with A1.4.10.

A1.2.3 All instruments used to make measurements required by this Annex shall be calibrated traceable to national standards when a system of traceability exists, except as noted otherwise.

A1.2.4 Direct verification of newly manufactured or rebuilt testing machines shall be performed at the place of manufacture, rebuild or repair. Direct verification may also be performed at the location of use.

A1.2.5 Indirect verification of the testing machine shall be performed at the location where it will be used.

NOTE A1.1—It is recommended that the calibration agency that is used to conduct the verifications of Rockwell hardness testing machines be accredited to the requirements of ISO 17025 (or an equivalent) by an accrediting body recognized by the International Laboratory Accreditation Cooperation (ILAC) as operating to the requirements of ISO/IEC 17011.

A1.3 Direct Verification

A1.3.1 A direct verification of the testing machine shall be performed at specific instances in accordance with Table A1.1. The test forces, depth-measuring system, machine hysteresis, and testing cycle shall be verified as follows.

NOTE A1.2—Direct verification is a useful tool for determining the sources of error in a Rockwell hardness testing machine. It is recommended that testing machines undergo direct verification periodically to make certain that errors in one component of the machine are not being offset by errors in another component.

A1.3.2 *Verification of the Test Forces*—For each Rockwell scale that will be used, the corresponding test forces (preliminary test force at loading, total test force, and preliminary test force during elastic recovery) shall be measured. The test forces shall be measured by means of a Class A elastic force measuring instrument having an accuracy of at least 0.25 %, as described in ASTM E74.

A1.3.2.1 Make three measurements of each force. The forces shall be measured as they are applied during testing.

A1.3.2.2 Each preliminary test force F_0 and each total test force F shall be accurate to within the tolerances given in Table A1.2, and the range of the three force measurements (highest minus lowest) shall be within 75 % of the tolerances of Table A1.2.

A1.3.3 Verification of the Depth Measuring System—The depth measuring system shall be verified by means of an instrument, device or standard having an accuracy of at least 0.0002 mm.

A1.3.3.1 Verify the testing machine's depth measurement system at not less than four evenly spaced increments covering the full range of the normal working depth measured by the testing machine. The normal working depth range shall correspond to the lowest and highest hardness values for the Rockwell scales that will be tested.

A1.3.3.2 The indentation-depth measuring device shall be accurate within ± 0.001 mm for the regular Rockwell hardness scales and ± 0.0005 mm for the Rockwell superficial hardness scales. These accuracies correspond to 0.5 hardness units.

A1.3.3.3 Some testing machines have a long-stroke depth measuring system where the location of the working range of the depth measuring system varies depending on the thickness of the test material. This type of testing machine shall have a system to electronically verify that the depth measuring device is continuous over its full range and free from dirt or other discontinuities that could affect its accuracy. These types of testers shall be verified using the following steps.

(1) At the approximate top, mid point, and bottom of the total stroke of the measuring device, verify the accuracy of the device at no less than four evenly spaced increments of approximately 0.05 mm at each of the three locations. The accuracy shall be within the tolerances defined above.

(2) Operate the actuator over its full range of travel and monitor the electronic continuity detection system. The system shall indicate continuity over the full range.

A1.3.4 Verification of Machine Hysteresis—Each time a Rockwell hardness test is made, the testing machine will undergo flexure in some of the machine components and the machine frame. If the flexure is not entirely elastic during the application and removal of the additional force F_1 , the testing machine may exhibit hysteresis in the indenter-depth measurement system, resulting in an offset or bias in the test result. The goal of the hysteresis verification is to perform a purely elastic

TABLE A1.2 Tolerances on Applied Force for a Rockwell Testing Machine

Force		Tolerance	
kgf	N	kgf	N
10	98.07	0.20	1.96
60	588.4	0.45	4.41
100	980.7	0.65	6.37
150	1471	0.90	8.83
3	29.42	0.060	0.589
15	147.1	0.100	0.981
30	294.2	0.200	1.961
45	441.3	0.300	2.963

test that results in no permanent indentation. In this way, the level of hysteresis in the flexure of the testing machine can be determined.

A1.3.4.1 Perform repeated Rockwell tests using a blunt indenter (or the indenter holder surface) acting directly onto the anvil or a very hard test piece. The tests shall be conducted using the highest test force that is used during normal testing

A1.3.4.2 Repeat the hysteresis verification procedure for a maximum of ten measurements and average the last three tests. The average measurement shall indicate a hardness number of 130 ± 1.0 Rockwell units when Rockwell ball scales B, E, F, G, H and K are used, or within 100 ± 1.0 Rockwell units when any other Rockwell scale is used.

A1.3.5 *Verification of the Testing Cycle*—Section 7 specifies the Rockwell testing cycle by stating requirements and recommendations for five separate parameters of the cycle. The testing machine shall be verified to be capable of meeting the tolerances specified in Table 3 for the following four test cycle parameters: the dwell time for preliminary force, the time for application of additional force, the dwell time for total force and the dwell time for elastic recovery. The tolerance for the indenter contact velocity is a recommendation. Direct verification of the testing cycle is to be verified by the testing machine manufacturer at the time of manufacture, and when the testing machine is returned to the manufacturer for repair when a problem with the testing cycle is suspected. Verification of the testing cycle is not required as part of the direct verification at other times.

A1.3.5.1 Rockwell hardness testing machines manufactured before the implementation of E18–07 may not have undergone the direct verification of the machine’s testing cycle. Since this verification often must be performed at the manufacturer’s site, the test cycle verification requirement does not apply to testing machines manufactured before the implementation of E18–07, unless the testing machine is returned to the manufacturer for repair.

A1.3.6 *Direct Verification Failure*—If any of the direct verifications fail the specified requirements, the testing machine shall not be used until it is adjusted or repaired. If the test forces, depth measuring system, machine hysteresis, or testing cycle may have been affected by an adjustment or repair, the affected components shall be verified again by direct verification.

A1.3.7 An indirect verification shall follow a successful direct verification.

A1.4 Indirect Verification

A1.4.1 An indirect verification of the testing machine shall be performed, at a minimum, in accordance with the schedule given in Table A1.1. The frequency of indirect verifications should be based on the usage of the testing machine.

A1.4.2 The testing machine shall be verified for each Rockwell scale that will be used prior to the next indirect verification. Hardness tests made using Rockwell scales that have not been verified within the schedule given in Table A1.1 do not meet this standard.

A1.4.3 Standardized test blocks meeting the requirements of Annex A4 (see Note 4) shall be used in the appropriate hardness ranges for each scale to be verified. These ranges are given in Table A1.3. Hardness measurements shall be made only on the calibrated surface of the test block.

A1.4.4 The indenters to be used for the indirect verification shall meet the requirements of Annex A3 (see Note 3).

A1.4.5 The testing cycle to be used for the indirect verification shall be the same as is typically used by the user.

A1.4.6 Prior to performing the indirect verification, ensure that the testing machine is working freely, and that the indenter and anvil are seated adequately. Make at least two hardness measurements on a suitable test piece to seat the indenter and anvil. The results of these measurements need not be recorded.

A1.4.7 As-found Condition:

A1.4.7.1 It is recommended that the as-found condition of the testing machine be assessed as part of an indirect verification. This is important for documenting the historical performance of the machine in the scales used since the last indirect verification. This procedure should be conducted prior to any cleaning, maintenance, adjustments, or repairs.

A1.4.7.2 When the as-found condition of the testing machine is assessed, it shall be determined with the user’s indenter(s) that are normally used with the testing machine. At least two standardized test blocks, each from a different hardness range as defined in Table A1.3, should be tested for each Rockwell scale that will undergo indirect verification. The difference in hardness between any of the standardized test blocks shall be at least 5 hardness points for each Rockwell scale.

A1.4.7.3 On each standardized test block, make at least two measurements distributed uniformly over the test surface.

A1.4.7.4 Determine the repeatability R and the error E (Eq 2 and Eq 3) in the performance of the testing machine for each standardized test block that is measured.

A1.4.7.5 The error E and the repeatability R should be within the tolerances of Table A1.3. If the calculated values of error E or repeatability R fall outside of the specified tolerances, this is an indication that the hardness tests made since the last indirect verification may be suspect.

A1.4.8 *Cleaning and Maintenance*—Perform cleaning and routine maintenance of the testing machine (when required) in accordance with the manufacturer’s specifications and instructions.

A1.4.9 *Indirect Verification Procedure*—The indirect verification procedure requires that the testing machine be verified using one or more of the user’s indenters.

A1.4.9.1 One standardized test block shall be tested from each of the hardness ranges (usually three ranges) for each Rockwell scale to be verified, as given in Table A1.3. The difference in hardness between any of the standardized test blocks shall be at least 5 hardness points for each Rockwell scale. The user may find that high, medium and low range test blocks are unavailable commercially for some scales. In these cases, one of the following two procedures shall be followed.

TABLE A1.3 Maximum Allowable Repeatability and Error of Testing Machines for Ranges of Standardized Test Blocks

Range of Standardized Test Blocks ^A		Maximum Repeatability, <i>R</i> (HR units)	Maximum Error, <i>E</i> (HR units)
HRA	< 70	2.0	± 1.0
	≥ 70 and < 80	1.5	± 1.0
HRBW	≥ 80	1.0	± 0.5
	< 60	2.0	± 1.5
	≥ 60 and < 80	1.5	± 1.0
HRC	≥ 80	1.5	± 1.0
	< 35	2.0	± 1.0
	≥ 35 and < 60	1.5	± 1.0
HRD	≥ 60	1.0	± 0.5
	< 51	2.0	± 1.0
	≥ 51 and < 71	1.5	± 1.0
HREW	≥ 71	1.0	± 0.5
	< 84	1.5	± 1.0
	≥ 84 and < 93	1.5	± 1.0
HRFW	≥ 93	1.0	± 1.0
	< 80	1.5	± 1.0
	≥ 80 and < 94	1.5	± 1.0
HRGW	≥ 94	1.0	± 1.0
	< 55	2.0	± 1.0
	≥ 55 and < 80	2.0	± 1.0
HRHW	≥ 80	2.0	± 1.0
	< 96	2.0	± 1.0
	≥ 96	2.0	± 1.0
HRKW	< 65	1.5	± 1.0
	≥ 65 and < 85	1.0	± 1.0
	≥ 85	1.0	± 1.0
HRLW ^B		2.0	± 1.0
HRMW ^B		2.0	± 1.0
HRPW ^B		2.0	± 1.0
HRRW ^B		2.0	± 1.0
HRSW ^B		2.0	± 1.0
HRVW ^B		2.0	± 1.0
HR15N	< 78	2.0	± 1.0
	≥ 78 and < 90	1.5	± 1.0
	≥ 90	1.0	± 0.7
HR30N	< 55	2.0	± 1.0
	≥ 55 and < 77	1.5	± 1.0
	≥ 77	1.0	± 0.7
HR45N	< 37	2.0	± 1.0
	≥ 37 and < 66	1.5	± 1.0
	≥ 66	1.0	± 0.7
HR15TW	< 81	2.0	± 1.5
	≥ 81 and < 87	1.5	± 1.0
	≥ 87	1.5	± 1.0
HR30TW	< 57	2.0	± 1.5
	≥ 57 and < 70	1.5	± 1.0
	≥ 70	1.5	± 1.0
HR45TW	< 33	2.0	± 1.5
	≥ 33 and < 53	1.5	± 1.0
	≥ 53	1.5	± 1.0
HR15WW ^B		2.0	± 1.0
HR30WW ^B		2.0	± 1.0
HR45WW ^B		2.0	± 1.0
HR15XW ^B		2.0	± 1.0
HR30XW ^B		2.0	± 1.0
HR45XW ^B		2.0	± 1.0
HR15YW ^B		2.0	± 1.0
HR30YW ^B		2.0	± 1.0
HR45YW ^B		2.0	± 1.0

^A The user may find that high, medium and low range test blocks are unavailable commercially for some scales. In these cases one or two standardized blocks where available may be used. It is recommended that all high range test blocks for Rockwell scales using a ball indenter should be less than 100 HR units.

^B Appropriate ranges of standardized test blocks for the L, M, P, R, S, V, W, X, and Y scales shall be determined by dividing the usable range of the scale into two ranges, if possible.

(1) *Alternative Procedure 1*—The testing machine shall be verified using the standardized blocks from the one or two ranges that are available. Also, the testing machine shall be

verified on another Rockwell scale which uses the same test forces and for which three blocks are available. In this case, the testing machine is considered verified for the entire Rockwell scale.

(2) *Alternative Procedure 2*—This procedure may be used when standardized blocks from two ranges are available. The testing machine shall be verified using the standardized blocks from the two available ranges. In this case, the testing machine is considered verified for only the part of the scale bracketed by the levels of the blocks.

A1.4.9.2 On each standardized test block, make five measurements distributed uniformly over the test surface. Determine the error *E* and the repeatability *R* in the performance of the testing machine using Eq 2 and Eq 3 for each hardness level of each Rockwell scale to be verified.

A1.4.9.3 The error *E* and the repeatability *R* shall be within the tolerances of Table A1.3. The indirect verification shall be approved only when the testing machine measurements of repeatability and error meet the specified tolerances using at least one of the user's indenters.

A1.4.9.4 In the case that the testing machine cannot pass the repeatability and error verifications with the user's indenter, a number of corrective actions may be attempted to bring the testing machine within tolerances. These actions include cleaning and maintenance, replacing the anvil or using another of the user's indenters. The indirect verification procedures shall be repeated after making the allowed corrective actions.

NOTE A1.3—When a testing machine fails indirect verification, it is recommended that the testing machine be verified again using a Class A (or better) indenter for those scales and hardness levels that failed the indirect verification with the user's indenter. If the testing machine passes the repeatability and error tests with a Class A indenter, it is an indication that the user's indenter is out of tolerance. A new indenter may be acquired by the user as a corrective action (see A1.4.9.4) allowing the indirect verification procedures to be repeated without having to perform a direct verification. If the testing machine continues to fail the repeatability or error tests of an indirect verification with the Class A indenter, it is an indication that there is a problem with the machine and not the user's indenter.

A1.4.9.5 If the testing machine continues to fail the repeatability or error tests following corrective actions, the testing machine shall undergo adjustment and/or repair followed by a direct verification.

A1.4.10 *Qualifying Additional User's Indenters*—In cases where the testing machine passes indirect verification using only one of the user's indenters, only that one indenter is considered verified for use with the specific testing machine for the Rockwell scales that were indirectly verified using that indenter. Before any other indenter may be used for testing the same Rockwell scales, it must be verified for use with the specific verified testing machine. This requirement does not apply to changing an indenter ball. The indenter verifications may be made at any time after the indirect verification, and may be performed by the user as follows.

A1.4.10.1 The testing machine and indenter shall be verified together using the indirect verification procedures of A1.4.9 with the following exception. The verification shall be performed on at least two standardized test blocks (high and low ranges) for each Rockwell scale that the indenter will be used.

A1.4.10.2 The indenter may be used with the specific verified testing machine only when the verification measurements of repeatability and error meet the specified tolerances.

A1.4.11 The user shall identify and keep track of the indenters verified for use with the testing machine.

A1.5 Daily Verification

A1.5.1 The daily verification is intended for the user to monitor the performance of the testing machine between indirect verifications. At a minimum, the daily verification shall be performed in accordance with the schedule given in **Table A1.1** for each Rockwell scale that will be used.

A1.5.2 It is recommended that the daily verification procedures be performed whenever the indenter, anvil, or test force is changed.

A1.5.3 *Daily Verification Procedures*—The procedures to use when performing a daily verification are as follows.

A1.5.3.1 Daily verification shall use standardized test block(s) that meet the requirements of **Annex A4** (see **Note 4**). Daily verification shall be done for each Rockwell scale that is to be used that day. At least one test block shall be used, and when commercially available, the hardness range of the test block shall be chosen to be within 15 Rockwell points of the hardness value that the testing machine is expected to measure. Alternatively, two test blocks can be used, (when commercially available), one higher and one lower than the hardness range that the testing machine is expected to measure. In cases where the configuration of the anvil to be used is not suitable for the testing of blocks, a suitable anvil or adapter for testing a test block must be used temporarily.

A1.5.3.2 The indenter to be used for the daily verification shall be the indenter that is normally used for testing.

A1.5.3.3 Before performing the daily verification tests, ensure that the testing machine is working freely, and that the indenter and anvil are seated adequately. Make at least two hardness measurements on a suitable test piece. The results of these measurements need not be recorded.

A1.5.3.4 Make at least two hardness measurements on each of the daily verification test blocks adhering to the spacing requirements given in **7.9**.

A1.5.3.5 For each test block, calculate the error E (see **Eq 2**) and the repeatability R (see **Eq 3**) from the measured hardness values. The testing machine with the indenter is regarded as performing satisfactorily if both E and R for all test blocks are within the maximum tolerances given in **Table A1.3**. Note that if the differences between the individual hardness values and the certified value for a test block are all within the maximum error E tolerances marked on the test block and given in **Table A1.3**, the above criteria will be met for that block and it is not necessary to calculate E and R .

A1.5.3.6 If the daily verification measurements for any of the test blocks do not meet the criteria of **A1.5.3.5**, the daily verification may be repeated with a different indenter or after cleaning the tester, or both (see the manufacturer's instructions). If any of the test block measurements continue to not meet the criteria of **A1.5.3.5**, an indirect verification shall be performed. Whenever a testing machine fails a daily

verification, the hardness tests made since the last valid daily verification may be suspect.

A1.5.3.7 If the anvil to be used for testing is different than the anvil used for the daily verification, it is recommended that the daily verification be repeated on an appropriate part of known hardness.

NOTE A1.4—It is highly recommended that the results obtained from the daily verification testing be recorded using accepted Statistical Process Control techniques, such as, but not limited to, X-bar (measurement averages) and R-charts (measurement ranges), and histograms.

A1.6 Verification Report

A1.6.1 The verification report shall include the following information as a result of the type of verification performed.

A1.6.2 Direct Verification:

A1.6.2.1 Reference to this ASTM test method.

A1.6.2.2 Identification of the hardness testing machine, including the serial number, manufacturer and model number.

A1.6.2.3 Identification of all devices (elastic proving devices, etc.) used for the verification, including serial numbers and identification of standards to which traceability is made.

A1.6.2.4 Test temperature at the time of verification (see **A1.2.2**).

A1.6.2.5 The individual measurement values and calculated results used to determine whether the testing machine meets the requirements of the verification performed. It is recommended that the uncertainty in the calculated results used to determine whether the testing machine meets the requirements of the verification performed also be reported.

A1.6.2.6 Description of adjustments or maintenance done to the testing machine, when applicable.

A1.6.2.7 Date of verification and reference to the verifying agency or department.

A1.6.2.8 Signature of the person performing the verification.

A1.6.3 Indirect Verification:

A1.6.3.1 Reference to this ASTM test method.

A1.6.3.2 Identification of the hardness testing machine, including the serial number, manufacturer and model number.

A1.6.3.3 Identification of all devices (test blocks, indenters, etc.) used for the verification, including serial numbers and identification of standards to which traceability is made.

A1.6.3.4 Test temperature at the time of verification (see **A1.2.2**).

A1.6.3.5 The Rockwell hardness scale(s) verified.

A1.6.3.6 The individual measurement values and calculated results used to determine whether the testing machine meets the requirements of the verification performed. Measurements made to determine the as-found condition of the testing machine shall be included whenever they are made. It is recommended that the uncertainty in the calculated results used to determine whether the testing machine meets the requirements of the verification performed also be reported.

A1.6.3.7 Description of maintenance done to the testing machine, when applicable.

A1.6.3.8 Date of verification and reference to the verifying agency or department.

A1.6.3.9 Signature of the person performing the verification.

A1.6.4 Daily Verification:

A1.6.4.1 No verification report is required; however, it is recommended that records be kept of the daily verification

results, including the verification date, measurement results, certified value of the test block, test block identification, and the name of the person that performed the verification, etc. (see also **Note A1.4**). These records can be used to evaluate the performance of the hardness machine over time.

A2. ROCKWELL HARDNESS STANDARDIZING MACHINES

A2.1 Scope

A2.1.1 **Annex A2** specifies the requirements for the capabilities, usage, periodic verification, and monitoring of a Rockwell hardness standardizing machine. The Rockwell hardness standardizing machine differs from a Rockwell hardness testing machine by having tighter tolerances on certain performance attributes such as force application and machine hysteresis. A Rockwell standardizing machine is used for the standardization of Rockwell hardness indenters as described in **Annex A3**, and for the standardization of Rockwell test blocks as described in **Annex A4**.

A2.1.2 Adherence to this standard and annex provide traceability to national standards, except as stated otherwise.

A2.2 Accreditation

A2.2.1 The agency conducting direct and/or indirect verifications of Rockwell hardness standardizing machines shall be accredited to the requirements of ISO 17025 (or an equivalent) by an accrediting body recognized by the International Laboratory Accreditation Cooperation (ILAC) as operating to the requirements of ISO/IEC 17011. An agency accredited to perform verifications of Rockwell hardness standardizing machines may perform the verifications of its own standardizing machines. The standardizing laboratory shall have a certificate/scope of accreditation stating the types of verifications (direct and/or indirect) and the Rockwell scales that are covered by the accreditation.

NOTE A2.1—Accreditation is a new requirement starting with this edition of the standard.

A2.3 Apparatus

A2.3.1 The standardizing machine shall satisfy the requirements of Section 5 for a Rockwell hardness testing machine with the following additional requirements.

A2.3.1.1 The standardizing machine shall be designed so that: (1) each test force can be selected by the operator, and (2) adjustments to test forces cannot be made by the operator.

A2.3.1.2 The system for displaying the hardness measurement value shall be digital with a resolution of 0.1 Rockwell units or better.

A2.3.1.3 Deviation in parallelism between the indenter mounting surface and the anvil mounting surface shall not be greater than 0.002 mm/mm (0.002 in./in.). This characteristic of the standardizing machine is not likely to vary with time. As such, the accuracy of this dimension shall only be certified by

the machine manufacturer and need not be periodically verified by direct verification unless the components have been changed.

A2.3.1.4 *Indenters*—Class A ball indenters and Class A or Reference diamond indenters as described in **Annex A3** (see **Note 3**) shall be used.

A2.3.1.5 *Testing Cycle*—The standardizing machine shall be capable of meeting each part of the testing cycle within the tolerances specified in **Table A2.1**. The manufacturer of the standardizing machine shall verify each of the five components of the testing cycle at the time of manufacture, or when the testing machine is returned to the manufacturer for repair.

A2.3.1.6 It is important that the final portion of the additional force application be controlled. Two recommended procedures for properly applying the additional force are as follows: (1) the average indenter velocity v_F (see **Fig. 2**) during the final 40 % of additional force application should be between 0.020 mm/s and 0.040 mm/s, or (2) the amount of force applied during the final 10 % of the additional force application time should be less than 5 % of the additional force.

A2.3.1.7 During the period between verifications, no adjustments may be made to the force application system, the force measurement system, the indenter depth measurement system, or the test cycle that is used for each Rockwell scale.

A2.4 Laboratory Environment

A2.4.1 The standardizing machine shall be located in a temperature and relative-humidity controlled room with tolerances for these conditions given in **Table A2.2**. The accuracy of the temperature and relative-humidity measuring instruments shall be as given in **Table A2.2**. The display of the temperature measuring device shall have a resolution of at least 1 °C.

A2.4.2 The temperature and relative-humidity of the standardizing laboratory shall be monitored beginning at least one hour prior to standardization and throughout the standardizing procedure.

TABLE A2.1 Testing Cycle Requirements

Test Cycle Parameter	Tolerance
Indenter contact velocity, v_A	$\leq 1.0 \text{ mm/s}$
Dwell time for preliminary force, t_{PF} (when the time to apply the preliminary force $t_{PA} \geq 1 \text{ s}$, then calculate this parameter as $\frac{t_{PA} + t_{PF}}{2}$)	$3.0 \pm 1.0 \text{ s}$
Additional force application, t_{TA} (see A2.3.1.6)	1.0 to 8.0 s
Dwell time for total force, t_{TF}	$5.0 \pm 1.0 \text{ s}$
Dwell time for elastic recovery, t_R	$4.0 \pm 1.0 \text{ s}$

TABLE A2.2 Standardization Laboratory Environmental Requirements

Environmental Parameter	Tolerance	Accuracy of Measuring Instrument
Temperature	$23.0 \pm 3.0^{\circ}\text{C}$ ($73.4 \pm 5.4^{\circ}\text{F}$)	$\pm 1.0^{\circ}\text{C}$ (1.8°F)
Relative humidity	$\leq 70\%$	$\pm 10\%$

A2.4.3 The standardizing machine, indenter(s), and test blocks to be standardized must be in an environment meeting the tolerances of **Table A2.2** for at least one hour prior to standardization.

A2.4.4 During the standardization process, the standardizing machine shall be isolated from any vibration that may affect the measurements.

A2.4.5 The power supply to the standardizing machine shall be isolated from any electrical surges that could affect its performance.

A2.5 Verifications

A2.5.1 The standardizing machine shall undergo direct and indirect verifications at periodic intervals and when circumstances occur that may affect the performance of the standardizing machine, according to the schedule given in **Table A2.3**.

NOTE A2.2—Periodic direct verification (every 12 months) is a new requirement starting with this edition of the standard. In previous editions of this standard, direct verification was required only when a standardizing machine was new, moved, or when adjustments, modifications or repairs were made that could affect the application of the test forces, the depth measuring system, or the machine hysteresis.

A2.5.2 A standardizing machine used for the standardization of test blocks shall undergo monitoring verifications each day that standardizations are made, according to the schedule given in **Table A2.3**.

A2.5.3 All instruments used to make measurements required by this Annex shall be calibrated traceable to national standards where a system of traceability exists, except as noted otherwise.

A2.5.4 The standardizing machine shall be directly and indirectly verified at the location where it will be used.

TABLE A2.3 Verification Schedule for a Rockwell Hardness Standardizing Machine

Verification Procedure	Schedule
Direct verification	Shall be every 12 months. When a standardizing machine is new, moved, or when adjustments, modifications or repairs are made that could affect the application of the test forces, the depth measuring system, or the machine hysteresis.
Indirect verification	Shall be within 12 months prior to standardization testing. Following a direct verification(limited number of scales).
Monitoring verification	Shall be before and after each lot is standardized, and at the end of each day and the start of the following day when a single lot is standardized over multiple days.

A2.6 Periodic Verification Procedures

A2.6.1 *Perform Cleaning and Maintenance*—If required, cleaning and routine maintenance of the standardizing machine shall be made before conducting direct or indirect verifications in accordance with the manufacturer's specifications and instructions.

A2.6.2 *Direct Verification*—Perform a direct verification of the standardizing machine in accordance with the schedule given in **Table A2.3**. The test forces, depth measuring system, and machine hysteresis shall be verified.

A2.6.2.1 *Verification of the Test Forces*—For each Rockwell scale that will be used, the associated forces (preliminary test force, total test force, and test force during elastic recovery) shall be measured. The test forces shall be measured by means of a Class AA elastic force measuring instrument having an accuracy of at least 0.05 %, as described in ASTM E74.

A2.6.2.2 Make three measurements of each force. The forces shall be measured as they are applied during testing.

A2.6.2.3 Each preliminary test force F_0 and each total test force F shall be accurate to within 0.25 % in accordance with **Table A2.4**.

A2.6.2.4 *Verification of the Depth Measuring System*—The depth measuring system shall be verified by means of an instrument having an accuracy of at least 0.0001 mm.

A2.6.2.5 Verify the standardizing machine's measurement of depth at not less than four evenly spaced increments of approximately 0.05 mm at the range of the normal working depth of the standardizing machine. The normal working depth range shall correspond to the lowest and highest hardness values for the Rockwell scales that will be standardized or that will be used for indenter calibrations.

A2.6.2.6 For testing machines with long stroke actuators and fixed anvils, the depth measurement verification shall be repeated at positions corresponding to each thickness of test block that will be standardized or that will be used for indenter calibrations.

A2.6.2.7 The indentation depth measuring device shall have an accuracy of at least 0.0002 mm over the normal working depth range which corresponds to 0.1 regular Rockwell hardness units and 0.2 Rockwell Superficial hardness units.

A2.6.2.8 *Verification of Machine Hysteresis*—Most Rockwell hardness machines will undergo flexure in the machine frame and some machine components each time a test is made. If the flexure is not entirely elastic during the application and removal of the additional force F_1 , the testing machine may exhibit hysteresis in the indenter depth measuring system, resulting in an offset or bias in the test result. The goal of the

TABLE A2.4 Tolerances on Applied Force for the Standardizing Machine

Force, kgf (N)	Tolerance, kgf (N)
10 (98.07)	0.025 (0.245)
60 (588.4)	0.150 (1.471)
100 (980.7)	0.250 (2.452)
150 (1471)	0.375 (3.678)
3 (29.42)	0.008 (0.074)
15 (147.1)	0.038 (0.368)
30 (294.2)	0.075 (0.736)
45 (441.3)	0.113 (1.103)

hysteresis verification is to perform a purely elastic test that results in no permanent indentation. In this way, the level of hysteresis in the flexure of the testing machine can be determined.

A2.6.2.9 Perform repeated Rockwell tests using a blunt indenter (or the indenter holder surface) acting directly onto the anvil or a very hard test piece. The tests shall be conducted on a Rockwell scale having the highest test force that is used for normal standardizations.

A2.6.2.10 Repeat the hysteresis tests for a maximum of ten measurements and average the last three tests. The average measurement shall indicate a hardness number within 130 ± 0.3 Rockwell units when Rockwell ball scales B, E, F, G, H and K are used, or within 100 ± 0.3 Rockwell units when any other Rockwell scale is used.

A2.6.2.11 *Direct Verification Failure*—If any of the direct verifications fail the specified requirements, the standardizing machine shall not be used until it is adjusted or repaired. Any parameter that may have been affected by an adjustment or repair shall be verified again by direct verification.

A2.6.3 *Indirect Verification*—Indirect verification involves verifying the performance of the standardizing machine by means of standardized test blocks and indenters. Prior to performing standardizations for any Rockwell scale, an indirect verification of the standardizing machine for that scale shall be made within the time period given in Table A2.3. A selected number of Rockwell scales shall be indirectly verified at the time of the direct verification as described below. The indirect verification of all other Rockwell scales may be made at any time as long as it occurs within the time period given in Table A2.3 prior to standardization.

A2.6.3.1 Immediately following the direct verification, indirect verifications of a selected number of scales shall be performed to determine the performance of the standardizing machine at each force level that the standardizing machine is capable of applying. An example of an indirect verification for a standardizing machine capable of applying all force levels is given in Table A2.5. It is recommended that Rockwell scales be chosen that will also verify each indenter that will be used. When national primary standardized test blocks (see Note A2.3) are available, they should be used for the periodic indirect verification.

NOTE A2.3—Primary standardized test blocks are certified at the national standardizing laboratory level. In the United States, the national Rockwell hardness standardizing laboratory is the National Institute of Standards and Technology (NIST), Gaithersburg, MD 20899.

TABLE A2.5 Suggested Rockwell Scales for the Indirect Verification of Machines Capable of Performing Both Regular and Superficial Scale Tests and that Will Use Only Diamond and 1/16 in. (1.588 mm) Diameter Carbide Ball Indenters

Preliminary Force kgf (N)	Total Force kgf (N)	Indenter Type	Rockwell Scale
10 (98.07)	60 (588.4)	diamond	HRA
10 (98.07)	100 (980.7)	1/16 in. ball	HRB
10 (98.07)	150 (1471)	diamond	HRC
3 (29.42)	15 (147.1)	diamond	HR15N
3 (29.42)	30 (294.2)	1/16 in. ball	HR30T
3 (29.42)	45 (441.3)	diamond	HR45N

A2.6.3.2 Standardized test blocks shall be used in the appropriate hardness ranges for each scale to be verified. These ranges are given in Table A2.6. The standardizing testing machine shall not be adjusted during the indirect verification procedures.

TABLE A2.6 Maximum Allowable Repeatability and Error of Standardizing Machines

	Range of Standardized Test Blocks	Maximum Repeatability, <i>R</i> (HR units)	Maximum Error, <i>E</i> (HR units)
HRA	20 to 65	1.0	± 0.5
	70 to 78	0.7	± 0.5
	80 to 84	0.5	± 0.3
HRBW	40 to 59	1.0	± 0.7
	60 to 79	0.7	± 0.5
	80 to 100	0.7	± 0.5
HRC	20 to 30	1.0	± 0.5
	35 to 55	0.7	± 0.5
	60 to 65	0.5	± 0.3
HRD	40 to 48	1.0	± 0.5
	51 to 67	0.7	± 0.5
	71 to 75	0.5	± 0.3
HREW	70 to 79	0.7	± 0.5
	84 to 90	0.7	± 0.5
	93 to 100	0.5	± 0.5
HRFW	60 to 75	0.7	± 0.5
	80 to 90	0.7	± 0.5
	94 to 100	0.5	± 0.5
HRGW	30 to 50	1.0	± 0.5
	55 to 75	1.0	± 0.5
	80 to 94	1.0	± 0.5
HRHW	80 to 94	1.0	± 0.5
	96 to 100	1.0	± 0.5
HRKW	40 to 60	0.7	± 0.5
	65 to 80	0.5	± 0.5
	85 to 100	0.5	± 0.5
HRLW ^A		1.0	± 0.5
HRMW ^A		1.0	± 0.5
HRPW ^A		1.0	± 0.5
HRRW ^A		1.0	± 0.5
HRSW ^A		1.0	± 0.5
HRVW ^A		1.0	± 0.5
HR15N	70 to 77	1.0	± 0.5
	78 to 88	0.7	± 0.5
	90 to 92	0.5	± 0.4
HR30N	42 to 50	1.0	± 0.5
	55 to 73	0.7	± 0.5
	77 to 82	0.5	± 0.4
HR45N	20 to 31	1.0	± 0.5
	37 to 61	0.7	± 0.5
	66 to 72	0.5	± 0.4
HR15TW	74 to 80	1.0	± 0.7
	81 to 86	0.7	± 0.5
	87 to 93	0.7	± 0.5
HR30TW	43 to 56	1.0	± 0.7
	57 to 69	0.7	± 0.5
	70 to 83	0.7	± 0.5
HR45TW	13 to 32	1.0	± 0.7
	33 to 52	0.7	± 0.5
	53 to 73	0.7	± 0.5
HR15WW ^A		1.0	± 0.5
HR30WW ^A		1.0	± 0.5
HR45WW ^A		1.0	± 0.5
HR15XW ^A		1.0	± 0.5
HR30XW ^A		1.0	± 0.5
HR45XW ^A		1.0	± 0.5
HR15YW ^A		1.0	± 0.5
HR30YW ^A		1.0	± 0.5
HR45YW ^A		1.0	± 0.5

^A Appropriate ranges of standardized test blocks for the L, M, P, R, S, V, W, X, and Y scales shall be determined by dividing the usable range of the scale into two ranges, high and low. Standardized test blocks for the R and S scales may be available at only one hardness level.

A2.6.3.3 The indenter(s) to be used for the indirect verification shall be the same indenter(s) that will be used for future standardizations. If more than one indenter will be used for the same hardness scale, an additional verification shall be made for each indenter.

A2.6.3.4 The test cycle to be used for the indirect verification should be the same as the test cycle used by the standardizing laboratory when calibrating the standardized test blocks.

A2.6.3.5 Prior to testing the standardized test blocks, ensure that the testing machine is working freely, and that the indenter and anvil are seated adequately. Make at least two hardness measurements on a uniform test piece for the scale to be verified. The results of these measurements need not be recorded.

A2.6.3.6 On each standardized block, make at least five hardness measurements distributed uniformly over the surface of the block.

A2.6.3.7 *Error*—Using Eq 2, determine the error E in the performance of the standardizing machine for each standardized test block that is measured. The error E shall be within the tolerances of Table A2.6.

A2.6.3.8 *Repeatability*—Using Eq 3, determine the repeatability R in the performance of the standardizing machine for each standardized test block that is measured. The repeatability R shall be within the tolerances of Table A2.6. If the calculated repeatability is outside the tolerances of Table A2.6, it may be due to the non-uniformity of the test block. The repeatability R may be determined again by making an additional five measurements on each standardized block in close proximity to each other adhering to indentation spacing restrictions (see Fig. 3). A pattern such as illustrated in Fig. A2.1 is recommended. The close proximity of the measurements will reduce the effect of test block non-uniformity.

A2.6.3.9 If any of the error E or repeatability R measurements fall outside of the specified tolerances, the standardizing machine shall not be considered to have passed the indirect verification. A number of corrective actions may be attempted to bring the standardizing machine within tolerances. These actions include cleaning and maintenance or replacing the anvil. No adjustments to the force application system, force

measurement system, or depth measuring system may be made. The indirect verification procedures may be repeated after making the allowed corrective actions. If the standardizing machine continues to fail the repeatability or error tests following corrective actions, the standardizing machine must undergo adjustment and/or repair followed by a direct verification.

A2.6.3.10 It is recommended that immediately following the successful completion of an indirect verification, user test blocks are calibrated for use as monitoring blocks as outlined in A2.7.

A2.7 Monitoring Verification

A2.7.1 This section describes the monitoring procedures for a standardizing hardness machine used for the standardization of test blocks, and the calibration and use of monitoring test blocks.

A2.7.2 The standardizing laboratory shall monitor the performance of a standardizing machine used for the standardization of test blocks between periodic direct and indirect verifications by performing monitoring verifications each day that standardizations are made, according to the schedule given in Table A2.3. Monitoring verifications are indirect verifications performed with monitoring test blocks that bracket the standardization hardness level.

A2.7.3 The standardizing laboratory should track the performance of the standardizing machine using control-charting techniques or other comparable methods. The control charts are intended to indicate whether there is a loss of measurement control in the performance of the standardizing machine.

A2.7.4 *Monitoring Test Blocks*—Test blocks that meet the physical requirements (see Table A4.1) and the uniformity requirements (see Table A4.2) of Annex A4 shall be used. The monitoring test blocks shall be at each of the appropriate hardness ranges of each hardness scale that will be used. These ranges are given in Table A2.6. It is to the advantage of the laboratory to use test blocks that exhibit high uniformity in hardness across the test surface. The laboratory may, in all cases, perform the monitoring tests using primary standardized test blocks.

A2.7.5 *Procedure for Calibrating Monitoring Test Blocks*—Monitoring test blocks for a specific Rockwell scale shall be calibrated by the standardizing laboratory following an indirect verification of the scales for which monitoring blocks will be calibrated. An adequate number of monitoring blocks should be calibrated for each hardness scale and hardness level. The number of blocks required is dependent on each laboratory's needs and experience.

A2.7.5.1 Prior to calibrating the monitoring test blocks, ensure that the testing machine is working freely, and that the indenter and anvil are seated adequately. Each time the hardness scale is changed, make at least two hardness measurements on a uniform test piece for the scale to be verified. The results of these measurements need not be recorded.




FIG. A2.1 Suggested Pattern for Repeatability Measurements

A2.7.5.2 Make at least five measurements distributed uniformly over the surface of one of the monitoring test blocks. Repeat this procedure, as required, for the quantity of blocks needed at the appropriate ranges of each Rockwell scale.

A2.7.5.3 For each of the monitoring test blocks, let \bar{H}_M be the average of the calibration values as measured by the standardizing machine. The value of \bar{H}_M may be corrected for the error E that was determined for that Rockwell scale and hardness level as a result of the indirect verification.

A2.7.6 For each monitoring block, the following information shall be recorded and retained for at least the time period during which the monitoring block calibration is valid.

A2.7.6.1 Serial number.

A2.7.6.2 Calibrated hardness value, \bar{H}_M .

A2.7.6.3 Date of calibration.

A2.7.7 *Monitoring Methods*—It is recommended that control charts or other comparable methods be used to monitor the performance of the standardizing machine between verifications. Control charts provide a method for detecting lack of statistical control. There are many publications available that discuss the design and use of control charts, such as the ASTM “Manual on Presentation of Data and Control Chart Analysis: 6th Edition,” prepared by Committee E11 on Quality and Statistics. The standardizing laboratory should develop and use control charts that best apply to their specific needs.

A2.7.8 *Monitoring Procedures*—The following monitoring procedures shall be performed before and after each lot of test blocks is standardized. When standardizations of a single lot of test blocks spans multiple days, the monitoring procedures shall be performed at the end of the work day and at the start of the following day during the period that the lot is standardized. In addition, the monitoring procedures shall be performed whenever the indenter, anvil, or test force is changed.

A2.7.8.1 At least two monitoring test blocks shall be used in the appropriate hardness ranges that bracket the hardness level to be standardized. These ranges are given in **Table A2.6**. For some Rockwell scales (for example, HRR and HRS) there may be only one monitoring test block that can be used.

A2.7.8.2 Prior to testing the monitoring test blocks, ensure that the testing machine is working freely, and that the indenter and anvil are seated adequately. Make at least two hardness measurements on a uniform test piece for the scale to be verified. The results of these measurements need not be recorded. Repeat this procedure each time the hardness scale is changed.

A2.7.8.3 On each monitoring test block, make at least four measurements distributed uniformly over the surface of the block.

A2.7.8.4 *Error*—Determine the error E (**Eq 2**) in the performance of the standardizing machine for each monitoring test block that is measured. The error E shall be within the tolerances of **Table A2.6**.

A2.7.8.5 *Repeatability*—Determine the repeatability R in the performance of the standardizing machine (**Eq 3**) for each standardized test block that is measured. The repeatability R shall be within the tolerances of **Table A2.6**.

A2.7.8.6 If any of the error E measurements or the repeatability R measurements fall outside of the specified tolerances, the standardizing machine shall not be considered to have passed the monitoring verification, and shall not be used for standardizations. A number of corrective actions may be attempted to bring the standardizing machine within tolerances. These actions include cleaning and maintenance or replacing the anvil. No adjustments to the force application system, force measurement system, or depth measuring system may be made. The monitoring verification procedures may be repeated after making the allowed corrective actions. If the standardizing machine continues to fail the error tests following corrective actions, the standardizing machine must undergo adjustment and/or repair followed by a direct verification.

A2.7.8.7 Whenever a standardizing machine fails a monitoring verification, the standardizations made since the last valid monitoring verification may be suspect.

A2.7.8.8 Examine the measurement data using control charts or other monitoring systems that are being used (see **Note A2.4**). If the monitoring verification data indicates that the standardizing machine is within control parameters, standardizations are considered to be valid.

Note A2.4—Control chart data should be interpreted by the laboratory based on past experience. The need for corrective action does not depend solely on data falling outside the control limits, but also on the prior data leading to this occurrence. As a general rule, however, once the standardizing machine is determined to be in control, a single occurrence of data falling outside the control limits should alert the laboratory to a possible problem. The level of action that is required depends on the history of the machine performance. It may be precautionary such as increasing the monitoring frequency, or corrective such as performing new direct and indirect verifications.

A2.8 Verification Report

A2.8.1 Direct Verification:

A2.8.1.1 Reference to this ASTM test method.

A2.8.1.2 Identification of the hardness standardizing machine, including the serial number, manufacturer and model number.

A2.8.1.3 Identification of all devices (elastic proving devices, etc.) used for the verification, including serial numbers and identification of standards to which traceability is made.

A2.8.1.4 Test temperature at the time of verification reported to a resolution of at least 1°C.

A2.8.1.5 The individual measurement values and calculated results used to determine whether the standardizing machine meets the requirements of the verification performed. It is recommended that the uncertainty in the calculated results used to determine whether the standardizing machine meets the requirements of the verification performed also be reported.

A2.8.1.6 Description of adjustments or maintenance done to the standardizing machine, when applicable.

A2.8.1.7 Date of verification and reference to the verifying agency or department.

A2.8.1.8 Signature of the person performing the verification.

A2.8.1.9 Accreditation certification number.

A2.8.2 Indirect Verification:

A2.8.2.1 Reference to this ASTM test method.

A2.8.2.2 Identification of the standardizing machine, including the serial number, manufacturer and model number.

A2.8.2.3 Identification of all devices (test blocks, indenters, etc.) used for the verification, including serial numbers and identification of standards to which traceability is made.

A2.8.2.4 Test temperature at the time of verification reported to a resolution of at least 1°C.

A2.8.2.5 The Rockwell hardness scale(s) verified.

A2.8.2.6 The individual measurement values and calculated results used to determine whether the standardizing machine meets the requirements of the verification performed. Measurements made to determine the as-found condition of the standardizing machine shall be included whenever they are made. It is recommended that the uncertainty in the calculated

results used to determine whether the standardizing machine meets the requirements of the verification performed also be reported.

A2.8.2.7 Description of maintenance done to the standardizing machine, when applicable.

A2.8.2.8 Date of verification and reference to the verifying agency or department.

A2.8.2.9 Signature of the person performing the verification.

A2.8.2.10 Accreditation certification number.

A2.8.3 *Monitoring Verification:*

A2.8.3.1 No verification report is required; however, it is required that records be kept of the monitoring verification results, see [A2.7.8.8](#).

A3. STANDARDIZATION OF ROCKWELL INDENTERS

A3.1 Scope

A3.1.1 [Annex A3](#) specifies the requirements and procedures to manufacture and standardize the Rockwell diamond spherocanonical indenter and Rockwell ball indenters for use with all Rockwell scales.

NOTE A3.1—Previous versions of this standard specified that diamond indenters used for calibrations meet the following geometrical requirements:

included angle of $120 \pm 0.1^\circ$;

mean radius of 0.200 ± 0.005 mm; and

radius in each measured section of 0.200 ± 0.007 mm.

It is believed that diamond indenters meeting these tolerances are not reliably available on the world market at this time. Consequently, for this revision, the tolerances for the geometric features of the Class A and Reference diamond indenters have been temporarily widened to the levels of Class B indenters until such time as indenters having tighter tolerances become reliably available.

A3.1.2 The Annex covers two levels of ball indenters, designated by this standard as Class B, and Class A. Class B indenters are intended for every day use with Rockwell hardness testing machines and for the indirect verification of Rockwell hardness testing machines in accordance with [Annex A1](#). Class A indenters are intended for the indirect verification of Rockwell standardizing machines in accordance with [Annex A2](#), and for the standardization of test blocks in accordance with [Annex A4](#).

A3.1.3 The Annex covers three levels of diamond indenters, designated by this standard as Class B, Class A and Reference indenters. Class B indenters are intended for every day use with Rockwell hardness testing machines. Class A indenters are intended for the standardization of Class B indenters in accordance with this Annex, and for the standardization of test blocks in accordance with [Annex A4](#). Reference indenters are intended for the standardization of Class A indenters.

A3.1.4 This Annex also provides the schedule for verifying indenters.

A3.1.5 Adherence to this standard and annex provides traceability to national standards, except as stated otherwise.

A3.2 Accreditation

A3.2.1 The agency conducting the standardizations of indenters shall be accredited to the requirements of ISO 17025 (or an equivalent) by an accrediting body recognized by the International Laboratory Accreditation Cooperation (ILAC) as operating to the requirements of ISO/IEC 17011. The standardizing laboratory shall have a certificate of accreditation stating the class and types of indenters that are covered by the accreditation. Only indenters of the class and types within the laboratory's scope of accreditation are considered to meet this standard, except as stated below.

NOTE A3.2—Accreditation is a new requirement starting with this edition of the standard.

A3.3 General Requirements

A3.3.1 The standard Rockwell hardness indenters are the *diamond spherocanonical indenter*, and *tungsten carbide (WC)* ball indenters with diameters of $\frac{1}{16}$ in. (1.588 mm), $\frac{1}{8}$ in. (3.175 mm), $\frac{1}{4}$ in. (6.350 mm), and $\frac{1}{2}$ in. (12.70 mm) to be used for the Rockwell hardness scales as given in [Table A3.1](#). Steel ball indenters may be used in special circumstances (see [5.1.2.1](#)).

A3.3.2 The standardizing laboratory environment, the standardizing machine, and the standardizing test cycle shall satisfy the requirements of [Annex A2](#).

A3.3.3 All instruments used to make measurements required by this Annex shall be calibrated traceable to national standards where a system of traceability exists, except as noted otherwise.

A3.3.4 All classes of diamond indenters and ball indenters shall be verified for correct geometry and performance in accordance with the schedule specified in [Table A3.2](#).

A3.4 Ball Indenters

A3.4.1 Ball indenters frequently consist of a holder, a cap and a ball. The standardization process defined in this section

TABLE A3.1 Indenter Types for Specific Rockwell Scales

Scale Symbol	Indenter Type
HRA	Diamond Spheroconical
HRBW	WC Ball - $\frac{1}{16}$ in. (1.588 mm)
HRC	Diamond Spheroconical
HRD	Diamond Spheroconical
HREW	WC Ball - $\frac{1}{8}$ in. (3.175 mm)
HRFW	WC Ball - $\frac{1}{16}$ in. (1.588 mm)
HRGW	WC Ball - $\frac{1}{16}$ in. (1.588 mm)
HRHW	WC Ball - $\frac{1}{8}$ in. (3.175 mm)
HRKW	WC Ball - $\frac{1}{8}$ in. (3.175 mm)
HRLW	WC Ball - $\frac{1}{4}$ in. (6.350 mm)
HRMW	WC Ball - $\frac{1}{4}$ in. (6.350 mm)
HRPW	WC Ball - $\frac{1}{4}$ in. (6.350 mm)
HRRW	WC Ball - $\frac{1}{2}$ in. (12.70 mm)
HRSW	WC Ball - $\frac{1}{2}$ in. (12.70 mm)
HRVW	WC Ball - $\frac{1}{2}$ in. (12.70 mm)
HR15N	Diamond Spheroconical
HR30N	Diamond Spheroconical
HR45N	Diamond Spheroconical
HR15TW	WC Ball - $\frac{1}{16}$ in. (1.588 mm)
HR30TW	WC Ball - $\frac{1}{16}$ in. (1.588 mm)
HR45TW	WC Ball - $\frac{1}{16}$ in. (1.588 mm)
HR15WW	WC Ball - $\frac{1}{8}$ in. (3.175 mm)
HR30WW	WC Ball - $\frac{1}{8}$ in. (3.175 mm)
HR45WW	WC Ball - $\frac{1}{8}$ in. (3.175 mm)
HR15XW	WC Ball - $\frac{1}{4}$ in. (6.350 mm)
HR30XW	WC Ball - $\frac{1}{4}$ in. (6.350 mm)
HR45XW	WC Ball - $\frac{1}{4}$ in. (6.350 mm)
HR15YW	WC Ball - $\frac{1}{2}$ in. (12.70 mm)
HR30YW	WC Ball - $\frac{1}{2}$ in. (12.70 mm)
HR45YW	WC Ball - $\frac{1}{2}$ in. (12.70 mm)

TABLE A3.2 Indenter Verification Schedule

Indenter Type	Geometrical Features	Performance
Class B diamond	When an indenter is new.	When an indenter is new, and when suspected damage has occurred.
Class A diamond	When an indenter is new.	Shall be within 12 months prior to standardization testing and when suspected damage has occurred.
Reference diamond	When an indenter is new.	When an indenter is new, and when suspected damage has occurred.
Class A and Class B ball	Balls shall be verified for dimensions when new. Ball holders shall be verified for ball protrusion when new.	Ball holders shall be verified when new, and when suspected damage has occurred. (This requirement does not apply when simply replacing a ball.)

involves the assembled unit. The ball may be changed without affecting the assembly's verification provided the ball conforms to all the requirements in this section.

A3.4.2 One-piece fixed-ball indenters are allowed provided the indenter meets the same requirements as removable ball indenters. The manufacturer shall ensure that the method used to affix the ball to the holder does not affect the dimensions or properties of the ball.

A3.4.3 Indenter Balls—The balls shall meet the following requirements:

A3.4.3.1 The mean surface roughness of the ball shall not exceed 0.00005 mm (2 μ m).

A3.4.3.2 The diameter of Class B balls, when measured at not less than three positions, shall not differ from the nominal diameter by more than 0.0025 mm (0.0001 in.).

A3.4.3.3 The diameter of Class A balls, when measured at not less than three positions, shall not differ from the nominal diameter by more than 0.0010 mm (0.00004 in.).

NOTE A3.3—Balls that conform to ABMA Grade 24 satisfy the requirements for size and finish for Class A and Class B as specified in ABMA Standard 10-1989.

A3.4.3.4 The hardness of a tungsten carbide ball shall not be less than 1500 HV1 in accordance with Test Method E92 or E384.

A3.4.3.5 The material of tungsten carbide balls shall have a density of 14.8 ± 0.2 g/cm³, and the following chemical composition:

Total other carbides	2.0 % maximum
Cobalt (Co)	5.0 to 7.0 %
Tungsten carbide (WC)	balance

A3.4.3.6 The surface hardness of a steel ball shall not be less than 746 HV1 in accordance with Test Method E92 or E384.

A3.4.3.7 For the purpose of verifying the requirements of the ball given in A3.4.3, it is considered sufficient to test a sample set of balls selected at random from a batch in accordance with the schedule specified in Table A3.2. The balls verified for hardness shall be discarded.

A3.4.3.8 To meet the above requirements for indenter balls, the indenter standardizing laboratory may either verify that the balls meet the requirements, or obtain a certificate of verification from the ball manufacturer.

A3.4.4 Ball Holder—The ball holder shall meet the following requirements:

A3.4.4.1 The material used to manufacture the portion of the ball holder that supports the test force should have a minimum hardness of 25 HRC.

A3.4.4.2 The ball shall protrude outside the holder a minimum of 0.3 mm. This requirement may be verified by direct measurement or by performing the appropriate Rockwell scale test on a standardized test block that has an equivalent hardness of 10 HRBW or softer. The protrusion is sufficient if the hardness result is within ± 1.5 of the certified value of the block.

A3.4.5 Performance Verification of Ball Indenter Holders—The influence of the ball indenter on the hardness value is not due solely to the previously specified features of the ball, but also on characteristics of the ball holder that may vary due to manufacturing procedures. To examine these influences, the performance of each new Class B and Class A ball holder shall be verified in accordance with the schedule specified in Table A3.2.

A3.4.5.1 The performance verification is accomplished by making hardness measurements on test blocks meeting the manufacturing requirements of A4.3 and having been standardized using a standardizing machine which successfully passed direct verification in accordance with A2.6.2. At least one test block shall be tested for the Rockwell hardness scale and hardness range given in Table A3.3, corresponding to the ball size being verified. Some specially designed $\frac{1}{16}$ in. (1.588 mm) Class B indenters may not be able to perform tests using the Rockwell scales required for verification of normal indenters in

TABLE A3.3 Test Blocks to be Used for Class A and Class B Ball Indenter Performance Verifications and the Maximum Tolerance on the Performance with Respect to Standardized Reference Blocks

Ball Size in. (mm)	Ranges of Required Test Blocks	Class A Tolerance	Class B Tolerance
1/16 (1.588)	20 to 100 HRBW	± 0.4 HRBW	± 0.8 HRBW
1/8 (3.175)	68 to 92 HREW	± 0.4 HREW	± 0.8 HREW
1/4 (6.350)	HRLW, HRMW, or HRPW (any level)	± 0.4 HR	± 0.8 HR
1/2 (12.70)	HRRW, HRSW, or HRVW (any level)	± 0.4 HR	± 0.8 HR

Table A3.3. For example, this applies to thin-tip 1/16 in. (1.588 mm) ball indenters that cannot support HRB scale test forces. These limited scale indenters may be used provided they are certified for the scale or scales they are designed to perform by using the test block or blocks for those scales as defined in **Table A3.4**. In all cases the test report shall define the scale or scales the indenter is certified to perform.

A3.4.5.2 Prior to the performance verification, ensure that the testing machine is working freely, and that the indenter to be verified and anvil are seated adequately. Make at least two hardness measurements on a uniform test piece. The results of these measurements need not be recorded.

A3.4.5.3 On the standardized test block, make at least three measurements distributed uniformly over the test surface. Determine the difference between the average of the three or more measurements and the calibrated value of the test block.

A3.4.5.4 For acceptability, the difference shall be within the tolerances specified in **Table A3.3** for the class of indenter being verified or **Table A3.4** for the singular or limited scale indenter being verified.

A3.4.6 Ball indenters frequently consist of a holder and a removable cap that allows periodic changing of the ball. Indenter caps can be damaged during use and therefore may have to be replaced. When the cap is replaced with a new cap, the ball indenter assembly shall be performance tested before use by performing a daily verification according to **A1.5.3.1**. The test block used should have a hardness equal to or softer than the softest material that is expected to be tested using the indenter. The verification may be performed by the indenter owner or a calibration agency. A testing machine that meets the requirements of **Annex A1** shall be used for this verification.

TABLE A3.4 Test Blocks to be used for Singular or Limited Scale Ball Indenter Performance Verifications and the Maximum Tolerance on the Performance with Respect to Standardized Reference Blocks

Ball Size in. (mm)	Ranges of Required Test Blocks	Tolerance
1/16 (1.588) HR15TW scale	67 to 90 HR15TW	± 0.8 HR15TW
1/16 (1.588) HR30TW scale	30 to 77 HR30TW	± 0.8 HR30TW

A3.5 Class B Diamond Indenters

A3.5.1 Class B diamond indenters are intended for every day use to perform Rockwell hardness measurements. They shall be verified for correct geometry and performance in accordance with the schedule specified in **Table A3.2**.

A3.5.2 Geometric Requirements of Class B Diamond Indenters:

A3.5.2.1 The polished portion of the diamond indenter shall be free from surface defects (cracks, chips, pits, etc.) when observed under a 20× magnification. The indenter shall be polished to such an extent that no unpolished part of its surface makes contact with the test piece when the indenter penetrates to a depth of 0.3 mm.

A3.5.2.2 Verification of the following geometric features shall be made at not less than four approximately equally spaced full cross-section profiles. For example, four profiles would be spaced at approximately 45° intervals.

A3.5.2.3 The diamond shall have an included angle of $120 \pm 0.35^\circ$ (see **Fig. A3.1**).

A3.5.2.4 The tip of the diamond shall be spherical with a mean radius of 0.200 ± 0.010 mm (see **Fig. A3.1**). In each measured section, the radius shall be within 0.200 ± 0.015 mm, and local deviations from a true radius shall not exceed 0.002 mm.

A3.5.2.5 The surfaces of the cone and spherical tip shall blend in a tangential manner.

A3.5.2.6 The instrument(s) used to verify the geometrical features shall be capable of measuring to the accuracies given in **Table A3.5**.

A3.5.2.7 The verification of the geometrical features of the diamond may be made by direct measurement or by measurement of its projection on a screen provided the accuracy requirements are met.

A3.5.2.8 When the projection on a screen method is used, the contour of the diamond projection is compared to lines on the screen that indicate the dimensional tolerance limits. In this case, measurement values for the geometrical features are not required. It is sufficient to state that the features are within tolerances.

A3.5.3 Performance Verification of Class B Diamond Indenters:

A3.5.3.1 The influence of the diamond indenter on the hardness value is not due solely to the previously specified features of the indenter, but also on other characteristics that vary due to manufacturing procedures. To examine these influences, the performance of each Class B indenter shall be




FIG. A3.1 Diagram of Cross-Sectional View of Spherocoinal Diamond Indenter Tip

TABLE A3.5 Minimum Measuring Instrument Accuracies for Verifying the Geometrical Features of Class B, Class A and Reference Diamond Indenters

Geometrical Feature	Minimum Accuracy
Angles	0.1°
Radius	0.001 mm
Straightness of the generative line of the cone (Class A and Reference indenters only)	0.001 mm

verified by comparison to the performance of a *qualifying* Class A or Reference indenter.

A3.5.3.2 Diamond indenters may be verified for use on limited Rockwell scales as follows: regular Rockwell scales only; superficial Rockwell scales only; or both regular and superficial Rockwell scales. Special diamond indenters intended for single or limited scale use and indenters, such as side cut diamond indenters, that because of their geometries cannot support the heavier loads of some Rockwell scales are also allowed. In all cases the test report shall define the scale or scales the indenter is certified to perform.

A3.5.3.3 The performance verification is accomplished by making hardness measurements on test blocks meeting the manufacturing requirements of A4.3.

A3.5.3.4 Prior to the performance verification, ensure that the testing machine is working freely, and that the indenter and anvil are seated adequately. Make at least two hardness measurements on a uniform test piece using a total force of 150 kgf, or the greatest test force that the indenter can support. The results of these measurements need not be recorded. This procedure shall be repeated each time the indenter is changed.

A3.5.3.5 Using the *qualifying* indenter, perform the daily verification procedures of A1.5.3 for the scales and hardness levels that will be used for the indenter performance verification. If any of the error *E* measurements or the repeatability *R* measurements fall outside of the specified tolerances, the standardizing machine shall not be considered to have passed the verification, and shall not be used for standardization until the problem is determined and corrections have been made. Once corrections have been made, the verification procedure shall be repeated. This verification procedure is required only at the start of the indenter performance verification.

A3.5.3.6 The following procedures for performance verification involve making *qualifying* hardness tests on test blocks with a Class A or Reference indenter, then performing *verification* tests on the same blocks with the Class B indenters to be verified.

A3.5.3.7 Using the *qualifying* indenter, perform one set of at least three qualifying tests on each test block from each range defined in Table A3.6 for the type of indenter to be verified. Special singular or limited scale indenters (see A3.5.3.2) shall be certified for use on singular or limited scales using the test blocks defined in Table A3.7. For example, if an HRA scale only diamond indenter is desired, the two HRA scale test blocks defined in the table would be used. If an indenter to be used in the 15N and 30N scales only is desired, then 4 test

TABLE A3.6 Test Blocks to be Used Class B Diamond Indenter Performance Verifications and the Maximum Tolerance on the Performance Relative to the Class A or Reference Indenter

Indenter Type	Ranges of Required Test Blocks	Class B Tolerance as Compared to Class A or Reference Indenter $\bar{H}_Q - \bar{H}_V$
Regular Scales Diamond	22 to 28 HRC 60 to 65 HRC	± 0.8 HRC ± 0.4 HRC
Superficial Scales Diamond	88 to 94 HR15N 60 to 69 HR30N 22 to 29 HR45N	± 0.5 HR15N ± 0.5 HR30N ± 0.8 HR45N
Combination Regular and Superficial Scales Diamond	22 to 28 HRC 60 to 65 HRC 88 to 94 HR15N 60 to 69 HR30N	± 0.8 HRC ± 0.5 HRC ± 0.5 HR15N ± 0.5 HR15N

TABLE A3.7 Test Blocks to be Used for Singular or Limited Scale Diamond Indenter Performance Verifications and the Maximum Tolerance on the Performance Relative to the Class A or Reference Indenter

Indenter Type	Ranges of Required Test Blocks	Tolerance as Compared to Class A or Reference Indenter $\bar{H}_Q - \bar{H}_V$
HRA Scale	61 to 65 HRA 81 to 84 HRA	± 0.8 HRA ± 0.5 HRA
HRD Scale	41 to 46 HRD 70 to 75 HRD	± 0.8 HRD ± 0.5 HRD
HR15N Scale	70 to 74 HR15N 88 to 94 HR15N	± 0.8 HR15N ± 0.5 HR15N
HR30N Scale	43 to 49 HR30N 77 to 82 HR30N	± 0.8 HR30N ± 0.5 HR30N

blocks would be used, 2 in the 15N scale and 2 in the 30N scale as defined in the table. Record each test result and the location of the indentation. Let \bar{H}_Q be the average of the qualifying measurements.

A3.5.3.8 Using the Class B indenter to be verified, perform *verification* tests on the test blocks previously tested with the Class A or Reference indenter. One *verification* test shall be made within 6 mm of each qualifying indent. Let \bar{H}_V be the average of the verifying measurements.

A3.5.3.9 The number of verifying tests that can be made adjacent to each qualifying test is limited by the requirements to be within 6 mm of the qualifying indent while adhering to the indent to indent spacing requirements given in 7.9. To make additional verifying tests, perform additional qualifying tests with the Class A or Reference indenter, and repeat the above verifying procedure. This process may be repeated until there is no longer space on the test block.

A3.5.3.10 For acceptability, the difference between the qualifying and verifying averages, $\bar{H}_Q - \bar{H}_V$, shall be within the tolerances for Class B indenters of Table A3.6 or Table A3.7 for the singular or limited scale indenter being verified.

A3.6 Class A Diamond Indenters

A3.6.1 Class A indenters are intended to be used for the standardization of Class B indenters in accordance with this Annex; the standardization of Rockwell hardness test blocks as described in [Annex A4](#), and as a troubleshooting tool during the indirect verification of Rockwell hardness testing machines in accordance with [Annex A1](#). They are verified for correct geometry and performance in accordance with the schedule specified in [Table A3.2](#).

A3.6.1.1 The instrument(s) used to verify the geometrical features shall be capable of measuring to the accuracies given in [Table A3.5](#).

A3.6.2 A Class A diamond indenter shall meet all of the manufacture and geometric requirements for a Class B diamond indenter given in [A3.5.2](#) with the following additional requirements. See also [Note A3.1](#).

A3.6.2.1 The deviation from straightness of the generatic line of the diamond cone adjacent to the blend shall not exceed 0.002 mm over a minimum length of 0.40 mm.

A3.6.2.2 The angle between the axis of the indenter and the axis normal to the seating surface of the indenter shall not exceed 0.5°.

A3.6.3 Class A diamond indenters have tighter performance tolerances than Class B diamond indenters. The performance of each Class A indenter shall be verified by comparison to the performance of a Reference indenter.

A3.6.4 Perform the qualifying and verifying measurements as described in [A3.5.3](#) for a Class B diamond indenter, except that the qualifying measurements shall be made using a Reference diamond indenter on each test block from each range defined in [Table A3.8](#) for the type of indenter to be verified.

A3.6.4.1 For acceptability, the difference of the average of the three qualifying measurements and the average of the three verifying measurements, $\bar{H}_Q - \bar{H}_V$, shall be within the tolerance specified for Class A diamond indenters in [Table A3.8](#).

TABLE A3.8 Test Blocks to be Used for Class A Diamond Indenter Performance Verifications and the Maximum Tolerance on the Performance Relative to the Reference Indenter

Indenter Type	Ranges of Required Test Blocks	Class A Tolerance as Compared to Reference Indenter $\bar{H}_Q - \bar{H}_V$
Regular Scales Diamond	80 to 83 HRA	± 0.3 HRA
	22 to 28 HRC	± 0.4 HRC
	42 to 50 HRC	± 0.4 HRC
	60 to 65 HRC	± 0.3 HRC
Superficial Scales Diamond	88 to 94 HR15N	± 0.3 HR15N
	60 to 69 HR30N	± 0.3 HR30N
	42 to 50 HR30N	± 0.4 HR45N
	22 to 29 HR45N	± 0.4 HR45N
Combination Regular and Superficial Scales Diamond	22 to 28 HRC	± 0.4 HRC
	60 to 65 HRC	± 0.3 HRC
	88 to 94 HR15N	± 0.3 HR15N
	60 to 69 HR30N	± 0.3 HR30N

A3.7 Reference Diamond Indenters

A3.7.1 Reference diamond indenters are intended for the standardization of Class A diamond indenters. The reference indenter shall have tighter performance tolerances than Class A and Class B indenters and shall be verified for performance by comparison to an indenter recognized as the national reference indenter(s) of a national Rockwell hardness standardizing laboratory (see [Note A3.4](#)).

NOTE A3.4—In the United States, the national Rockwell hardness standardizing laboratory is the National Institute of Standards and Technology (NIST).

A3.7.2 Geometric Requirements of Reference Diamond Indenters:

A3.7.2.1 Verification of the following geometric features of a Reference diamond spherconical indenter shall be made at not less than eight approximately equally spaced full cross-section profiles. For example, eight profiles would be spaced at approximately 22.5 degree intervals.

A3.7.3 A Reference diamond indenter shall meet all of the manufacture and geometric requirements for a Class A diamond indenter given in [A3.6.2](#). See also [Note A3.1](#).

A3.7.4 Performance Verification of Reference Diamond Indenters:

A3.7.4.1 The performance comparison shall be performed by a national Rockwell hardness standardizing laboratory, and shall meet the performance tolerances of [Table A3.9](#).

A3.7.4.2 Perform the qualifying and verifying measurements as described in [A3.5.3](#) for a Class B indenter, except that at least four qualifying measurements shall be made using a national reference indenter (see [A3.7.1](#)) on each test block from each range defined in [Table A3.9](#) for the type of indenter to be verified.

A3.7.4.3 For acceptability, the difference of the average of the five qualifying measurements and the average of the five verifying measurements, $\bar{H}_Q - \bar{H}_V$, shall be within the tolerance specified for Reference indenters in [Table A3.9](#) for each test block used in the verification.

TABLE A3.9 Test Blocks to be Used for Reference Indenter Performance Verifications and the Maximum Tolerance on the Performance Relative to a National Reference Indenter

Indenter Type	Ranges of Required Test Blocks	Reference Indenter Tolerance as Compared to a National Reference Indenter $\bar{H}_Q - \bar{H}_V$
Regular Scales Diamond	22 to 28 HRC	± 0.3 HRC
Superficial Scales Diamond	88 to 94 HR15N	± 0.3 HR15N
Combination Regular and Superficial Scales Diamond	20 to 28 HRC	± 0.3 HRC
	62 to 65 HRC	± 0.3 HRC
	40 to 48 HR45N	± 0.3 HR45N
	88 to 94 HR15N	± 0.3 HR15N
	40 to 48 HR45N	± 0.3 HR45N

A3.8 Marking

A3.8.1 All indenters shall be serialized. When it is not practical to mark the serial number on the indenter due to size limitations, the serial number shall be marked on the container.

A3.8.2 Diamond indenters should be marked to indicate the scales that they are certified to perform. For example, regular scale diamond indenters may be marked with a "C" and superficial scale diamond indenters may be marked with an "N". Combination indenters may be marked with both a "C" and an "N".

A3.8.3 Single or limited scale indenters shall be marked to indicate the scale(s) they are certified to perform. When it is not practical to mark the scale on the indenter due to size limitations, the scale shall be marked on the container.

A3.9 Certificate

A3.9.1 *Ball Indenters*—Each Class B and Class A ball indenter holder shall have a calibration certificate with the following information:

A3.9.1.1 Reference to this ASTM test method.

A3.9.1.2 Serial number of the indenter.

A3.9.1.3 Date of standardization.

A3.9.1.4 A statement declaring that the indenter meets all of the material hardness, ball protrusion and performance requirements for the particular Class of Rockwell ball indenter.

A3.9.1.5 Accreditation agency certification number.

A3.9.1.6 The scale(s) that the indenter is certified to perform when certified for singular or limited scales.

A3.9.2 Indenter balls for Class B and Class A indenters shall have a report, applicable to one or more balls, with the following information:

A3.9.2.1 Reference to this ASTM test method.

A3.9.2.2 Identification of the lot or batch.

A3.9.2.3 A statement declaring that the ball meets all of the geometrical, density, chemical composition and hardness requirements for the particular Class of Rockwell ball indenter.

A3.9.3 *Class B Diamond Indenters*—Each Class B diamond indenter shall have a calibration certificate with the following information:

A3.9.3.1 Reference to this ASTM test method.

A3.9.3.2 Serial number of the indenter.

A3.9.3.3 Date of standardization.

A3.9.3.4 A statement declaring that the indenter meets all of the geometrical and performance requirements for a Class B indenter.

A3.9.3.5 Accreditation agency certification number.

A3.9.3.6 The scale(s) that the indenter is certified to perform when certified for singular or limited scales.

A3.9.4 *Class A Diamond Indenters*—Each Class A diamond indenter shall have a calibration certificate with the following information:

A3.9.4.1 Reference to this ASTM test method.

A3.9.4.2 Serial number of the indenter.

A3.9.4.3 Date of standardization.

A3.9.4.4 The results of all geometrical verifications.

A3.9.4.5 All qualifying and verifying performance measurements with the hardness levels of the test blocks used.

A3.9.4.6 The performance differences between the Reference standardizing indenter and the verified Class A indenter $\bar{H}_Q - \bar{H}_V$ for each test block used.

A3.9.4.7 A statement declaring that the indenter meets all of the geometrical and performance requirements for a Class A indenter.

A3.9.4.8 Accreditation agency certification number.

A3.9.5 *Reference Diamond Indenters*—Each Reference diamond indenter shall have a calibration certificate or report with the following information:

A3.9.5.1 Serial number of the indenter.

A3.9.5.2 Date of standardization.

A3.9.5.3 The results of all geometrical verifications.

A3.9.5.4 Serial number of the reference indenter.

A3.9.5.5 All qualifying and verifying performance measurements with the hardness levels of the test blocks used.

A3.9.5.6 The performance differences between the reference indenter and the verified Reference indenter $\bar{H}_Q - \bar{H}_V$ for each test block used.

A4. STANDARDIZATION OF ROCKWELL HARDNESS TEST BLOCKS

A4.1 Scope

A4.1.1 Annex A4 specifies the requirements and procedures for the standardization of Rockwell hardness test blocks that are traceable to specific Rockwell hardness standards. These standardized test blocks are to be used for the verification of the performance of Rockwell and Rockwell superficial hardness testing machines by way of daily verifications and indirect verifications as described in Annex A1. The standardized test blocks are also to be used for the monitoring verifications of Rockwell standardizing machines as described in Annex A2.

A4.1.2 Adherence to this standard and annex provides traceability to national standards, except as stated otherwise.

A4.2 Accreditation

A4.2.1 The agency conducting the standardizations of test blocks shall be accredited to the requirements of ISO 17025 (or an equivalent) by an accrediting body recognized by the International Laboratory Accreditation Cooperation (ILAC) as operating to the requirements of ISO/IEC 17011. The standardizing agency shall have a certificate/scope of accreditation

stating the Rockwell hardness scales that are covered by the accreditation, and the standards to which the test block standardizations are traceable.

NOTE A4.1—Accreditation is a new requirement starting with this edition of the standard.

A4.3 Manufacture

A4.3.1 The attention of the manufacturer of test blocks is drawn to the need to use material and a manufacturing process which will give the necessary homogeneity, stability of structure, and uniformity of surface hardness. For quality control purposes, test blocks should be examined for homogeneity and uniformity of surface hardness in accordance with a statistically acceptable sampling procedure.

A4.3.2 The test blocks, if of steel, shall be demagnetized at the end of the manufacturing process.

A4.3.3 To assure that material is not removed from the test surface after standardization, an identifying mark shall be made on the test surface. The mark shall be such that it can not be removed by any method other than removal of test block material.

A4.3.4 The standardized test block shall meet the physical requirements of [Table A4.1](#).

A4.4 General Requirements

A4.4.1 The standardizing laboratory environment, the standardizing machine, and the standardizing test cycle shall satisfy the requirements of [Annex A2](#).

A4.4.2 All instruments used to make measurements required by this Annex shall have been calibrated traceable to national standards where a system of traceability exists, except as noted otherwise.

A4.5 Standardization Procedure

A4.5.1 A test block is standardized by calibrating the average hardness of the test surface to a specific Rockwell hardness standard. Only one surface of the test block shall be calibrated. When possible, the test blocks should be calibrated traceable to national Rockwell standards (see [Note A4.2](#)). The Rockwell standard to which the test blocks are traceable shall be stated in the certification.

NOTE A4.2—In the United States, the national Rockwell hardness standardizing laboratory is the National Institute of Standards and Technology (NIST), Gaithersburg, MD 20899.

NOTE A4.3—Primary standardized test blocks are available as Standard Reference Material from NIST, Gaithersburg, MD 20899.

TABLE A4.1 Physical Requirements of Standardized Test Blocks

Test Block Parameter	Tolerance
Thickness	$\geq 6.0 \text{ mm (0.236 in.)}$ $\leq 16.0 \text{ mm (0.630 in.)}$
Test surface area	$\leq 2600 \text{ mm}^2 (4 \text{ in.}^2)$
Deviation from surface flatness (test & bottom)	$\leq 0.005 \text{ mm (0.0002 in.)}$
Deviation from surface parallelism (test & bottom)	$\leq 0.0002 \text{ mm per mm}$ $(0.0002 \text{ in. per in.})$
Mean surface roughness (test & bottom)	$R_a \leq 0.003 \text{ mm (12 } \mu\text{in.)}$ center line average

A4.5.2 Class A ball indenters and Class A or Reference diamond indenters as described in [Annex A3](#) (see [Note 3](#)) shall be used for the standardization of test blocks.

A4.5.3 The standardization procedure involves making hardness measurements on the test block surface using the forces and type of indenter that are appropriate for the hardness scale.

A4.5.3.1 Make at least five measurements distributed uniformly over the test surface.

A4.5.4 Determine the nonuniformity range H_R of the measurements as:

$$H_R = H_{\max} - H_{\min} \quad (\text{A4.1})$$

where:

H_{\max} = highest hardness value, and
 H_{\min} = lowest hardness value.

A4.5.4.1 The nonuniformity range H_R of the standardizing measurements provides an indication of the non-uniformity of the test block hardness. For acceptability, the nonuniformity range H_R shall be within the tolerances of [Table A4.2](#).

A4.5.5 The standardized value of the test block is defined as the average of the standardization measurements \bar{H} .

A4.5.6 In some cases, a more accurate standardized value for the test block may be obtained by correcting the measured average hardness value by a performance offset value for the standardizing machine. The offset value may be based on the error E values measured during the last indirect verification of the standardizing machine. For example, an appropriate offset correction curve for each standardizing machine may be calculated for a specific Rockwell scale by fitting a linear line to the error values measured during the indirect verification.

TABLE A4.2 Maximum Nonuniformity for Standardized Test Blocks

Nominal Hardness of Standardized Test Block	Max. Nonuniformity Range, H_R (HR units)	
HRA	$\geq 20 \text{ and } < 80$ $\geq 80 \text{ and } < 92$	1.0 0.5
HRBW	$\geq 0 \text{ and } < 45$ $\geq 45 \text{ and } < 100$	1.5 1.0
HRC	$\geq 20 \text{ and } < 60$ $\geq 60 \text{ and } < 70$	1.0 0.5
HRD	$\geq 40 \text{ and } < 60$ $\geq 60 \text{ and } < 87$	1.0 0.5
HREW, HRFW, HRGW, HRHW, HRKW, HRLW, HRMW, HRPW, HRRW, HRSW, HRVW		1.0
HR15N	$\geq 69 \text{ and } < 90$ $\geq 90 \text{ and } < 97$	1.0 0.7
HR30N	$\geq 41 \text{ and } < 77$ $\geq 77 \text{ and } < 92$	1.0 0.7
HR45N	$\geq 19 \text{ and } < 66$ $\geq 66 \text{ and } < 87$	1.0 0.7
HR15TW, HR30TW, HR45TW HR15WW, HR30WW, HR45WW, HR15XW, HR30XW, HR45XW, HR15YW, HR30YW, HR45YW		1.0 1.0

The laboratory should be cautioned that the validity of calculating a correction curve in this way is dependent on the linearity of the fit of the offset data across the entire scale.

A4.6 Marking

A4.6.1 Markings placed on the side of the block shall be upright when the calibrated test surface is the upper surface.

A4.6.2 Each standardized block shall be marked with the following.

A4.6.2.1 The standardized hardness value, \bar{H} , of the test block, rounded to no less than one decimal place in accordance with Practice E29, for example 61.4 HRC.

A4.6.2.2 The appropriate tolerance value for error E given in Table A1.3.

A4.6.2.3 Name or identifying mark of the standardizing agency.

A4.6.2.4 A mark identifying the test surface, which will be obliterated if the surface is reground.

A4.6.2.5 Unique serial number.

A4.6.2.6 Year of standardization. It is sufficient that the year of standardization be incorporated into the serial number of the block.

A4.7 Certificate

A4.7.1 Each standardized test block shall be supplied with a certificate from the standardizing laboratory stating the following standardization information:

A4.7.1.1 Serial number of the test block.

A4.7.1.2 The standardized hardness value, \bar{H} , of the test block with the scale designation, rounded to no less than one decimal place in accordance with Practice E29, for example 61.4 HRC.

A4.7.1.3 Value of the uncertainty in the standardized value with a detailed explanation of how the uncertainty was calculated.

A4.7.1.4 The individual standardizing hardness measurements.

A4.7.1.5 A description of the testing cycle used, including the dwell times for the preliminary force, total force and elastic recovery.

A4.7.1.6 The body that maintains the Rockwell scale to which the test block is traceable. For example, the national Rockwell C scale maintained at NIST.

A4.7.1.7 Date of standardization.

A4.7.1.8 Accreditation agency certification number.

A5. GUIDELINES FOR DETERMINING THE MINIMUM THICKNESS OF A TEST PIECE

**TABLE A5.1 A Minimum Thickness Guide for Selection of Scales
Using the Diamond Indenter (see Fig. A5.1)**

NOTE 1—For any given thickness, the indicated Rockwell hardness is the minimum value acceptable for testing. For a given hardness, material of any greater thickness than that corresponding to that hardness can be tested on the indicated scale.

Minimum Thickness	Rockwell Scale				
	in.	mm	Hardness Reading	A	C
				Approximate Hardness C-Scale ^A	Hardness Reading
0.014	0.36
0.016	0.41	86	69
0.018	0.46	84	65
0.020	0.51	82	61.5
0.022	0.56	79	56	69	69
0.024	0.61	76	50	67	67
0.026	0.66	71	41	65	65
0.028	0.71	67	32	62	62
0.030	0.76	60	19	57	57
0.032	0.81	52	52
0.034	0.86	45	45
0.036	0.91	37	37
0.038	0.96	28	28
0.040	1.02	20	20

^A These approximate hardness numbers are for use in selecting a suitable scale and should not be used as hardness conversions. If necessary to convert test readings to another scale, refer to Hardness Conversion Tables E140 (Relationship Between Brinell Hardness, Vickers Hardness, Rockwell Hardness, Rockwell Superficial Hardness, and Knoop Hardness).

**TABLE A5.2 A Minimum Thickness Guide for Selection of Scales
Using the 1/16 in. (1.588 mm) Diameter Ball Indenter
(see Fig. A5.2)**

NOTE 1—For any given thickness, the indicated Rockwell hardness is the minimum value acceptable for testing. For a given hardness, material of any greater thickness than that corresponding to that hardness can be tested on the indicated scale.

Minimum Thickness		Rockwell Scale		
in.	mm	Hardness Reading	Approximate Hardness B-Scale ^A	Hardness Reading
0.022	0.56
0.024	0.61	98	72	94
0.026	0.66	91	60	87
0.028	0.71	85	49	80
0.030	0.76	77	35	71
0.032	0.81	69	21	62
0.034	0.86	52
0.036	0.91	40
0.038	0.96	28
0.040	1.02

^A These approximate hardness numbers are for use in selecting a suitable scale and should not be used as hardness conversions. If necessary to convert test readings to another scale refer to Hardness Conversion Tables E140 (Relationship Between Brinell Hardness, Vickers Hardness, Rockwell Hardness, Rockwell Superficial Hardness and Knoop Hardness).

TABLE A5.3 A Minimum Thickness Guide for Selection of Scales Using the Diamond Indenter (see Fig. A5.1)

NOTE 1—For any given thickness, the indicated Rockwell hardness is the minimum value acceptable for testing. For a given hardness, material of any greater thickness than that corresponding to that hardness can be tested on the indicated scale.

Minimum Thickness		Rockwell Superficial Scale					
		15N		30N		45N	
in.	mm	Hardness Reading	Approximate Hardness C-Scale ^A	Hardness Reading	Approximate Hardness C-Scale ^A	Hardness Reading	Approximate Hardness C-Scale ^A
0.006	0.15	92	65
0.008	0.20	90	60
0.010	0.25	88	55
0.012	0.30	83	45	82	65	77	69.5
0.014	0.36	76	32	78.5	61	74	67
0.016	0.41	68	18	74	56	72	65
0.018	0.46	66	47	68	61
0.020	0.51	57	37	63	57
0.022	0.56	47	26	58	52.5
0.024	0.61	51	47
0.026	0.66	37	35
0.028	0.71	20	20.5
0.030	0.76


^A These approximate hardness numbers are for use in selecting a suitable scale, and should not be used as hardness conversions. If necessary to convert test readings to another scale, refer to Hardness Conversion Tables E140 (Relationship Between Brinell Hardness, Vickers Hardness, Rockwell Hardness, Rockwell Superficial Hardness and Knoop Hardness).

TABLE A5.4 A Minimum Thickness Guide for Selection of Scales Using the 1/16 in. (1.588 mm) Diameter Ball Indenter (see Fig. A5.2)

NOTE 1—For any given thickness, the indicated Rockwell hardness is the minimum value acceptable for testing. For a given hardness, material of any greater thickness than that corresponding to that hardness can be tested on the indicated scale.


Minimum Thickness		Rockwell Superficial Scale					
in.	mm	15T		30T		45T	
		Hardness Reading	Approximate Hardness B-Scale ^A	Hardness Reading	Approximate Hardness B-Scale ^A	Hardness Reading	Approximate Hardness B-Scale ^A
0.010	0.25	91	93
0.012	0.30	86	78
0.014	0.36	81	62	80	96
0.016	0.41	75	44	72	84	71	99
0.018	0.46	68	24	64	71	62	90
0.020	0.51	55	58	53	80
0.022	0.56	45	43	43	70
0.024	0.61	34	28	31	58
0.026	0.66	18	45
0.028	0.71	4	32
0.030	0.76

^A These approximate hardness numbers are for use in selecting a suitable scale, and should not be used as hardness conversions. If necessary to convert test readings to another scale refer to Hardness Conversion Tables E140 (Relationship Between Brinell Hardness, Vickers Hardness, Rockwell Hardness, Rockwell Superficial Hardness and Knoop Hardness).



NOTE 1—Locate a point corresponding to the thickness-hardness combination to be tested. Only scales falling to the left of this point may be used to test this combination.

FIG. A5.1 Thickness Limits for Rockwell Hardness Testing Using the Diamond Indenter



NOTE 1—Locate a point corresponding to the thickness-hardness combination to be tested. Only scales falling to the left of this point may be used to test this combination.

FIG. A5.2 Thickness Limits for Rockwell Hardness Testing Using the 1/16-in. (1.588-mm) Diameter Ball Indenter

A6. HARDNESS VALUE CORRECTIONS WHEN TESTING ON CONVEX CYLINDRICAL SURFACES

TABLE A6.1 Corrections to be Added to Rockwell C, A, and D Values Obtained on Convex Cylindrical Surfaces of Various Diameters^A

Dial Reading	Diameters of Convex Cylindrical Surfaces							
	1/4 in. (6.4 mm)	5/8 in. (10 mm)	1/2 in. (13 mm)	5/8 in. (16 mm)	3/4 in. (19 mm)	7/8 in. (22 mm)	1 in. (25 mm)	1 1/4 in. (32 mm)
Corrections to be Added to Rockwell C, A, and D Values ^B								
20	6.0	4.5	3.5	2.5	2.0	1.5	1.5	1.0
25	5.5	4.0	3.0	2.5	2.0	1.5	1.0	1.0
30	5.0	3.5	2.5	2.0	1.5	1.5	1.0	0.5
35	4.0	3.0	2.0	1.5	1.5	1.0	1.0	0.5
40	3.5	2.5	2.0	1.5	1.0	1.0	1.0	0.5
45	3.0	2.0	1.5	1.0	1.0	1.0	0.5	0.5
50	2.5	2.0	1.5	1.0	1.0	0.5	0.5	0.5
55	2.0	1.5	1.0	1.0	0.5	0.5	0.5	0
60	1.5	1.0	1.0	0.5	0.5	0.5	0	0
65	1.5	1.0	1.0	0.5	0.5	0.5	0	0
70	1.0	1.0	0.5	0.5	0.5	0.5	0	0
75	1.0	0.5	0.5	0.5	0.5	0	0	0
80	0.5	0.5	0.5	0.5	0	0	0	0
85	0.5	0.5	0.5	0	0	0	0	0
90	0.5	0	0	0	0	0	0	0

^A When testing cylindrical specimens, the accuracy of the test will be seriously affected by alignment of elevating screw, V-anvil, indenters, surface finish, and the straightness of the cylinder.

^B These corrections are approximate only and represent the averages to the nearest 0.5 Rockwell number, of numerous actual observations.

TABLE A6.2 Corrections to be Added to Rockwell B, F, and G Values Obtained on Convex Cylindrical Surfaces of Various Diameters^A

Hardness Reading	Diameters of Convex Cylindrical Surfaces						
	1/4 in. (6.4 mm)	5/8 in. (10 mm)	1/2 in. (13 mm)	5/8 in. (16 mm)	3/4 in. (19 mm)	7/8 in. (22 mm)	1 in. (25 mm)
Corrections to be Added to Rockwell B, F, and G Values ^B							
0	12.5	8.5	6.5	5.5	4.5	3.5	3.0
10	12.0	8.0	6.0	5.0	4.0	3.5	3.0
20	11.0	7.5	5.5	4.5	4.0	3.5	3.0
30	10.0	6.5	5.0	4.5	3.5	3.0	2.5
40	9.0	6.0	4.5	4.0	3.0	2.5	2.5
50	8.0	5.5	4.0	3.5	3.0	2.5	2.0
60	7.0	5.0	3.5	3.0	2.5	2.0	2.0
70	6.0	4.0	3.0	2.5	2.0	2.0	1.5
80	5.0	3.5	2.5	2.0	1.5	1.5	1.5
90	4.0	3.0	2.0	1.5	1.5	1.5	1.0
100	3.5	2.5	1.5	1.5	1.0	1.0	0.5

^A When testing cylindrical specimens, the accuracy of the test will be seriously affected by alignment of elevating screw, V-anvil, indenters, surface finish, and the straightness of the cylinder.

^B These corrections are approximate only and represent the averages to the nearest 0.5 Rockwell number, of numerous actual observations.

TABLE A6.3 Corrections to be Added to Rockwell Superficial 15N, 30N, and 45N Values Obtained on Convex Cylindrical Surfaces of Various Diameters^A

Hardness Reading	Diameters of Convex Cylindrical Surfaces					
	1/8 in. (3.2 mm)	1/4 in. (6.4 mm)	5/8 in. (10 mm)	1/2 in. (13 mm)	5/8 in. (19 mm)	1 in. (25 mm)
Corrections to be Added to Rockwell Superficial 15N, 30N, and 45N Values ^B						
20	6.0	3.0	2.0	1.5	1.5	1.5
25	5.5	3.0	2.0	1.5	1.5	1.0
30	5.5	3.0	2.0	1.5	1.0	1.0
35	5.0	2.5	2.0	1.5	1.0	1.0
40	4.5	2.5	1.5	1.5	1.0	1.0
45	4.0	2.0	1.5	1.0	1.0	1.0
50	3.5	2.0	1.5	1.0	1.0	0.5
55	3.5	2.0	1.5	1.0	0.5	0.5
60	3.0	1.5	1.0	1.0	0.5	0.5
65	2.5	1.5	1.0	0.5	0.5	0.5
70	2.0	1.0	1.0	0.5	0.5	0.5
75	1.5	1.0	0.5	0.5	0.5	0
80	1.0	0.5	0.5	0.5	0	0
85	0.5	0.5	0.5	0.5	0	0
90	0	0	0	0	0	0

^A When testing cylindrical specimens the accuracy of the test will be seriously affected by alignment of elevating screw, V-anvil, indenters, surface finish, and the straightness of the cylinder.

^B These corrections are approximate only and represent the averages, to the nearest 0.5 Rockwell superficial number, of numerous actual observations.

TABLE A6.4 Corrections to be Added to Rockwell Superficial 15T, 30T, and 45T Values Obtained on Convex Cylindrical Surfaces of Various Diameters^A

Hardness Reading	Diameters of Convex Cylindrical Surfaces						
	1/8 in. (3.2 mm)	1/4 in. (6.4 mm)	3/8 in. (10 mm)	1/2 in. (13 mm)	5/8 in. (16 mm)	3/4 in. (19 mm)	1 in. (25 mm)
Corrections to be Added to Rockwell Superficial 15T, 30T, and 45T Values ^B							
20	13.0	9.0	6.0	4.5	4.5	3.0	2.0
30	11.5	7.5	5.0	3.5	3.5	2.5	2.0
40	10.0	6.5	4.5	3.5	3.0	2.5	2.0
50	8.5	5.5	4.0	3.0	2.5	2.0	1.5
60	6.5	4.5	3.0	2.5	2.0	1.5	1.5
70	5.0	3.5	2.5	2.0	1.5	1.0	1.0
80	3.0	2.0	1.5	1.5	1.0	1.0	0.5
90	1.5	1.0	1.0	0.5	0.5	0.5	0.5

^A When testing cylindrical specimens, the accuracy of the test will be seriously affected by alignment of elevating screw, V-anvil, indenters, surface finish, and the straightness of the cylinder.

^B These corrections are approximate only and represent the averages to the nearest 0.5 Rockwell number, of numerous actual observations.

APPENDIXES

(Nonmandatory Information)

X1. LIST OF ASTM SPECIFICATIONS GIVING HARDNESS VALUES CORRESPONDING TO TENSILE STRENGTH

X1.1 The following ASTM standards give approximate Rockwell hardness or Rockwell superficial hardness values corresponding to the tensile strength values specified for the materials covered: Test Methods and Definitions [A370](#) and

Specifications [B19](#), [B36/B36M](#), [B96/B96M](#), [B103/B103M](#), [B121/B121M](#), [B122/B122M](#), [B130](#), [B134/B134M](#), [B152/B152M](#), and [B370](#).

X2. EXAMPLES OF PROCEDURES FOR DETERMINING ROCKWELL HARDNESS UNCERTAINTY

X2.1 Scope

X2.1.1 The intent of this appendix is to provide a basic approach to evaluating the uncertainty of Rockwell hardness measurement values in order to simplify and unify the interpretation of uncertainty by users of Rockwell hardness.

X2.1.2 This appendix provides basic procedures for determining the uncertainty of the following values of hardness:

X2.1.2.1 *The Hardness Machine “Error” Determined as Part of an Indirect Verification* (see [X2.6](#))—As part of an indirect verification, a number of Rockwell hardness measurements are made on a reference test block. The average of the measurement values is compared to the certified value of the reference block to determine the “error” (see [3.2.2](#)) of the hardness machine. The procedure described in section [X2.6](#) provides a method for determining the uncertainty in this measurement “error” of the hardness machine. The uncertainty value may be reported on the verification certificate and report.

X2.1.2.2 *Rockwell Hardness Value Measured by a User* (see [X2.7](#))—The procedure provides a method for determining the uncertainty in the hardness values measured by a user during the normal use of a Rockwell hardness machine. The user may report the uncertainty value with the measurement value.

X2.1.2.3 *Certified Value of a Rockwell Hardness Test Block* (see [X2.8](#))—The procedure provides a method for determining the uncertainty in the certified value of standardized test

blocks. The standardizing agency may report the uncertainty value on the test block certificate.

NOTE X2.1—When calculated, uncertainty values reported by a field calibration agency (see [X2.6](#)) are not the measurement uncertainties of the hardness machine in operation, but only that of the measurements made at the time of verification to determine machine “error.”

NOTE X2.2—The procedures outlined in this appendix for the determination of uncertainties are based primarily on measurements made as part of the verification and standardization procedures of this test method. This is done to provide a method that is based on familiar procedures and practices of Rockwell hardness users and standardizing agencies. The reader should be aware that there are other methods that may be employed to determine the same uncertainties, which may provide more accurate estimations of the uncertainty values.

NOTE X2.3—This standard states tolerances or limits on the acceptable repeatability and error of a Rockwell hardness machine ([Table A1.3](#)) and the nonuniformity of standardized blocks ([Table A4.2](#)). These limit values were originally established based on the testing experience of many users of the Rockwell hardness test, and therefore reflect the normal performance of a properly functioning Rockwell hardness machine, including the normal errors associated with the measurement procedure and the machine’s performance. Because the limits are based on testing experience, it is believed that the stated limit values take into account a level of uncertainty that is typical for valid Rockwell hardness measurements. Consequently, when determining compliance with [Table A1.3](#) and [Table A4.2](#), the user’s measurement uncertainty should not be subtracted from the tolerance limit values given in the tables, as is commonly done for other types of metrological measurements. The calculated values for repeatability, error or block nonuniformity should be directly compared to the tolerance limits given in the tables.

NOTE X2.4—Most product specification tolerances for Rockwell hardness were established based on testing and performance experience. The

tolerance values reflect the normal performance of a properly functioning Rockwell hardness machine, including the normal acceptable errors associated with the hardness measurement process. For these products, the stated tolerance limits take into account a level of uncertainty that is typical for valid Rockwell hardness measurements. Consequently, when acceptance testing most products for Rockwell hardness, the user's measurement uncertainty should not be subtracted from the tolerance limit values given in the specification. The measured hardness values should be directly compared to the tolerances. There may be exceptional circumstances where the hardness of a product must fall within determined ranges to a high level of confidence. In these rare occasions, special agreement between the parties involved should be obtained before the hardness measurement uncertainty is subtracted from the tolerance limits. Before such an agreement is made, it is recommended that the product design take into consideration the anticipated influence of material and metallurgical factors on the product variation as well as typical industry hardness uncertainty values.

X2.1.3 This appendix does not address uncertainties at the primary reference standardizing level.

X2.2 Equations

X2.2.1 The average (AVG), \bar{H} , of a set of n hardness measurements H_1, H_2, \dots, H_n is calculated as:

$$\text{AVG}(H_1, H_2, \dots, H_n) = \bar{H} = \frac{H_1 + H_2 + \dots + H_n}{n} \quad (\text{X2.1})$$

X2.2.2 The standard deviation (STDEV) of a set of n hardness measurements H_1, H_2, \dots, H_n is calculated as:

$$\text{STDEV}(H_1, H_2, \dots, H_n) = \sqrt{\frac{(H_1 - \bar{H})^2 + \dots + (H_n - \bar{H})^2}{n - 1}} \quad (\text{X2.2})$$

where \bar{H} is the average of the set of n hardness measurements H_1, H_2, \dots, H_n as defined in Eq X2.1.

X2.2.3 The absolute value (ABS) of a number is the magnitude of the value irrespective of the sign, for example:

$$\text{ABS}(0.12) = 0.12$$

and

$$\text{ABS}(-0.12) = 0.12$$

X2.3 General Requirements

X2.3.1 The approach for determining uncertainty presented in this appendix considers only those uncertainties associated with the overall measurement performance of the Rockwell hardness machine with respect to reference standards. These performance uncertainties reflect the combined effect of the separate uncertainties associated with the numerous individual components of the machine, such as the force application system and indentation depth measuring system. Therefore, the uncertainties associated with the individual components of the machine are not included in the calculations. Because of this approach, it is important that the individual machine components are operating within tolerances. It is strongly recommended that this procedure be applied only after successfully passing a direct verification.

X2.3.2 The procedures given in this appendix are appropriate only when the Rockwell hardness machine has passed an indirect verification in accordance with the procedures and schedules of this test method standard.

X2.3.3 The procedures for calculating the uncertainty of Rockwell hardness measurement values are similar for both a standardizing machine and testing machine. The principal difference is in the hierarchy level of the reference test blocks normally used for the indirect verification. Generally, standardizing machines are verified using primary reference standards, and testing machines are standardized using secondary reference standards.

X2.3.4 To estimate the overall uncertainty of Rockwell hardness measurement values, contributing components of uncertainty must be determined. Because many of the uncertainties may vary depending on the specific hardness scale and hardness level, an individual measurement uncertainty should be determined for each hardness scale and hardness level of interest. In many cases, a single uncertainty value may be applied to a range of hardness levels based on the laboratory's experience and knowledge of the operation of the hardness machine.

X2.3.5 Uncertainty should be determined with respect to a country's highest level of reference standard or the national reference standard of another country. In some cases, the highest level of reference standard may be a commercial reference standard.

X2.4 General Procedure

X2.4.1 This procedure calculates a combined standard uncertainty u_c by combining the contributing components of uncertainty u_1, u_2, \dots, u_n , such that:

$$u_c = \sqrt{u_1^2 + u_2^2 + \dots + u_n^2} \quad (\text{X2.3})$$

X2.4.2 Measurement uncertainty is usually expressed as an expanded uncertainty U which is calculated by multiplying the combined standard uncertainty u_c by a numerical coverage factor k , such that:

$$U = k \times u_c \quad (\text{X2.4})$$

X2.4.3 A coverage factor is chosen that depends on how well the standard uncertainty was estimated (number of measurements), and the level of uncertainty that is desired. For this analysis, a coverage factor of $k = 2$ should be used. This coverage factor provides a confidence level of approximately 95 %.

X2.4.4 The measurement bias B of the hardness machine is the difference between the expected hardness measurement values as displayed by the hardness machine and the "true" hardness of a material. Ideally, measurement biases should be corrected. When test systems are not corrected for measurement bias, as often occurs in Rockwell hardness testing, the bias then contributes to the overall uncertainty in a measurement. There are a number of possible methods for incorporating biases into an uncertainty calculation, each of which has both advantages and disadvantages. A simple and conservative method is to combine the bias with the calculation of the expanded uncertainty as:

$$U = ku_c + \text{ABS}(B) \quad (\text{X2.5})$$

where $\text{ABS}(B)$ is the absolute value of the bias.

X2.4.5 Because several approaches may be used to evaluate and express measurement uncertainty, a brief description of what the reported uncertainty values represent should be included with the reported uncertainty value.

X2.5 Sources of Uncertainty

X2.5.1 This section describes the most significant sources of uncertainty in a Rockwell hardness measurement and provides procedures and formulas for calculating the total uncertainty in the hardness value. In later sections, it will be shown how these sources of uncertainty contribute to the total measurement uncertainty for the three measurement circumstances described in X2.1.2.

X2.5.2 The sources of uncertainty to be discussed are (1) the hardness machine's lack of repeatability, (2) the non-uniformity in hardness of the material under test, (3) the hardness machine's lack of reproducibility, (4) the resolution of the hardness machine's measurement display, and (5) the uncertainty in the certified value of the reference test block standards. An estimation of the measurement bias and its inclusion into the expanded uncertainty will also be discussed.

X2.5.3 Uncertainty Due to Lack of Repeatability (u_{Repeat}) and when Combined with Non-uniformity ($u_{\text{Rep\& NU}}$)—The repeatability of a hardness machine is an indication of how well it can continually produce the same hardness value each time a measurement is made. Imagine there is a material, which is perfectly uniform in hardness over its entire surface. Also imagine that hardness measurements are made repeatedly on this uniform material over a short period of time without varying the testing conditions (including the operator). Even though the actual hardness of every test location is exactly the same, it would be found that due to random errors each measurement value would differ from all other measurement values (assuming sufficient measurement resolution). Therefore, lack of repeatability prevents the hardness machine from being able to always measure the true hardness of the material, and hence contributes to the uncertainty in the measurement.

X2.5.3.1 The contribution that a hardness machine's lack of repeatability makes to the overall measurement uncertainty is determined differently depending on whether a single measurement value or an average of multiple measurements is to be reported. Additionally, in cases where the reported average measurement value is intended to be an estimate of the average hardness of the material tested, the uncertainty contributions due to the machine's lack of repeatability and the non-uniformity in the hardness of the test material are difficult to separate and must be determined together. The uncertainty contributions for each of these circumstances may be estimated as follows.

X2.5.3.2 Single Hardness Measurement—For a future single hardness measurement, the standard uncertainty contribution u_{Repeat} due to the lack of repeatability, may be estimated by the standard deviation of the values from a number of hardness measurements made on a uniform test sample as:

$$u_{\text{Repeat}} = \text{STDEV}(H_1, H_2, \dots, H_n) \quad (\text{X2.6})$$

where H_1, H_2, \dots, H_n are the n hardness values. In general, the estimate of repeatability is improved as the number of hardness measurements is increased. Usually, the hardness values measured during an indirect verification will provide an adequate estimate of u_{Repeat} ; however, the caution given in Note X2.6 should be considered. It may be more appropriate for the user to determine a value of u_{Repeat} by making hardness measurements close together (within spacing limitations) on a uniform material, such as a test block.

NOTE X2.5—The uncertainty u_{Repeat} , due to the lack of repeatability of a hardness machine as discussed above, should not be confused with the historically defined “repeatability” that is a requirement to be met as part of an indirect verification (see 3.2.3). The calculations of the uncertainty u_{Repeat} and of the historically defined repeatability do not produce the same value. The uncertainty u_{Repeat} is the contribution to the overall uncertainty of a hardness measurement value due to a machine's lack of repeatability, while the historically defined repeatability is the range of hardness values measured during an indirect verification.

NOTE X2.6—All materials exhibit some degree of hardness non-uniformity across the test surface. Therefore, the above evaluation of the uncertainty contribution due to the lack of repeatability will also include a contribution due to the hardness non-uniformity of the measured material. When evaluating repeatability as discussed above, any uncertainty contribution due to the hardness non-uniformity should be minimized as much as possible. The laboratory should be cautioned that if the measurements of repeatability are based on tests made across the surface of the material, then the repeatability value will likely include a significant uncertainty contribution due to the material's non-uniformity. A machine's repeatability is better evaluated by making hardness measurements close together (within spacing limitations).

X2.5.3.3 Average of Multiple Measurements—When the average of multiple hardness test values is to be reported, the standard uncertainty contribution $u_{\overline{\text{Repeat}}}$, due to the lack of repeatability of the hardness machine, may be estimated by dividing the standard uncertainty contribution u_{Repeat} (previously calculated from a number of hardness measurements made on a uniform test sample, see X2.5.3.1) by the square-root of the number of hardness test values being averaged, as:

$$u_{\overline{\text{Repeat}}} = \frac{u_{\text{Repeat}}}{\sqrt{n_T}} \quad (\text{X2.7})$$

where u_{Repeat} is calculated by Eq X2.6 and n_T is the number of individual hardness test values being averaged.

X2.5.3.4 Estimate of the Material Hardness—Hardness measurements are often made at several locations and the values averaged in order to estimate the average hardness of the material as a whole. For example, this may be done when making quality control measurements during the manufacture of many types of products; when determining the machine “error” as part of an indirect verification; and when calibrating a test block. Because all materials exhibit some degree of hardness non-uniformity across the test surface, the extent of a material's non-uniformity also contributes to the uncertainty in this estimate of the average hardness of the material. When the average of multiple hardness measurement values is calculated as an estimate of the average material or product hardness, it may be desired to state the uncertainty in this value with respect to the true hardness of the material. In this case, the combined uncertainty contributions due to the lack of repeatability in the hardness machine and the non-uniformity in the test material may be estimated from the “standard deviation of

the mean” of the hardness measurement values. This is calculated as the standard deviation of the hardness values, divided by the square-root of the number of measurements as:

$$u_{Rep\& NU} = \frac{STDEV(H_{T1}, H_{T2}, \dots, H_{Tn})}{\sqrt{n_T}} \quad (\text{X2.8})$$

where $H_{T1}, H_{T2}, \dots, H_{Tn}$ are the n_T measurement values.

X2.5.4 Uncertainty Due to Lack of Reproducibility (u_{Reprod})—The day-to-day variation in the performance of the hardness machine is known as its level of reproducibility. Variations such as different machine operators and changes in the test environment often influence the performance of the hardness machine. The level of reproducibility is best determined by monitoring the performance of the hardness machine over an extended period of time during which the hardness machine is subjected to the extremes of variations in the testing variables. It is very important that the test machine be in control during the assessment of reproducibility. If the machine is in need of maintenance or is operated incorrectly, the lack of reproducibility will be over estimated.

X2.5.5 An assessment of a hardness machine’s lack of reproducibility should be based on periodic monitoring measurements of the hardness machine, such as daily verification measurements made on the same test block over time. The uncertainty contribution may be estimated by the standard deviation of the average of each set of monitoring values, as:

$$u_{Reprod} = STDEV(M_1, M_2, \dots, M_n) \quad (\text{X2.9})$$

where M_1, M_2, \dots, M_n are individual averages of each of the n sets of multiple monitoring measurement values.

NOTE X2.7—The uncertainty contribution due to the lack of reproducibility, as calculated in Eq X2.10, also includes a contribution due to the machine’s lack of repeatability and the non-uniformity of the monitoring test block; however, these contributions are based on the average of multiple measurements and should not significantly overestimate the reproducibility uncertainty.

X2.5.6 Uncertainty Due to the Resolution of the Hardness Measurement Display (u_{Resol})—The finite resolution of the hardness value display prevents the hardness machine from providing an absolutely accurate hardness value. However, the influence of the display resolution on the measurement uncertainty is usually only significant when the hardness display resolution is no better than 0.5 Rockwell hardness units, such as for some dial displays. The uncertainty contribution u_{Resol} , due to the influence of the display resolution, may be described by a rectangular distribution and estimated as:

$$u_{Resol} = \frac{r/2}{\sqrt{3}} = \frac{r}{\sqrt{12}} \quad (\text{X2.10})$$

where r is the resolution limit that a hardness value can be estimated from the measurement display in Rockwell hardness units.

X2.5.7 Standard Uncertainty in the Certified Average Hardness Value of the Reference Test Block (u_{RefBlk})—Reference test blocks provide the link to the Rockwell standard to which traceability is claimed. The certificate accompanying reference test blocks should provide an uncertainty in the stated certified value, and should state to which Rockwell standard the

reference test block value is traceable. This uncertainty contributes to the measurement uncertainty of hardness machines calibrated or verified with the reference test blocks. Note that the uncertainty reported on reference test block certificates is typically stated as an expanded uncertainty. As indicated by Eq X2.4, the expanded uncertainty is calculated by multiplying the standard uncertainty by a coverage factor (often 2). This analysis uses the standard uncertainty and not the expanded uncertainty value. Thus, the uncertainty value due to the uncertainty in the certified value of the reference test block usually may be calculated as:

$$u_{RefBlk} = \frac{U_{RefBlk}}{k_{RefBlk}} \quad (\text{X2.11})$$

where U_{RefBlk} is the reported expanded uncertainty of the certified value of the reference test block, and k_{RefBlk} is the coverage factor used to calculate the uncertainty in the certified value of the reference standard (usually 2).

X2.5.8 Measurement Bias (B)—The measurement bias is the difference between the hardness measurement values as displayed by the hardness machine and the “true” hardness of a material. The measurement bias B may be estimated by the “error” determined as part of the indirect verification as:

$$B = \bar{H} - \bar{H}_{RefBlk} \quad (\text{X2.12})$$

where \bar{H} is the mean hardness value as measured by the hardness machine during the indirect verification, and \bar{H}_{RefBlk} is the certified average hardness value of the reference test block standard used for the indirect verification.

X2.6 Procedure for Calculating Uncertainty: Indirect Verification

X2.6.1 As part of an indirect verification, the “error” of the hardness machine is determined from the average value of measurements made on a reference test block (see 3.2.2). This value provides an indication of how well the hardness machine can measure the “true” hardness of a material. Since there is always uncertainty in a hardness measurement, it follows that there must be uncertainty in the determination of the average value of the measurements, and thus the determination of the machine “error.” This section provides a procedure that can be used, for example by a field calibration agency, to estimate the uncertainty U_{Mach} in the measurement “error” of the hardness machine determined as the difference between the average of the measurement values and the certified value of the reference block used for the verification.

X2.6.2 The contributions to the standard uncertainty of the measurement “error,” u_{Mach} , are (1) $u_{Rep\& NU}(\text{Ref. Block})$, the uncertainty due to the lack of repeatability of the hardness machine combined with the uncertainty due to the non-uniformity in the reference test block (Eq X2.9), which is determined from the hardness measurements made on a reference test block to determine the “error” of the hardness machine, (2) u_{Resol} , the uncertainty due to the resolution of the hardness machine measurement display (Eq X2.11), and (3) u_{RefBlk} , the standard uncertainty in the certified value of the reference test block (Eq X2.12). The notation (Ref. Block) is added to the term $u_{Rep\& NU}$ to clarify that the uncertainty is

determined from measurements made on the reference block used for the indirect verification.

X2.6.3 The combined standard uncertainty u_{Mach} and the expanded uncertainty U_{Mach} are calculated by combining the appropriate uncertainty components described above for each hardness level of each Rockwell scale as:

$$u_{Mach} = \sqrt{u_{Rep\& NU}^2(Ref. Block) + u_{Resol}^2 + u_{RefBlk}^2} \quad (X2.13)$$

and

$$U_{Mach} = k u_{Mach} \quad (X2.14)$$

X2.6.4 For this analysis, a coverage factor of $k = 2$ should be used. This coverage factor provides a confidence level of approximately 95 %.

NOTE X2.8—The uncertainty contribution u_{Mach} as calculated in Eq X2.14 does not include a contribution due to the machine's lack of reproducibility. This is because it is assumed that the indirect verification is made while the hardness machine is operating at its optimal performance level with the best possible environmental conditions.

NOTE X2.9—The expanded uncertainty U_{Mach} will commonly be larger than the value of the hardness machine "error."

X2.6.5 *Reporting the Measurement Uncertainty*—This expanded uncertainty U_{Mach} may be reported by a verification agency to its customer as an indication of the uncertainty in the hardness machine "error" reported as part of the indirect verification of the Rockwell hardness machine. The value of U_{Mach} should be supplemented with a statement defining to what Rockwell scale and hardness level the uncertainty is applicable, with an explanatory statement such as, "The expanded uncertainty of the hardness machine "error" reported as part of the indirect verification for the stated Rockwell scale(s) and hardness level(s) is with respect to Rockwell hardness reference standards maintained at _____ (for example, NIST), and was calculated in accordance with Appendix X2 of ASTM E18 with a coverage factor of 2 representing a confidence level of approximately 95 %."

X2.6.6 The standard uncertainty value u_{Mach} can be used as an uncertainty contribution when determining the measurement uncertainty of future measurements made with the hardness machine (see X2.7 and X2.8).

X2.6.7 *Example X2.1*—As part of an indirect verification of a Rockwell hardness machine, a verification agency needs to report an estimate of the uncertainty of the hardness machine "error." For this example, an evaluation will only be made for measurements made on the low range of the HRC scale. The hardness machine has a digital display with a resolution of 0.1 HRC. The agency performs five verification measurements on a low range HRC hardness block. The reported certified value of the reference test block is 25.7 HRC with an expanded uncertainty of $U_{RefBlk} = 0.45$ HRC. The five verification measurements values are: 25.4, 25.3, 25.5, 25.3, and 25.7 HRC, resulting in an average value of 25.44 HRC, a repeatability (range) value of 0.4 HRC and an "error" of -0.26 HRC. Therefore:

$$u_{Rep\& NU}(Ref. Block) = \frac{STDEV(25.4, 25.3, 25.5, 25.3, 25.7)}{\sqrt{5}}$$

or $u_{Rep\& NU}(Ref. Block) = 0.075$ HRC

$$u_{Resol} = \frac{0.1}{\sqrt{12}} = 0.029 \text{ HRC, and}$$

$$u_{RefBlk} = \frac{0.45}{2} = 0.225 \text{ HRC}$$

Thus,

$$u_{Mach} = \sqrt{0.075^2 + 0.029^2 + 0.225^2} = 0.239 \text{ HRC, and}$$

$$U_{Mach} = (2 \times 0.239) = 0.48 \text{ HRC}$$

Therefore, the uncertainty in the -0.26 HRC "error" in the hardness machine is 0.48 HRC. Although this evaluation was made on material having a hardness of approximately 25 HRC, the uncertainty may be considered to apply to the entire low range of the HRC scale. This calculation must be made for the mid and high ranges of the HRC scale, as well as for the ranges of the other Rockwell scales that are verified.

NOTE X2.10—The reader should be aware that in computing the final uncertainty value in all examples in this appendix, no rounding of results was done between steps. Consequently, if individual equations are solved using the rounded values that are given at each step of this example, some computed results might differ in value in the last decimal place from the results stated.

X2.7 Procedure for Calculating Uncertainty: Rockwell Hardness Measurement Values

X2.7.1 The uncertainty U_{Meas} in a hardness value measured by a user may be thought of as an indication of how well the measured value agrees with the "true" value of the hardness of the material.

X2.7.2 *Single Measurement Value*—When measurement uncertainty for a single hardness measurement value is to be determined, the contributions to the standard uncertainty u_{Meas} are (1) u_{Repeat} , the uncertainty due to the machine's lack of repeatability (Eq X2.6), (2) u_{Reprod} , the uncertainty contribution due to the lack of reproducibility (Eq X2.10), (3) u_{Resol} , the uncertainty due to the resolution of the hardness machine measurement display (Eq X2.11), and (4) u_{Mach} , the uncertainty in determining the "error" of the hardness machine (Eq X2.14). The combined standard uncertainty u_{Meas} is calculated by combining the appropriate uncertainty components described above for the applicable hardness level and Rockwell scale as:

$$u_{Meas} = \sqrt{u_{Repeat}^2 + u_{Reprod}^2 + u_{Resol}^2 + u_{Mach}^2} \quad (X2.15)$$

X2.7.3 *Average Measurement Value*—In the case that measurement uncertainty is to be determined for an average value of multiple hardness measurements, made either on the same test piece or multiple test pieces, the contributions to the standard uncertainty u_{Meas} are (1) u_{Repeat} , the uncertainty due to the machine's lack of repeatability based on the average of multiple measurements (Eq X2.8), (2) u_{Reprod} , the uncertainty contribution due to the lack of reproducibility (Eq X2.10), (3) u_{Resol} , the uncertainty due to the resolution of the hardness machine measurement display (Eq X2.11), and (4) u_{Mach} , the uncertainty in determining the "error" of the hardness machine (Eq X2.14). The combined standard uncertainty u_{Meas} is calculated by combining the appropriate uncertainty components described above for the applicable hardness level and Rockwell scale as:

$$u_{Meas} = \sqrt{u_{Repeat}^2 + u_{Reprod}^2 + u_{Resol}^2 + u_{Mach}^2} \quad (X2.16)$$

X2.7.4 The measurement uncertainty discussed above for the single and average hardness values only represents the uncertainties of the measurement process and are independent of any test material non-uniformity.

X2.7.5 *Average Measurement Value as an Estimate of the Average Material Hardness*—Measurement laboratories and manufacturing facilities often measure the Rockwell hardness of a test sample or product for the purpose of estimating the average hardness of the test material. Usually, multiple hardness measurements are made across the surface of the test piece, and then the average of the hardness values is reported as an estimation of the average hardness of the material. If it is desired to report the uncertainty as an indication of how well the average measurement value represents the true average hardness of the material, then the contributions to the standard uncertainty u_{Meas} are (1) $u_{Rep\& NU}(\text{Material})$, the uncertainty due to the machine's lack of repeatability combined with the uncertainty due to the material's non-uniformity (Eq X2.9), which is determined from the hardness measurements made on the test material, (2) u_{Reprod} , the uncertainty contribution due to the lack of reproducibility (Eq X2.10), (3) u_{Resol} , the uncertainty due to the resolution of the hardness machine measurement display (Eq X2.11), and (4) u_{Mach} , the uncertainty in determining the “error” of the hardness machine (Eq X2.14). The notation (*Material*) is added to the term $u_{Rep\& NU}$ to clarify that the uncertainty is determined from measurements made on the material under test. The combined standard uncertainty u_{Meas} is calculated by combining the appropriate uncertainty components described above for the applicable hardness level and Rockwell scale as:

$$u_{Meas} = \sqrt{u_{Rep\& NU}^2(\text{Material}) + u_{Reprod}^2 + u_{Resol}^2 + u_{Mach}^2} \quad (\text{X2.17})$$

X2.7.6 When reporting uncertainty as an indication of how well the average measurement value represents the true average hardness of the material, it is important to assure that a sufficient number of measurements are made at the appropriate test locations to provide an appropriate sampling of any variations in the hardness of the material.

X2.7.7 The expanded uncertainty U_{Meas} is calculated for the three cases discussed above as:

$$U_{Meas} = k u_{Meas} + ABS(B) \quad (\text{X2.18})$$

For this analysis, a coverage factor of $k = 2$ should be used. This coverage factor provides a confidence level of approximately 95 %.

X2.7.8 Reporting Measurement Uncertainty:

X2.7.8.1 *Single and Average Measurement Values*—When the reported measurement value is for a single hardness test or the average of multiple hardness tests, then the value of U_{Meas} should be supplemented with an explanatory statement such as, “The expanded measurement uncertainty of the reported hardness value (or average hardness value) is with respect to Rockwell hardness reference standards maintained at _____ [for example, NIST], and was calculated in accordance with Appendix X2 of ASTM E18 with a coverage factor of 2 representing a confidence level of approximately 95 %.”

X2.7.8.2 *Average Measurement Value as an Estimate of the Average Material Hardness*—When it is desired to report the

uncertainty as an indication of how well the average measurement value represents the true average hardness of the material, then the value of U_{Meas} should be supplemented with an explanatory statement such as, “The expanded uncertainty of the reported average hardness of the material under test is based on uncertainty contributions from the measurement process and from the hardness non-uniformity of the material. The uncertainty is with respect to Rockwell hardness reference standards maintained at _____ [for example, NIST], and was calculated in accordance with Appendix X2 of ASTM E18 with a coverage factor of 2 representing a confidence level of approximately 95 %.” If the test report does not state the number of measurements that were averaged and the locations that the measurements were made, then this information should also be included as part of the brief explanation of how the uncertainty was calculated.

X2.7.8.3 *Example X2.2*—For this example, a company tests its product by making six Rockwell hardness measurements across its surface as an estimate of the product hardness. The hardness machine has a dial display that is judged to have a reading resolution of 0.5 HRC. The values of the hardness measurements of the product were 33, 31.5, 31.5, 32, 31, 32.5, resulting in an average value of 31.92 HRC. The testing facility would like to determine the measurement uncertainty in the average hardness value. A hardness of 31.92 HRC is closest to the low range of the HRC scale (see Table A1.3). The last indirect verification of the low range of the HRC scale reported $U_{Mach} = 0.8$ HRC and an “error” of -0.3 HRC. Therefore:

$$u_{Rep\& NU}(\text{Material}) = \frac{STDEV(33, 31.5, 31.5, 32, 31, 32.5)}{\sqrt{6}} \text{ or} \\ u_{Rep\& NU}(\text{Material}) = 0.300 \text{ HRC}$$

For this example, assume the hardness machine has been monitored for an extended period of time, and from Eq X2.10, it was determined that $u_{Reprod} = 0.21$ HRC for the low range of the HRC scale. Other uncertainty contributions are calculated as:

$$u_{Resol} = \frac{0.5}{\sqrt{12}} = 0.144 \text{ HRC and} \\ u_{Mach} = \frac{0.8}{2} = 0.4 \text{ HRC, therefore} \\ u_{Meas} = \sqrt{0.300^2 + 0.21^2 + 0.144^2 + 0.4^2} = 0.561 \text{ HRC}$$

and since $B = -0.3$ HRC, $U_{Meas} = (2 \times 0.561) + ABS(-0.3)$, or $U_{Meas} = 1.42$ HRC for the average value of the hardness measurements made on the single product item.

X2.8 Procedure for Calculating Uncertainty: Certified Value of Standardized Test Blocks

X2.8.1 Standardizing laboratories engaged in the calibration of reference test blocks must determine the uncertainty in the reported certified value. This uncertainty UCert provides an indication of how well the certified value would agree with the “true” average hardness of the test block.

X2.8.2 Test blocks are certified as having an average hardness value based on calibration measurements made across the surface of the test block. This analysis is essentially identical to the analysis given in 5.3.1 for measuring the

average hardness of a product. In this case, the product is a calibrated reference test block. The contributions to the standard uncertainty u_{Cert} of the certified average value of the test block are (1) $u_{Rep\& NU}$ (*Calib. Block*), the uncertainty due to the standardizing machine's lack of repeatability combined with the uncertainty due to the calibrated block's non-uniformity (**Eq X2.9**), which is determined from the calibration measurements made on the test block, (2) u_{Reprod} , the uncertainty contribution due to the lack of reproducibility (**Eq X2.10**), (3) u_{Resol} , the uncertainty due to the resolution of the standardizing machine's measurement display (**Eq X2.11**), and (4) u_{Mach} , the uncertainty in determining the "error" of the standardizing machine (**Eq X2.14**). The notation (*Calib. Block*) is added to the term $u_{Rep\& NU}$ to clarify that the uncertainty is determined from calibration measurements made on the calibrated block.

X2.8.3 The combined standard uncertainty u_{Cert} and the expanded uncertainty U_{Cert} are calculated by combining the appropriate uncertainty components described above for each hardness level of each Rockwell scale as:

$$u_{Cert} = \sqrt{u_{Rep\& NU}^2(\text{Calib. Block}) + u_{Reprod}^2 + u_{Resol}^2 + u_{Mach}^2} \quad (\text{X2.19})$$

and

$$U_{Cert} = k u_{Cert} + ABS(B) \quad (\text{X2.20})$$

X2.8.4 For this analysis, a coverage factor of $k = 2$ should be used. This coverage factor provides a confidence level of approximately 95 %.

X2.8.5 *Reporting the Measurement Uncertainty*—The value of U_{Cert} is an estimate of the uncertainty in the reported certified average hardness value of a reference test block. The reported value should be supplemented with a statement defining to what Rockwell scale and hardness level the uncertainty is applicable, with an explanatory statement such as, "The expanded uncertainty in the certified value of the test block is with respect to Rockwell hardness reference standards

maintained at _____ [for example, NIST], and was calculated in accordance with Appendix X2 of ASTM E18 with a coverage factor of 2 representing a confidence level of approximately 95 %."

X2.8.6 *Example X2.3*—A secondary level test-block standardizing laboratory has completed the calibration of a test block in the hardness range of 40 HRC. The values of the calibration measurements of the block were 40.61, 40.72, 40.65, 40.61, and 40.55 HRC, resulting in an average value of 40.63 HRC and an E18 repeatability range of 0.17 HRC. The laboratory must determine the uncertainty in the certified average hardness value of the block. A hardness of 40 HRC is considered within the mid-range of the HRC scale (see **Table A1.3**). The last indirect verification of the mid range of the HRC scale reported $U_{Mach} = 0.16$ HRC and an "error" of +0.11 HRC. The standardizing machine has a digital display with a resolution of 0.01 HRC. Therefore:

$$u_{Rep\& NU}(\text{Calib. Block}) = \frac{STDEV(40.61, 40.72, 40.65, 40.61, 40.55)}{\sqrt{5}} \text{ or} \\ u_{Rep\& NU}(\text{Calib. Block}) = 0.028 \text{ HRC}$$

For this example, let's assume that the standardizing machine has been monitored for an extended period of time, and from **Eq X2.10**, it was determined that $u_{Reprod} = 0.125$ HRC for the mid range of the HRC scale. Other uncertainty contributions are calculated as:

$$u_{Resol} = \frac{0.01}{\sqrt{12}} = 0.003 \text{ HRC and} \\ u_{Mach} = \frac{0.16}{2} = 0.08 \text{ HRC therefore,} \\ u_{Cert} = \sqrt{0.028^2 + 0.125^2 + 0.003^2 + 0.08^2} = 0.151 \text{ HRC}$$

and, since $B = +0.11$ HRC, $U_{Cert} = (2 \times 0.151) + ABS(+0.11)$, or $U_{Cert} = 0.41$ HRC for the certified hardness value of the single calibrated test block.

SUMMARY OF CHANGES

Committee E28 has identified the location of selected changes to this standard since the last issue (E18–14a) that may impact the use of this standard. (Approved February 1, 2015.)

(1) **A1.5.3.4** was revised.

Committee E28 has identified the location of selected changes to this standard since the last issue (E18–14) that may impact the use of this standard. (Approved Oct. 1, 2014.)

(1) **A3.9.1.6** was revised.

(2) **A3.9.3.6** was revised.

Committee E28 has identified the location of selected changes to this standard since the last issue (E18–12) that may impact the use of this standard. (Approved Jan. 1, 2014.)

(1) **A3.4.5.1** was revised.
 (2) **A3.4.5.4** was revised.

(3) **A3.5.3.2** was revised.
 (4) **A3.5.3.7** was revised.

- (5) A3.8.2 was added.
- (6) A3.8.3 was added.
- (7) A3.9.1.6 was added.

- (8) A3.9.3.6 was added.
- (9) New Table A3.4 was added.
- (10) New Table A3.7 was added.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; <http://www.copyright.com/>

Anexo 3. Norma NTC - 2.

NORMA TÉCNICA COLOMBIANA

NTC
2

1995-11-29

SIDERURGIA. ENSAYO DE TRACCIÓN PARA MATERIALES METÁLICOS. MÉTODO DE ENSAYO A TEMPERATURA AMBIENTE



MINISTERIO DE DESARROLLO ECONÓMICO

E: SIDERURGY. TENSILE TESTING OF METALLIC MATERIALS.
METHOD OF TEST AT AMBIENT TEMPERATURE

CORRESPONDENCIA: esta norma es idéntica a la BS EN
10002-1

DESCRIPTORES: ensayo; tracción; tensión; metal;
temperatura; ambiente.

I.C.S: 77.040.10

Editada por el Instituto Colombiano de Normas Técnicas y Certificación (ICONTEC)
Apartado 14237 Bogotá, D.C. - Tel. 6078888 - Fax 2221435

Prohibida su reproducción

Tercera actualización

PRÓLOGO

El Instituto Colombiano de Normas Técnicas y Certificación, **ICONTEC**, es el organismo nacional de normalización, según el Decreto 2269 de 1993.

ICONTEC es una entidad de carácter privado, sin ánimo de lucro, cuya Misión es fundamental para brindar soporte y desarrollo al productor y protección al consumidor. Colabora con el sector gubernamental y apoya al sector privado del país, para lograr ventajas competitivas en los mercados interno y externo.

La representación de todos los sectores involucrados en el proceso de Normalización Técnica está garantizada por los Comités Técnicos y el período de Consulta Pública, este último caracterizado por la participación del público en general.

La NTC 2 (Tercera actualización) fue ratificada por el Consejo Directivo de 1995-11-29.

Esta norma está sujeta a ser actualizada permanentemente con el objeto de que responda en todo momento a las necesidades y exigencias actuales.

En consulta Pública el proyecto se puso a consideración de las siguientes empresas:

ACERÍAS DE CALDAS (ACASA) S.A.	SIDERÚRGICA DE BOYACÁ S.A.
ACERÍAS DE COLOMBIA S.A.	SIDERÚRGICA DE MEDELLÍN S.A.
ACERÍAS PAZ DEL RÍO S.A.	SIDERÚRGICA DEL MUÑA S.A.
CONSORCIO METALÚRGICO NACIONAL S.A.	SIDERÚRGICA DEL NORTE S.A.
COLMENA	SIDERÚRGICA DEL PACÍFICO S.A.
DIACO LTDA.	SIDERÚRGICA HORNOS NACIONAL S.A.
FÁBRICA DE TORNILLOS Y REMACHES GUTEMBERTO LTDA.	SUPERINTENDENCIA DE INDUSTRIA Y COMERCIO
MINISTERIO DE DESARROLLO ECONÓMICO	TUBOS DEL CARIBE S.A.

ICONTEC cuenta con un Centro de Información que pone a disposición de los interesados normas internacionales, regionales y nacionales.

DIRECCIÓN DE NORMALIZACIÓN

**SIDERURGIA.
ENSAYO DE TRACCIÓN PARA MATERIALES
MÉTALICOS. MÉTODO DE ENSAYO A
TEMPERATURA AMBIENTE**

1. OBJETO Y CAMPO DE APLICACIÓN

Esta norma especifica el método para el ensayo de tensión de materiales metálicos y define las propiedades mecánicas que se pueden determinar a temperatura ambiente.

Para ciertos materiales metálicos y aplicaciones particulares, el ensayo de tensión debe estar sujeto a normas específicas o requerimientos particulares.

2. REFERENCIAS

EN 10 002-2: Materiales metálicos; Ensayo de tensión. Parte 2. Verificación de las máquinas de ensayo de tensión.

ISO 2566-1: 1984, Acero. Conversión de los valores de elongación. Parte 1. Aceros al carbono y de baja aleación.

ISO 2566-2: 1984, Acero. Conversión de los valores de elongación. Parte 2. Aceros austeníticos.

ISO/DIS 9513: Materiales metálicos. Verificación de extensómetros usados en ensayo uniaxial.

EU 18: 1979, Selección y preparación de muestras y probetas de ensayo para aceros, fundiciones de hierro y productos de acero.

3. PRINCIPIO

El ensayo comprende el alargamiento de una probeta de ensayo por fuerza de tensión, generalmente hasta la rotura, con el propósito de determinar una o más de las propiedades mecánicas definidas en el capítulo 4.

El ensayo se lleva a cabo a temperatura ambiente entre 10 °C y 35 °C, a menos que se especifique de otra manera. Los ensayos que se realizan bajo condiciones controladas se efectúan a temperaturas de 23 °C ± 5 °C.

4. DEFINICIONES

Para los propósitos de esta norma, se aplican las siguientes definiciones:

4.1 Longitud Calibrada (L): es la longitud de la sección cilíndrica o prismática de la probeta de ensayo en la que se va a medir la elongación en cualquier momento durante el ensayo.

Particularmente se hace una distinción entre:

4.1.1 Longitud Calibrada Inicial (L_o): longitud calibrada antes de la aplicación de la carga.

4.1.2 Longitud Calibrada Final (L_u): longitud calibrada después de la rotura de la probeta ensayo (véase el numeral 11.1).

4.2 Longitud Paralela (L_c): longitud de la sección reducida paralela de la probeta de ensayo.

Nota. El concepto de longitud paralela es reemplazado por el concepto de distancia entre marcas para probetas no maquinadas.

4.3 Elongación: incremento de la longitud calibrada inicial (L_o) al final del ensayo.

4.4 Porcentaje de Elongación: alargamiento expresado como un porcentaje de la longitud calibrada inicial (L_o).

4.4.1 Porcentaje de elongación permanente: Incremento de la longitud calibrada inicial en una probeta de ensayo después de eliminar el esfuerzo especificado (véase el numeral 4.9) y expresado como un porcentaje de la longitud calibrada inicial (L_o).

4.4.2 Porcentaje de elongación después de la rotura (A): elongación permanente de la longitud calibrada inicial después de la rotura ($L_u - L_o$) expresado como un porcentaje de la longitud calibrada inicial (L_o).

Nota. En el caso de probetas de ensayo proporcionales, solamente si la longitud calibrada inicial es diferente de $5.65 \sqrt{S_o}$ en donde S_o es la sección transversal de la longitud paralela, el símbolo A se complementa con un índice, que indica el coeficiente de proporcionalidad usado, por ejemplo:

A 11,3 = significa el porcentaje de elongación en una longitud calibrada (L_o) de $11,3 \sqrt{S_o}$.

En el caso de probetas de ensayo no proporcionales, el símbolo A se complementa con un índice que indica la longitud calibrada inicial usada, expresada en milímetros, por ejemplo:

A 80 mm significa el porcentaje de elongación en una longitud calibrada (L_o) de 80 mm.

4.4.3 Porcentaje de elongación total a la rotura (A_t): alargamiento total (elongación elástica más elongación plástica) de la longitud calibrada en el momento de la rotura, expresado como un porcentaje de la longitud calibrada inicial (L_o).

4.4.4 Porcentaje de elongación al esfuerzo máximo: es el aumento en la longitud calibrada de la probeta cuando la fuerza es máxima, expresado como un porcentaje de la longitud calibrada inicial (L_o) Se hace una distinción entre el porcentaje de elongación total a la carga máxima (A_{gt}) y el porcentaje de elongación no proporcional a la carga máxima (A_g) (véase la Figura 1).

4.5 Longitud calibrada del extensómetro (L_e): longitud de la sección paralela de la probeta de ensayo usada para la medición del alargamiento por medio de un extensómetro (esta longitud puede diferir de L_o y debe tener un valor más grande que b, d o D (véase la Tabla 1) pero menor que la longitud paralela (L_c).

4.6 Alargamiento: incremento de la longitud calibrada (L_e) en el extensómetro en un momento dado del ensayo.

4.6.1 Porcentaje de alargamiento permanente: incremento de la longitud calibrada en el extensómetro después de suspender en la probeta de ensayo un esfuerzo especificado, se expresa como un porcentaje de la longitud calibrada de extensómetro (L_e).

4.6.2 Porcentaje de alargamiento en el límite de fluencia (A_e): alargamiento entre el inicio de la ductilidad dada por una deformación localizada y el comienzo de la deformación permanente dada por un suave trabajo de endurecimiento. Se expresa como un porcentaje de la longitud calibrada del extensómetro (L_e).

4.7 Porcentaje de reducción de área (Z): cambio máximo en el área de la sección transversal que ha ocurrido durante el ensayo (S_o-S_u) expresado como un porcentaje del área de la sección transversal inicial (S_o).

4.8 Esfuerzo máximo (F_m): la carga más alta que ha resistido la probeta durante el ensayo, una vez ha sido superado el límite de fluencia.

4.9 Esfuerzo: carga en cualquier momento del ensayo dividida por el área de la sección transversal inicial (S_o) de la probeta de ensayo.

4.9.1 Resistencia a la tensión (R_m): esfuerzo correspondiente a la máxima carga (F_m).

4.9.2 Resistencia a la fluencia (Límite de fluencia): cuando el material metálico muestra un fenómeno de cedencia, se alcanza un punto durante el ensayo en el cual la deformación plástica aparece sin ningún incremento en la carga. Se hace una distinción entre:


4.9.2.1 Límite de fluencia superior (R_{eH}): valor del esfuerzo en el momento en que se observa el primer decrecimiento de la carga (véase la Figura 2).

4.9.2.2 Límite de fluencia inferior (R_{el}): el valor más bajo del esfuerzo en el campo plástico, ignorando cualquier efecto transitorio (véase la Figura 2).

4.9.3 Prueba de resistencia con alargamiento no proporcional (R_p): el esfuerzo al cual el alargamiento no proporcional es igual al porcentaje especificado de la longitud calibrada del extensómetro (L_e) (Véase la Figura 3). El símbolo que se usa es seguido por un sufijo que indica el porcentaje prescrito de la longitud calibrada del extensómetro, por ejemplo $R_p 0,2 \%$.


4.9.4 Prueba de resistencia con alargamiento total (R_t): el esfuerzo al cual la deformación total (deformación elástica más deformación plástica) es igual al porcentaje especificado en la longitud calibrada del extensómetro (L_e) (Véase la Figura 4). El símbolo es seguido por un sufijo que indica el porcentaje prescrito de la longitud calibrada inicial del extensómetro por ejemplo: $R_t 0,5 \%$.

4.9.5 Resistencia a la deformación permanente (R_r): el esfuerzo al cual después de eliminar la carga, la elongación permanente de la longitud calibrada inicial (L_o) o la extensión permanente de la longitud calibrada del extensómetro (L_e) no excede el valor especificado (Véase la Figura 5). El símbolo usado es seguido por un sufijo que indica el porcentaje especificado de la elongación o del alargamiento permanente; por ejemplo: $R_r 0,2 \%$.



Nota. Véase la Tabla 1 para efectos de la explicación de los números referenciados.

Figura 1. Definiciones de elongación



Nota. Véase la Tabla 1 para la explicación correspondiente a los números referenciados.

Figura 2. Definiciones de límite de fluencia superior y límite de fluencia inferior para diferentes tipos de curvas




Figura 3. Prueba de resistencia con alargamiento no proporcional (R_p)




Figura 4. Prueba de resistencia con alargamiento total (R_t)




Figura 5. Resistencia a la deformación permanente (R_r)

5. SÍMBOLOS Y DESIGNACIONES

Los símbolos y sus correspondientes designaciones se relacionan en la Tabla 1.

Tabla 1. Símbolos y designaciones

Número de referencia	Símbolo	Unidades	Designación
Probeta de ensayo			
1	a	mm	Espesor de la probeta de ensayo plana o de la pared de un tubo.
2	b	mm	Ancho de la longitud paralela de la probeta de ensayo plana o ancho promedio de la platina longitudinal tomada de un tubo o ancho de un alambre plano.
3	d	mm	Diámetro de la longitud paralela de una probeta circular o diámetro de un alambre redondo o diámetro interno de un tubo.
4	D	mm	Diámetro externo de un tubo.
5	L _o	mm	Longitud calibrada inicial.
6	L _c	mm	Longitud paralela.
-	L _e	mm	Longitud calibrada del extensómetro.
7	L _t	mm	Longitud total de la probeta.
8	L _u	mm	Longitud final calibrada después de la rotura.
9	S _o	mm ²	Área de la sección transversal original de la longitud paralela.
10	S _u	mm ²	Área mínima de la sección transversal después de la rotura.
11	Z	%	Porcentaje de reducción de área $\frac{S_o - S_u}{S_o} \times 100$
12	-	-	Agarre de las mordazas.
Elongación			
13	-	mm	Elongación después de la rotura L _u -L _o .
14	A	%	Porcentaje de elongación después de la rotura. $\frac{L_u - L_o}{L_o} \times 100$
15	A _e	%	Porcentaje de alargamiento en el límite de fluencia.
16		%	Porcentaje de elongación no proporcional, a la carga máxima F _m .

Continua...

Tabla 1. (Continuación)

Número de referencia	Símbolo	Unidades	Designación
Elongación			
17		%	Porcentaje de elongación total, a la carga máxima Fm.
18	A _t	%	Porcentaje de elongación total a la rotura.
19	-	%	Porcentaje especificado de extensión no proporcional.
20	-	%	Porcentaje de extensión total.
21	-	%	Porcentaje especificado de extensión a la deformación permanente o elongación.
Carga	F _m	N	Carga máxima.
22			Límite de fluencia - Prueba de resistencia - Resistencia a la tensión.
23	R _{eH}	N/mm ²	Límite de fluencia superior.
24	R _{eL}	N/mm ²	Límite de fluencia inferior.
25	R _m	N/mm ²	Resistencia a la tensión.
26	R _p	N/mm ²	Prueba de resistencia con extensión no proporcional.
27	R _r	N/mm ²	Resistencia a la deformación permanente.
28	R _t	N/mm ²	Prueba de resistencia con extensión total.
-	E	N/mm ²	Módulo de elasticidad.

6. PROBETAS DE ENSAYO

6.1 FORMA Y DIMENSIONES

6.1.1 Generalidades

La forma y las dimensiones de las probetas de ensayo dependen de la forma y dimensiones de los productos metálicos y de las propiedades mecánicas que se van a determinar.

La probeta de ensayo se obtiene generalmente por maquinado de una muestra del producto trabajado o fundido. Sin embargo los productos de sección transversal uniforme (perfiles, barras, alambres, etc.) y también las probetas fundidas (fundiciones de hierro y aleaciones no ferrosas) pueden ser sometidas a ensayo sin maquinado.

La sección transversal de las probetas de ensayo puede ser circular, cuadrada, rectangular, anular o en casos especiales de cualquiera otra forma.

Las probetas de ensayo cuya longitud calibrada inicial se relacionada con el área inicial de la sección transversal por la ecuación $Lo = K \sqrt{S_0}$, son llamadas probetas proporcionales. El valor adoptado internacionalmente para K es 5,65. La longitud calibrada inicial no debe ser menor de 20 mm. Cuando el área de la sección transversal de la probeta de ensayo es demasiado pequeña es necesario convenir un valor del coeficiente K más alto (preferiblemente 11,3) o se puede ser usar una probeta no proporcional.

En el caso en que se usen probetas no proporcionales, la longitud calibrada inicial (L_o) se toma independientemente del área de la sección transversal inicial (S_o).

Las tolerancias dimensionales de las probetas de ensayo deben estar de acuerdo con los anexos referenciados (Véase el numeral 6.2).

6.1.2 Probetas maquinadas

Las probetas de ensayo maquinadas deben tener una curva de transición entre los agarres de las mordazas y la longitud paralela si estas son de diferentes dimensiones.

Las dimensiones de este radio de transición pueden ser importantes y se recomienda que se definan en la especificación del material y si no están especificadas, se relacionan en el anexo (véase el numeral 6.2).

Los extremos de agarre pueden ser de cualquier forma siempre y cuando se adapten a las mordazas de la máquina de tensión.

La longitud paralela (L_c) o en el caso en donde la probeta de ensayo no tiene curva de transición, la longitud libre entre las mordazas siempre debe ser mayor que la longitud inicial calibrada (L_o).

6.1.3 Probetas no maquinadas


Si la probeta es de una longitud no maquinada del producto o una barra de ensayo, la longitud libre entre las mordazas debe ser suficiente para que las marcas calibradas queden a una distancia razonable de las mordazas.

Las probetas de ensayo fundidas incorporarán un radio de transición entre los extremos de agarre y la longitud paralela. Las dimensiones de este radio de transición son importantes y se recomienda que se definan en la norma del producto. Los extremos de agarre pueden tener cualquier forma siempre y cuando se adapten a las mordazas de la máquina de tensión. La longitud paralela (L_c) siempre debe ser mayor que la longitud calibrada inicial (L_o).

6.2 TIPOS

Los principales tipos de probetas de ensayo están definidos en los anexos A-D de acuerdo con la forma y tipo de producto, como se indica en la Tabla 2. Se pueden especificar otros tipos de probetas en las normas de producto o por acuerdo.

Tabla 2. Tipos de producto

Tipo de producto		Anexos correspondientes
Láminas - planos 	Alambre - barras - secciones    Con un espesor en milímetros de :	
0,1 ≤ espesor < 3	—	A
—	< 4	B
≥ 3	≥ 4	C
Tubos		D

6.3 PREPARACIÓN DE PROBETAS PARA ENSAYO

Las probeta de ensayo se deben tomar y preparar de acuerdo con los requerimientos de las normas para los diferentes materiales (EU 18, etc).

7. DETERMINACIÓN DEL ÁREA DE LA SECCIÓN TRANSVERSAL INICIAL (S_o)

El área de la sección transversal inicial se calcula a partir de medidas de las dimensiones requeridas. La precisión de estos cálculos depende de la naturaleza y del tipo de la probeta de ensayo. Esta se indica en los anexos A a D para los diferentes tipos de probetas de ensayo.

8. MARCADO DE LA LONGITUD CALIBRADA INICIAL (L_o)

Cada extremo de la longitud calibrada inicial se debe marcar por medio de marcas finas o puntos, pero no por medio de indentaciones que puedan producir fracturas prematuras (véase el numeral 11.2).

Para probetas proporcionales, el valor calculado de la longitud calibrada puede aproximarse al múltiplo de 5 mm más cercano, cuidando que la diferencia entre la longitud calibrada calculada y la marcada sea menor del 10 % de L_o . La longitud calibrada inicial se debe marcar con una precisión de $\pm 1\%$.

Si la longitud paralela (L_c) es mucho mayor que la longitud calibrada inicial, como por ejemplo en probetas de ensayo no maquinadas, se pueden marcar una serie de longitudes calibradas traslapándolas, algunas de ellas se pueden extender hasta las mordazas.

En algunos casos puede ser útil marcarlas sobre la superficie de la probeta de ensayo, en una línea paralela al eje longitudinal a lo largo de la cual se pueden colocar las marcas.

9. PRECISIÓN DE LAS MÁQUINAS DE ENSAYO

Las máquinas de ensayo deben ser verificadas de acuerdo con la norma EN 10002-2 y deben ser de grado 1 o mejor.

El extensómetro debe ser de Clase 1 (ISO/DIS 9513) para la determinación de los límites de fluencia inferior y superior y resistencias de prueba (extensiones no proporcionales); para otras características (con mayor extensión) se puede usar un extensómetro Clase 2 (ISO/DIS 9513).

10. CONDICIONES DEL ENSAYO

10.1 VELOCIDAD DE LA MÁQUINA

10.1.1 Generalidades

A menos que se especifique lo contrario, en la norma del producto, la velocidad de la máquina debe ajustarse a los siguientes requerimientos, que dependen de la naturaleza del material.

Nota. En el caso especial del zinc, la velocidad de deformación debe ser de $(12,5 \pm 5) \%$ por minuto.

10.1.2 Límite de Fluencia y resistencia de prueba

10.1.2.1 Límite de fluencia superior (R_{eH}). Dentro del campo elástico y hasta el límite de fluencia superior la velocidad de separación de las mordazas de la máquina debe mantenerse constante, hasta donde sea posible, y dentro de los límites correspondientes a las velocidades para aplicación de los esfuerzos indicadas en la Tabla 3.

Tabla 3. Velocidades de esfuerzos

Módulo de elasticidad del material N/mm ²	Velocidad de aplicación de esfuerzos N/mm ² · s ⁻¹	
	min.	máx.
< 150 000	2	10
≥ 150 000	6	30

10.1.2.2 Límite de fluencia inferior (R_{eL}). Si se va a determinar solamente el límite de fluencia inferior, la velocidad de aplicación del esfuerzos durante la cedencia de la longitud paralela de la probeta de ensayo debe estar entre 0,000 25/seg. y 0,002 5/seg. La tasa de esfuerzos se debe mantener constante, hasta donde sea posible. Si esta velocidad no se puede regular directamente, se debe fijar por regulación de la velocidad de esfuerzos justamente antes de empezar la fluencia, los controles de la máquina no se deben ajustar hasta completar la cedencia.

En ningún caso la velocidad de aplicación de esfuerzos en el campo elástico debe exceder las velocidades máximas dadas en la Tabla 3.

10.1.2.3 Límites de fluencia Superior e Inferior (R_{eH} y R_{eL}). Si los 2 límites de fluencia son determinados durante el mismo ensayo, las condiciones para determinarlos deben cumplir con (véase el numeral 10.1.1.2).

10.1.2.4 Resistencia de prueba, extensión no proporcional y resistencia de prueba, extensión total (R_p y R_t). La velocidad de aplicación de esfuerzos debe estar entre los límites dados en la Tabla 3. En el campo plástico y hasta la resistencia de prueba (extensión no proporcional o extensión total) la velocidad de aplicación de esfuerzos no debe exceder de 0,002 5/seg.

10.1.3 Resistencia a la tracción (R_m)

10.1.3.1 En el campo plástico. La velocidad de aplicación de esfuerzos en la longitud paralela no debe exceder de 0,008/seg.

10.1.3.2 En el campo elástico. Si el ensayo no incluye la determinación del esfuerzo de fluencia (o esfuerzo de prueba) la velocidad de la máquina puede alcanzar el máximo permitido en el campo plástico.

10.2 MÉTODO DE AGARRE

Las probetas de ensayo se deben adaptar por medios tales como cuñas, roscas, resaltes, mandíbulas hidráulicas, etc.

Cada adaptación se debe hacer hasta asegurar que las probetas de ensayo estén agarradas de tal manera que la fuerza se aplique tan axialmente como sea posible. Esto es de particular importancia cuando se ensayan materiales frágiles o cuando se vayan a determinar esfuerzos de prueba (extensión no proporcional) o esfuerzos de prueba (extensión total) o límite de fluencia.

11. DETERMINACIÓN DEL PORCENTAJE DE ELONGACIÓN DESPUÉS DE LA ROTURA (A)

11.1 El porcentaje de elongación después de la rotura debe ser determinado de acuerdo con la definición dada en el numeral 4.4.2.

Para este propósito, los 2 pedazos rotos de la probeta de ensayo se deben ajustar cuidadosamente de tal manera que sus ejes permanezcan en una línea recta.

Se deben tomar precauciones especiales para asegurar un contacto apropiado entre las partes rotas de la probeta de ensayo cuando se vaya a medir la longitud calibrada final. Esto es particularmente importante en el caso de probetas de ensayo de sección transversal pequeña y probetas de ensayo que tengan valores de elongación bajos.

La elongación después de la rotura ($L_u - L_o$) se debe determinar a un valor lo más próximo a 0,25 mm utilizando un aparato de medida con una resolución de 0,1 mm, y los valores de los porcentajes de elongación después de la rotura se deben redondear o aproximar al 0,5 %. Si el porcentaje de elongación mínimo especificado es menor del 5 %, se recomienda tomar precauciones especiales para determinarlo.

Esta medición es en principio válida solamente si la distancia entre la fractura (rotura) y la marca más cercada no es menor que una tercera parte de la longitud calibrada inicial (L_o). Sin embargo, la medición es válida independientemente de la posición de la rotura, si el porcentaje de elongación después de la rotura alcanza como mínimo el valor especificado y este se debe informar en el reporte o certificado del ensayo.

11.2 Para máquinas con capacidad de medir el alargamiento a la rotura usando un extensómetro, no es necesario marcar las longitudes calibradas. La elongación es medida como el alargamiento total a la rotura, y por consiguiente es necesario deducir la extensión elástica con el fin de obtener el porcentaje de elongación después de la fractura.

En principio, esta medición es válida solamente si la fractura ocurre dentro de la longitud calibrada (L_e). La medición es válida en cuanto a la posición de la sección transversal fracturada si el porcentaje de elongación después de la rotura al menos alcanza el valor especificado y este se debe informar en el certificado del ensayo.

Nota. Si el proceso especifica la determinación del porcentaje de elongación después de la rotura para una longitud dada, la longitud calibrada se debe tomar igual a esa longitud.

11.3 Si la norma del producto lo permite, la elongación se puede medir sobre una longitud fija dada y convertida a una longitud calibrada proporcional usando fórmulas de conversión o tablas acordadas antes de empezar el ensayo (por ejemplo ISO 2566-1 o ISO 2566-2).

Nota. Las comparaciones de porcentajes de elongación son posibles solo cuando la longitud calibrada, el perfil y el área de la sección transversal son las mismas, o cuando el coeficiente de proporcionalidad (K) es el mismo.

11.4 Con el objeto de evitar el rechazo de probetas de ensayo en las cuales puede ocurrir la fractura por fuera de los límites especificados en el numeral 11.1, se puede usar el método basado en la subdivisión de (L_o) en N partes iguales, tal como se describe en el Anexo E.

12. DETERMINACIÓN DE RESISTENCIA DE PRUEBA (extensión no proporcional) (R_p)

12.1 La resistencia de prueba (extensión no proporcional) se determinada a partir del diagrama fuerza / deformación trazando una línea paralela a la parte recta de la curva y a una distancia de esta equivalente al porcentaje no proporcional prescrito, por ejemplo 0,2 %. El punto en el cual esta línea interseca a la curva da la fuerza correspondiente a la resistencia de prueba deseada (extensión no proporcional). Se obtiene con más precisión, dividiendo esta fuerza por el área de la sección transversal inicial de la probeta de ensayo (S_o). (Véase la Figura 3).

Para este caso es esencial un trazado correcto del diagrama fuerza/deformación.

Si la parte recta del diagrama fuerza/deformación no está claramente definida, y no se puede trazar la línea paralela con suficiente precisión, se recomienda el siguiente procedimiento (véase la Figura 6).

Cuando se presume que la resistencia de prueba se ha excedido, la fuerza se reduce a un valor igual al 10 % de la fuerza obtenida. La fuerza se incrementa de nuevo hasta exceder el valor obtenido originalmente. Para determinar la resistencia de prueba deseada, se traza una línea a través del bucle de histéresis. Se traza una línea paralela a esta, a una distancia de la curva original medida a lo largo de la abcisa, igual al porcentaje no proporcional prescrito. La intersección de esta línea paralela y la curva fuerza/deformación da el esfuerzo correspondiente a la resistencia de prueba. Se puede obtener con más precisión dividiendo esta fuerza por el área de la sección transversal inicial de la probeta de ensayo (S_o) (Véase la Figura 6).

12.2 Las propiedades se pueden obtener sin dibujar la curva fuerza/deformación, mediante el uso de equipos automáticos (microprocesador, etc.).




Figura 6. Resistencia de prueba, alargamiento no proporcional (R_p)
(Véase el numeral 12.1)

13. DETERMINACIÓN DE LA RESISTENCIA DE PRUEBA (extensión total) (R_t)


13.1 La resistencia de ensayo (extensión total) se determina con ayuda del diagrama esfuerzo/deformación trazando una línea paralela al eje de la ordenada (eje de esfuerzos) y a una distancia de ésta equivalente al porcentaje de alargamiento total prescrito. El punto en el cual esta línea que intersecta la curva del esfuerzo, corresponde a la resistencia de prueba deseada.

Se puede obtener con más precisión dividiendo este esfuerzo por el área de la sección transversal inicial de la probeta de ensayo (S_0). (Véase la Figura 4).

13.2 Las propiedades se pueden obtener sin dibujar el diagrama esfuerzo/deformación, usando equipos automáticos.


14. MÉTODO DE VERIFICACIÓN DE LA RESISTENCIA DE DEFORMACIÓN PERMANENTE (R_t)

Cuando la probeta de ensayo está sometida a cargas durante 10 s a 12 s correspondientes al esfuerzo especificado y éste se confirma, después de quitar la carga, la deformación permanente o la elongación no es más que el porcentaje especificado para la longitud calibrada inicial.



Nota. Véase la Tabla 1 para la explicación de los números de referencia

Figura 7. Límite de fluencia inferior (R_{eL})



Nota. Véase la Tabla 1 para la explicación de los números de referencia

Figura 8. Fuerza máxima (F_m)

15. CERTIFICADO DE ENSAYOS

El certificado de ensayos debe contener, como mínimo, la siguiente información:

- Referencia a ésta norma (NTC 2);
- Identificación de la probeta de ensayo;
- Naturaleza del material, si se conoce;
- Tipo de probeta de ensayo;
- Localización y dirección del muestreo de las probetas de ensayo; y,
- Medidas características y resultados.

Anexo A

Tipos de probetas de ensayo para productos delgados: láminas, flejes y productos planos 0,1 mm y 3,0 mm de espesor

(Este anexo forma parte integral de la norma)

Para productos con espesor menor de 0,5 mm, es necesario tener precauciones especiales.

A.1 FORMA DE LA PROBETA

Generalmente, la probeta tiene los extremos para sujetarse a las mordazas con extremos más anchos que su sección paralela. La longitud paralela (L_c) que se une con los extremos de la probeta debe terminar por medio de curvas de transición con un radio de por lo menos 12 mm (véase la Figura 9). El ancho de estos extremos debe ser por lo menos de 20 mm y de no más de 40 mm.

La probeta también puede ser una platina de lados paralelos.

Para productos cuyo ancho es menor o igual a 20 mm, el ancho de la probeta puede ser el mismo del producto.

A.2 DIMENSIONES DE LA PROBETA

A.2.1 Probetas no proporcionales

La longitud paralela no debe ser inferior de $L_o + b/2$. En caso de desacuerdo, siempre se debe usar una longitud de $L_o + 2b$ a menos que el material sea insuficiente.

En caso de probetas de lados paralelos de menos de 20 mm de ancho, y a menos que la norma del producto especifique otra cosa, la longitud calibrada inicial (L_o) debe ser igual a 50 mm. Para este tipo de probetas, la longitud libre entre las mordazas debe ser igual a $L_o + 3b$.

Existen dos tipos de probetas no-proporcionales cuyas dimensiones se establecen en la Tabla 4.

Cuando se determinan las dimensiones de las probetas, se aplican las tolerancias dadas en la Tabla 5.

En el caso en que las probetas sean del mismo ancho del producto, el área inicial de la sección transversal (S_o) se puede calcular con base en las dimensiones medidas del material a ensayar.

Se puede tomar como ancho nominal de la probeta el que resulte del maquinado con sus tolerancias, siempre y cuando cumpla las tolerancias de forma que se dan en la Tabla 5, con el fin de tener la medida del ancho de la probeta para efectos del ensayo.

A.2.2 Probetas proporcionales

Para probetas cuyos tamaños están definidos en el numeral A.2.1 se puede tomar la longitud calibrada inicial (L_o) proporcional al área transversal inicial (S_o) utilizando una de las siguientes relaciones:

$$L_o = 5,65 \sqrt{S_o}$$

$$L_o = 11,3 \sqrt{S_o}$$

Tabla 4. Dimensiones de las probetas

Tipo de probeta	Ancho b	Longitud calibrada inicial L_o	Longitud paralela L_c	Dimensiones en milímetros
				Mínima longitud libre entre las mordazas para probetas de lados paralelos
1	$12,5 \pm 1$	50	75	87,5
2	20 ± 1	80	120	140

A.3 PREPARACIÓN DE LAS PROBETAS

Las probetas se deben preparar de tal manera que no afecten las propiedades del metal. Si algunas áreas se han endurecido por efectos de corte o prensado, se deben eliminar por maquinado.

Para materiales muy delgados, se recomienda que las piezas del mismo ancho se corten ensambladas formando un paquete con separadores intermedios de papel. Se recomienda que cada paquete se ensamble con sujetadores a cada lado antes del maquinado para darle las dimensiones finales a las probetas.

A.4 DETERMINACIÓN DEL ÁREA DE LA SECCIÓN TRANSVERSAL INICIAL (S_o)



El área de la sección transversal inicial se calcula a partir de las medidas de las dimensiones de la probeta.

El error en la determinación del área de la sección transversal inicial de la probeta no debe ser mayor de $\pm 2\%$. La mayor parte de este error generalmente se debe a la medición del espesor de la probeta, el error en la medición del ancho no debe ser mayor de $\pm 0,2\%$

Tabla 5. Tolerancias en el ancho de las probetas

Dimensiones y tolerancias en milímetros		
Ancho nominal de la probeta	Tolerancias de maquinado ¹⁾	Tolerancias de forma
12,5	$\pm 0,09$	$\pm 0,04$
20	$\pm 0,10$	$\pm 0,05$

¹⁾ Estas tolerancias se aplican si el valor nominal del área de la sección transversal inicial (So) se incluye en el cálculo sin necesidad de medir su valor.



Nota. Véase la Tabla 1 para la explicación de los números referenciados

Figura 9. Probetas maquinados de sección transversal rectangular
(véase el Anexo A)

Anexo B.

Tipos de probetas usadas para alambres, barras y perfiles de diámetro o espesor inferior a 4 mm

(Este anexo forma parte integral de la norma)


B.1 FORMA DE LA PROBETA

La probeta generalmente es de una parte no maquinada del producto (véase la Figura 10).

B.2 DIMENSIONES DE LA PROBETA

La longitud calibrada inicial (L_0) debe ser de $200 \text{ mm} \pm 2 \text{ mm}$ ó $100 \pm 1 \text{ mm}$ o $11,3 \sqrt{S_0}$ ⁽¹⁾ para productos cuyo diámetro sea mayor o igual a 1 milímetro. La distancia entre mordazas de la máquina debe ser por lo menos igual a $L_0 + 50 \text{ mm}$, excepto cuando se trata de alambres de diámetro pequeño en los que esta distancia puede ser igual a L_0 .

Nota. En casos cuando el porcentaje de elongación después de la rotura no se determina, se debe usar una distancia entre mordazas de por lo menos 50 mm.



Notas:

- 1) La forma de la cabeza de la probeta se da solamente a manera de guía
- 2) Véase la Tabla 1 para la explicación de los números de referencia

Figura 10. Probetas que comprenden una porción no maquinada del producto (Véase el Anexo B)

1) El requisito expuesto en el numeral 6.6.1 no es aplicable en este caso.

B.3 PREPARACIÓN DE LAS PROBETAS

Si el producto se suministra en rollos, se debe tener cuidado al enderezar la probeta.

B.4 DETERMINACIÓN DEL ÁREA TRANSVERSAL INICIAL (S_o)

El área de la sección inicial de la probeta (S_o) se debe medir con una precisión de $\pm 1\%$.

Para productos de sección circular, el área de la sección transversal inicial se calcula por métodos aritméticos, promediando dos mediciones tomadas en dos direcciones perpendiculares.

El área de la sección transversal inicial se puede determinar a partir del peso de una longitud conocida y de su densidad.

Anexo C

Tipos de probetas usadas para láminas, productos planos de espesor igual o mayor de 3 mm, y alambres, barras y secciones de diámetro o espesor mayor de 4 mm

(Este anexo forma parte integral de la norma)

C.1 FORMA DE LAS PROBETAS

Generalmente la probeta es maquinada y la longitud paralela debe rematarse con un radio de transición en los extremos, que deben tener una forma adecuada para agarrarse a las mordazas de la máquina de ensayo (véase la Figura 11).

El radio de transición debe tener por lo menos:

- 2 mm para probetas cilíndricas; y,
- 12 mm para probetas de sección transversal rectangular.

Nota: Para ciertos materiales, estos valores pueden ser muy bajos, y por consiguiente pueden producir la fractura en el área de transición.

Si es necesario, los perfiles, las barras etc., se pueden ensayar sin necesidad de maquinado.

La sección transversal de la probeta puede ser circular, cuadrada rectangular o, en casos especiales, de cualquier forma.

Para piezas de sección transversal rectangular, se recomienda que no excedan de una relación de 8:1 entre el ancho y el espesor de la probeta.

Generalmente, el diámetro en la longitud paralela de las probetas cilíndricas maquinadas no debe ser inferior de 4 mm.

C.2 DIMENSIONES DE LA PROBETA

C.2.1 Longitud paralela de la probeta maquinada


La longitud paralela (L_c) debe ser por lo menos igual a:

- a) $L_o + d/2$ para probetas de sección circular
- b) $L_o + 1,5 \sqrt{S_o}$ para probetas de sección prismática.

En caso de desacuerdo y dependiendo del tipo de probeta, se deben utilizar las longitudes $L_o + 2d$ o $L_o + 1,5 \sqrt{S_o}$, a menos que el material sea insuficiente.

C.2.2 Longitud de la probeta sin maquinar

La longitud libre entre las mordazas de la máquina debe ser adecuada de acuerdo con la distancia entre las marcas y tener una distancia razonable entre estas mordazas.



Notas:

- 1) La forma de las cabezas de la probeta se dan solamente a manera de guía
- 2) Véase la Tabla 1 para la explicación de los números de referencia

Figura 11. Probetas de ensayo proporcionales (véase el Anexo C)

C.2.3 Longitud calibrada inicial (L_o)

C.2.3.1 Probetas proporcionales. Como regla general, las probetas proporcionales se utilizan cuando la longitud calibrada inicial (L_o) se relaciona con el área inicial de la sección transversal (S_o) por medio de la ecuación:

$$L_o = k \sqrt{S_o}$$

Donde k es igual a 5,65 lo que da $L_o = 5d$ para el caso de probetas de sección transversal circular.

Las probetas de sección transversal circular preferiblemente deben tener las dimensiones dadas en la Tabla 6.

Tabla 6. Probetas de sección transversal circular

k	Diámetro d mm	Área transversal inicial (S_o) mm²	Longitud calibrada inicial L_o = k√S_o mm	Longitud paralela mínima L_c mm	Longitud total L_t mm
5,85	20 ± 0,150	314,2	100 ± 1,0	110	Dependen del método de fijación de la probeta en principio: L _t > L _c + 2d
	10 ± 0,075	78,5	50 ± 0,5	55	
	5 ± 0,040	19,6	25 ± 0,25	28	

C.2.3.2 Probetas no-proporcionales. Las probetas no-proporcionales se pueden usar si se especifican en la norma del producto.

C.3 PREPARACIÓN DE LAS PROBETAS

Las tolerancias en las dimensiones transversales de las probetas maquinadas se dan en la Tabla 7.

A continuación se da un ejemplo de la aplicación de estas tolerancias.

a) Tolerancias de maquinado

Si el valor nominal del área de la sección transversal inicial (S_o) se incluye en el cálculo sin haberla medido, se toma el valor de la Tabla 7, por ejemplo ± 0,075 mm para un diámetro nominal de 10 mm, significa que el diámetro de la probeta debe variar dentro de los siguientes valores:

$$10 + 0,075 = 10,075 \text{ mm}$$

$$10 - 0,075 = 9,925 \text{ mm}$$

b) Tolerancias de forma

El valor dado en la Tabla 7 significa que, para probetas con un diámetro nominal de 10 mm que satisfacen las condiciones de maquinado dadas anteriormente, deben presentar una desviación que entre el mayor y el menor valor del diámetro medido no exceda de 0,04 mm

Por consiguiente, si el diámetro mínimo de esta probeta es 9,99 mm, su diámetro máximo no debe ser mayor de

$$9,99 + 0,04 = 10,03 \text{ mm}$$

C.4 DETERMINACIÓN DEL ÁREA TRANSVERSAL (S_o)

El diámetro nominal puede usarse para calcular el área transversal de la sección inicial de las probetas de sección circular que cumplen las tolerancias dadas en la Tabla 7. Para todas las otras formas de probetas, la sección transversal inicial se debe calcular a partir de mediciones de las dimensiones requeridas, con un error que no exceda de $\pm 0,5\%$ en cada dimensión.

Tabla 7. Tolerancias relacionadas con las dimensiones transversales de las probetas

Dimensiones y tolerancias en milímetros			
Designación	Dimensión transversal nominal	Tolerancia de maquinado en la dimensión nominal	Tolerancia de forma
Diámetro de maquinado de probetas de sección transversal	>3 <6 >6 <10 >10 <18 >18 <30	$\pm 0,06$ $\pm 0,075$ $\pm 0,09$ $\pm 0,106$	0,03 0,04 0,04 0,05
Dimensiones transversales de probetas de sección rectangular maquinadas por todos sus cuatro lados		Las mismas tolerancias que las probetas de sección circular	
Dimensiones transversales de probetas de sección rectangular maquinadas solamente en dos lados opuestos	>3 <6 >6 <10 >10 <18 >18 <30 >30 <50		0,18 0,22 0,27 0,33 0,39

Notas de la Tabla 7.

- 1) Estas tolerancias se aplican si el valor nominal del área transversal de la sección inicial (S_o) se incluye en el cálculo sin medir la probeta.
- 2) La desviación máxima entre las mediciones de una dimensión transversal especificada a lo largo de la longitud paralela (L_c) de la probeta.

Anexo D

Tipos de probetas de ensayo para tubos

(Este anexo forma parte integral de la norma)

D.1 FORMA DE LAS PROBETAS

La probeta puede ser ya sea de una parte de un tubo o de una tira (fleje) cortada(o) longitudinal o transversalmente a partir de un tubo que sea del mismo espesor de la pared el tubo (véanse las Figuras 12 y 13), o una probeta de la sección circular maquinada a partir de la pared del tubo.

Las probetas maquinadas transversales, longitudinales y de sección transversal circular se describen en el anexo A para tubos de pared inferior a 3 mm y en el anexo C para tubos de pared igual o mayor a 3 mm. La tira longitudinal generalmente se usa solamente para tubos cuyo espesor de pared es mayor de 0,5 mm. Para ensayos que se realizan en tiras tomadas de tubos soldados, a menos que se especifique otra cosa en la norma del producto, la tira se debe cortar de un sitio lejos de la unión soldada.

D.2 DIMENSIONES DE LAS PROBETAS

D.2.1 Longitud del tubo

Para que pueda ser asegurada por las mordazas en los extremos, la longitud del tubo debe ser tal que permita:

- a) Asegurarlo con pasadores de diámetro apropiado;
- b) o asegurarse con dos láminas planas adaptadas a su diámetro, y luego aplastarlas;
- c) o por aplastamiento.

Las opciones b) y c) solamente se pueden aplicar en tubos de 25 mm o menos. En caso de desacuerdo, solamente se puede usar la opción a).

Los pasadores o láminas deben tener un ancho por lo menos igual al de las mordazas y puede proyectarse más allá de las mordazas para tener una longitud igual al diámetro externo del tubo. Dentro de esta área, la forma de los pasadores o sellos no deben tener ningún efecto sobre la deformación en la longitud calibrada.

La longitud libre entre un pasador o el sello plano y la marca calibrada de la parte más cerrada debe ser mayor de $D/4$; en caso de desacuerdo esta longitud debe ser acordada entre las partes.

D.2.2 Tira transversal o longitudinal

La longitud paralela (L_c) de las tiras longitudinales no debe aplanarse pero los extremos que se sujetan a las mordazas pueden aplanarse con las mordazas en la máquina de ensayo.

Las dimensiones de las probetas transversales o longitudinales, además de las que se dan en los anexos A y C pueden estar especificadas en la norma del producto.

Se deben tomar precauciones especiales cuando se trabajen probetas transversales.

D.2.3 Sección transversal circular maquinada de una pared de un tubo

El muestreo de las probetas debe estar especificado en la norma del producto.

D.3 Determinación del área de la sección transversal inicial (S_o)

El área de la sección transversal inicial de la probeta se debe calcular con una precisión de $\pm 1\%$

El área de la sección transversal inicial de una longitud dada de tubo, o una tira longitudinal o transversal se pueden determinar a partir de la masa de la probeta, de su longitud, y de su densidad.

El área de la sección transversal inicial (S_o) de la probeta se toma sobre una tira longitudinal o transversal y se calcula de acuerdo con la siguiente ecuación:

$$S_o = \frac{(b/4)}{} (D^2 - b^2)^{\frac{1}{2}} + \frac{D^2}{4} \operatorname{arc sen} \frac{b}{D}$$
$$- \frac{(b/4)}{} [(D-2a)^2 - b^2]^{\frac{1}{2}}$$
$$- (D-2a/2)^2 \operatorname{arc sen} \frac{(b/D-2a)}$$

Donde:

a, es el espesor de la pared del tubo;

b, es el promedio del ancho de la tira; y,


D, es el diámetro externo

Se puede utilizar la siguiente ecuación simplificada para probetas longitudinales o transversales:

$$\text{cuando } b/D < 0,25 \quad S_o = ab[1 + b^2/6D(D-2a)]$$

$$\text{cuando } b/D < 0,17 \quad S_o = ab$$



En el caso de un tubo el área de la sección transversal inicial (S_o) se puede calcular así:



Nota. Véase la Tabla 1 para la explicación de los números de referencia

Figura 12. Probetas que comprenden una longitud de tubo (Véase el Anexo D)

$$S_o = 3,1416 \text{ a } (D-a)$$



Notas:

- 1) La forma de las cabezas de la probeta se da solamente como guía
- 2) Véase la Tabla 1 para la explicación de los números de referencia

Figura 13. Probeta cortada de un tubo (Véase el Anexo D)

Anexo E

Medición del porcentaje de elongación después de la rotura, con base en la subdivisión de la longitud calibrada inicial.

(Este anexo forma parte integral de la norma)

Por acuerdo, cuando sea necesario rechazar probetas que no cumplan con la posición de la rotura de acuerdo con las condiciones de 11.1, se pueden usar los siguientes métodos:

- a) Antes del ensayo, subdividir la longitud calibrada inicial L_0 en N partes iguales;
- b) Despues del ensayo, usar el símbolo X para marcar la pieza más corta y el símbolo Y para marcar las divisiones mostradas en la pieza más larga (cuando la distancia de la pieza más larga a partir de la fractura está más cerca a la distancia de la fractura de la marca X).

Si n es el número de intervalos entre X y Y, la elongación después de la fractura se determina así

- 1) Si $N-n$ es un número par (véase la Figura 14a), se mide la distancia entre X y Y y la distancia desde Y a la graduación marcada Z localizada en

$$(N-n)/2$$

intervalos más allá de Y,

se calcula el porcentaje de elongación después de la rotura usando la ecuación

$$A = [(XY + 2YZ - L_0)/L_0] \times 100$$


Si $N-n$ es un número impar (véase la Figura 14b), se mide la distancia entre X y Y y la distancia desde Y hasta la graduación marcada Z' y Z'' localizadas respectivamente en

$$(N-n-1)/2 \quad y \quad (N-n+1)/2$$

intervalos más allá de Y;

se calcula el porcentaje de elongación usando la ecuación:

$$A = [(XY + YZ' + YZ'' - L_0)/L_0] \times 100$$



Nota. La forma de las cabezas de las probetas se proporcionan solo como una guía

Figura 14. Ejemplo de medición de la elongación después de fractura

DOCUMENTO DE REFERENCIA

BRITISH STANDARDS INSTITUTION. Tensile Testing of Metallic Materials. Part 1. Method of Test at Ambient Temperature. London, 1990, 22 p., il. (BS EN 10002-1).